

Chart B - Assessment of Asbestos-Containing Building Materials (ACBM)

All asbestos-containing events listed here are to be inspected during each six-month periodic surveillance for changes in condition. The Institute for Environmental assessment (IEA) highly recommends an in-depth "front end" inspection prior to any general renovation or remodeling to determine if those activities may disrupt building materials that may involve existing or undiscovered asbestos. Potentially inaccessible or exempt asbestos-containing materials not included in this plan may include: adhesives, caulking, putty, woven blankets, curtains, gloves and gaskets, electrical wiring insulation and heat shields above lights, paints and coatings, roofing felts, flashings and shingles, and mineral core fire doors.

Damaged materials which require corrective action to reduce a potential hazard are indicated on Chart A. All non-damaged ACBM identified in Chart B should be monitored through scheduled inspections and removed prior to renovation or demolition activities, or when their condition deteriorates.

District administration will direct another formal inspection by a federally-certified inspector within three (3) years, and will maintain an on-going file for each building. Specific recommendations on how to manage the different types of Asbestos-containing material are identified in the Asbestos Management Plan.

PLEASE NOTE: Based on EPA recommendations, materials analyzed utilizing PLM and found to contain between 0% and 10% should be assumed asbestos containing unless building owner wishes the laboratory to utilize "point counting." For samples analyzed prior to 1994 containing 1% or less (trace) of asbestos, resampling utilizing the 1993 EPA Test Method or point counting is strongly recommended for purposes of demolition or renovation before treating these materials as non-asbestos containing. Contact your local IEA office for questions or additional information.

EPA ASSESSMENT CATEGORIES:	1 = Damaged or significantly damaged TSI ACM	5 = ACBM with potential for damage
	2 = Damaged friable surfacing ACM	6 = ACBM with potential for significant damage
	3 = Significantly damaged friable surfacing ACM	7 = Remaining friable ACBM or friable suspect ACBM
	4 = Damaged or significantly damaged friable miscellaneous ACM	

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
11 CAD #:	X1C	Miscellaneous Material 4" x 8" Red Quarry Tile	THROUGHOUT BUILDING	2000 Sq Ft	N	ASSUMED	5
Comments: MOSTLY ENTRANCES & STAIRWELLS. BROKEN TILE AT 2ND FLOOR ENTRY TO NORTHWEST STAIRWELL 1300A.					Sample #:		
13 CAD #:	X0D	Miscellaneous Material Mirror Mastic	THROUGHOUT BUILDING	50 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
18 CAD #:	X1B	Miscellaneous Material 2" Brown Ceramic Floor Tile System	THROUGHOUT BUILDING RESTROOMS	2000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
27 CAD #:	X1A	Miscellaneous Material 1" Brown Ceramic Floor Tile System	CUSTODIAL ROOM 1503	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
32 CAD #:	T0A	Light Cord Insulation Green, White & Black Cords	AUDITORIUM CATWALK	50 Lin Ft	N	70 CH	5
Comments: SIX (6) LIGHTS W/THREE (3) CORDS EACH. ACCESS FROM ROOM 1406.					Sample #: 2001-1901-2-BCM		
33 CAD #:	T0B	Light Cord Insulation White	AUDITORIUM CATWALK	6 Lin Ft	N	ASSUMED	5
Comments: AT FAR END OF CATWALK.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
34 CAD #:	H1A	Sprayed-On Structural Fireproofing Tan (1971)	AUDITORIUM STAGE 1407	600 Sq Ft	Y	20 CH	5
Comments: IN PLASTER SOFFIT ABOVE FRONT OF STAGE.					Sample #: 2001-1901-BM-15		
36 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1971 Original Building	AUDITORIUM STAGE 1407	1500 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
40 CAD #:	H1A	Sprayed-On Structural Fireproofing Tan (1971)	ROOM 1407B	3 Sq Ft	Y	20 CH	5
Comments: OVERSPRAY ON PIPES & DUCTS.					Sample #: 1991-2728, 2729, 2730		
42 CAD #:	H1A	Sprayed-On Structural Fireproofing Tan (1971)	ROOM 1406	80 Sq Ft	Y	20 CH	5
Comments: INACCESSIBLE IN BLOCK WALL ON COLUMN.					Sample #:		
47 CAD #:	X1A	Miscellaneous Material 1" Brown Ceramic Floor Tile System	ROOM 1306 (BOYS' LOCKER ROOM SHOWER AREA)	400 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
48 CAD #:	X1A	Miscellaneous Material 1" Brown Ceramic Floor Tile System	ROOM 1307A (BOYS' LOCKER ROOM OFFICE)	50 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
52 CAD #:	X1A	Miscellaneous Material 1" Brown Ceramic Floor Tile System	ROOM 1311 (GIRLS' LOCKER ROOM SHOWER AREA)	400 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
53 CAD #:	X1A	Miscellaneous Material 1" Brown Ceramic Floor Tile System	ROOM 1312A (GIRLS' LOCKER ROOM OFFICE)	50 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
54 CAD #:	P0D	Fire Doors Door Transom Panels (Mineral Core)	LOWER LEVEL HALLWAY 1300D OUTSIDE LOCKER ROOMS	12 Sq Ft	N	35 CH, 15 AM	5
Comments: TWO (2) PANELS.					Sample #:		
62 CAD #:	P0D	Fire Doors Door Transom Panels (Mineral Core)	UPPER LEVEL GYMNASIUM HALLWAY 2300B	12 Sq Ft	N	35 CH, 15 AM	5
Comments: TWO (2) PANELS.					Sample #: 2001-1901-XX-45B		
63 CAD #:	K0D	9" x 9" Vinyl Floor Tile & Mastic Gray w/Brown & White Flecks	UPPER GYMNASIUM 2303 & 2304	4300 Sq Ft	N	>1-3 CH (TILE), 10-15 CH (MASTIC)	5
Comments: INCLUDES PATCHED TILE. MASTIC EXPOSED BY WEST ENTRANCE TO ROOM 2304. SEALED WITH WAX.					Sample #: 2001-1501-BM-11, ; 2001-1901-ZZ-33B		
65 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 1205	1500 Sq Ft	Y	2-4 CH	5
Comments:					Sample #: 11-03-08-MA-08		
69 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 1206	2500 Sq Ft	Y	2-4 CH	5
Comments: ABOVE CEILING.					Sample #:		
76 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 1207	1000 Sq Ft	Y	2-4 CH	5
Comments: ABOVE CEILING. SUSPECT DEBRIS ON CEILING TILES ANALYZED AS "NONE DETECTED".					Sample #: 08092012MA-08		
81 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 1208	2500 Sq Ft	Y	2-4 CH	5
Comments: ABOVE CEILING.					Sample #: 11-03-08-MA-12		
85 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	1ST FLOOR HALLWAY 1004	1000 Sq Ft	Y	2-4 CH	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
87 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 1201	2500 Sq Ft	Y	2-4 CH	5
Comments: ABOVE CEILING.					Sample #:		
92 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 1202	2000 Sq Ft	Y	2-4 CH	5
Comments: ABOVE CEILING.					Sample #:		
97 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 1203	2500 Sq Ft	Y	2-4 CH	5
Comments: ABOVE CEILING.					Sample #:		
101 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	HALLWAY EAST OF ROOMS 1204 & 1205	1080 Sq Ft	Y	2-4 CH	5
Comments:					Sample #:		
102 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 1204	2500 Sq Ft	Y	2-4 CH	5
Comments:					Sample #:		
105 CAD #:	POD	Fire Doors Door Transom Panels (Mineral Core)	ROOM 1114	6 Sq Ft	N	35 CH, 15 AM	5
Comments: ONE (1) PANEL.					Sample #:		
121 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Dark Gray w/White Streaks	ELEVATOR	30 Sq Ft	N	3 CH (TILE)	5
Comments: FOUR (4) TILES CHIPPED W/PIECES MISSING. RECOMMEND SEALING WITH WAX.					Sample #: 11-03-08-MA-17		
127 CAD #:	H1A	Sprayed-On Structural Fireproofing Tan (1971)	ROOM 1007 (PRINCIPAL'S OFFICE)	120 Sq Ft	Y	20 CH	5
Comments: ABOVE CEILING. INACCESSIBLE AT BACK OF I-BEAM.					Sample #:		
128 CAD #:	K0D	9" x 9" Vinyl Floor Tile & Mastic Gray w/Brown & White Flecks	ROOM 1010 (OFFICE STORAGE)	276 Sq Ft	N	>1-3 CH (TILE), 10-15 CH (MASTIC)	5
Comments: LABELED 'SUPPLY CENTER'. TILE STARTING TO COME LOOSE. RECOMMEND SEALING WITH WAX.					Sample #: 310-8		
131 CAD #:	K0D	9" x 9" Vinyl Floor Tile & Mastic Gray w/Brown & White Flecks	ROOM 1003 (NURSE'S OFFICE)	175 Sq Ft	N	>1-3 CH (TILE), 10-15 CH (MASTIC)	5
Comments: TILE WORN IN MIDDLE OF ROOM AND NEAR FILING CABINETS. RECOMMEND CHAIR MAT. SEALED WITH WAX.					Sample #:		
133 CAD #:	K0D	9" x 9" Vinyl Floor Tile & Mastic Gray w/Brown & White Flecks	ROOM 1020 (BOYS' COT ROOM) OFF ROOM 1022	168 Sq Ft	N	>1-3 CH (TILE), 10-15 CH (MASTIC)	5
Comments:					Sample #:		
134 CAD #:	K0D	9" x 9" Vinyl Floor Tile & Mastic Gray w/Brown & White Flecks	ROOM 1021 (GIRLS' COT ROOM) OFF ROOM 1022	168 Sq Ft	N	>1-3 CH (TILE), 10-15 CH (MASTIC)	5
Comments: TILES STARTING TO COME LOOSE. MONITOR.					Sample #:		
135 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 1610	1400 Sq Ft	Y	2-4 CH	5
Comments:					Sample #:		
137 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 1609	1400 Sq Ft	Y	2-4 CH	5
Comments:					Sample #: 11-04-08-MA-09		
139 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 1608	1500 Sq Ft	Y	2-4 CH	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
141 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 1607	1500 Sq Ft	Y	2-4 CH	5
Comments:					Sample #:		
143 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	1ST FLOOR HALLWAY 1007	1080 Sq Ft	Y	2-4 CH	5
Comments:					Sample #:		
144 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 1606	2000 Sq Ft	Y	2-4 CH	5
Comments:					Sample #:		
146 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 1605	1100 Sq Ft	Y	2-4 CH	5
Comments:					Sample #: 11-04-08-MA-10		
148 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 1604	1500 Sq Ft	Y	2-4 CH	5
Comments:					Sample #:		
150 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 1603	1500 Sq Ft	Y	2-4 CH	5
Comments:					Sample #:		
154 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 1602	700 Sq Ft	Y	2-4 CH	5
Comments:					Sample #:		
155 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 1601	1200 Sq Ft	Y	2-4 CH	5
Comments:					Sample #:		
157 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	2ND FLOOR CENTER STAIR AREAS 2009-2010	3600 Sq Ft	Y	2-4 CH	5
Comments: WATER STAINING NEAR SKYLIGHTS. MONITOR.					Sample #:		
166 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 2204 (LIBRARY)	10000 Sq Ft	Y	2-4 CH	5
Comments:					Sample #: 11-04-08-MA-08		
170 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 2601	1500 Sq Ft	Y	2-4 CH	5
Comments:					Sample #:		
172 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 2602	1500 Sq Ft	Y	2-4 CH	5
Comments:					Sample #:		
174 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 2603	1500 Sq Ft	Y	2-4 CH	5
Comments:					Sample #:		
176 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 2605	1200 Sq Ft	Y	2-4 CH	5
Comments:					Sample #:		
179 CAD #:	K0C	9" x 9" Vinyl Floor Tile & Mastic Beige w/Tan Swirls	ROOM 2504	1456 Sq Ft	N	>1-4 CH (TILE), 10-15 CH (MASTIC)	5
Comments: SMALL CHIP AND SEVERAL CRACKS BY ENTRANCE. SEALED WITH WAX.					Sample #: 310-11		
180 CAD #:	K0C	9" x 9" Vinyl Floor Tile & Mastic Beige w/Tan Swirls	ROOM 2507 OFF ROOM 2504	126 Sq Ft	N	>1-4 CH (TILE), 10-15 CH (MASTIC)	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
185 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	2ND FLOOR HALLWAY 2600B	1080 Sq Ft	Y	2-4 CH	5
Comments:					Sample #:		
186 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 2606	1600 Sq Ft	Y	2-4 CH	5
Comments:					Sample #: 11-04-08-MA-06		
188 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 2608	1300 Sq Ft	Y	2-4 CH	5
Comments:					Sample #:		
190 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 2609	1600 Sq Ft	Y	2-4 CH	5
Comments:					Sample #:		
192 CAD #:	G1A	Sprayed-On Acoustical Finish Thin, White Texture	ROOM 2610	1600 Sq Ft	Y	2-4 CH	5
Comments:					Sample #: 11-04-08-MA-02		
194 CAD #:	K0D	9" x 9" Vinyl Floor Tile & Mastic Gray w/Brown & White Flecks	ROOM 2617	1170 Sq Ft	N	>1-3 CH (TILE), 10-15 CH (MASTIC)	5
Comments: CHIPS AND SCRATCHES IN TILE THROUGHOUT. MONITOR. INCLUDES REPLACEMENT TILES NEAR WHITEBOARD.					Sample #:		
197 CAD #:	K0D	9" x 9" Vinyl Floor Tile & Mastic Gray w/Brown & White Flecks	ROOM 2619 OFF ROOM 2617	145 Sq Ft	N	>1-3 CH (TILE), 10-15 CH (MASTIC)	5
Comments: TILE WORN UNDER CHAIR. RECOMMEND INSTALLING CHAIR MAT.					Sample #:		
198 CAD #:	K0D	9" x 9" Vinyl Floor Tile & Mastic Gray w/Brown & White Flecks	ROOM 2618 OFF ROOM 2617	100 Sq Ft	N	>1-3 CH (TILE), 10-15 CH (MASTIC)	5
Comments:					Sample #:		
199 CAD #:	K0D	9" x 9" Vinyl Floor Tile & Mastic Gray w/Brown & White Flecks	ROOM 2614	1170 Sq Ft	N	>1-3 CH (TILE), 10-15 CH (MASTIC)	5
Comments: SCRATCHES IN TILE THROUGHOUT. CHIPS IN TILE IN NORTHWEST CORNER WITH EXPOSED MASTIC. SEALED WITH WAX.					Sample #:		
202 CAD #:	K0D	9" x 9" Vinyl Floor Tile & Mastic Gray w/Brown & White Flecks	ROOM 2616 OFF ROOM 2614	200 Sq Ft	N	>1-3 CH (TILE), 10-15 CH (MASTIC)	5
Comments: UNDER CARPET.					Sample #:		
203 CAD #:	K0D	9" x 9" Vinyl Floor Tile & Mastic Gray w/Brown & White Flecks	ROOM 2615 OFF ROOM 2614	154 Sq Ft	N	>1-3 CH (TILE), 10-15 CH (MASTIC)	5
Comments:					Sample #:		
204 CAD #:	K2G	12" x 12" Vinyl Floor Tile & Mastic Tan w/Brown, White & Pink Flecks	ROOM 2611	342 Sq Ft	N	10 CH (MASTIC)	5
Comments:					Sample #: 11-04-08-MA-04		
205 CAD #:	K0D	9" x 9" Vinyl Floor Tile & Mastic Gray w/Brown & White Flecks	ROOM 2611	828 Sq Ft	N	>1-3 CH (TILE), 10-15 CH (MASTIC)	5
Comments:					Sample #:		
208 CAD #:	K0D	9" x 9" Vinyl Floor Tile & Mastic Gray w/Brown & White Flecks	ROOM 2613 OFF ROOM 2611	120 Sq Ft	N	>1-3 CH (TILE), 10-15 CH (MASTIC)	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
209 CAD #:	K0D	9" x 9" Vinyl Floor Tile & Mastic Gray w/Brown & White Flecks	ROOM 2612 OFF ROOM 2611	100 Sq Ft	N	>1-3 CH (TILE), 10-15 CH (MASTIC)	5
Comments: TILE WORN UNDER CHAIR. RECOMMEND INSTALLING CHAIR MAT.						Sample #:	
213 CAD #:	K0C	9" x 9" Vinyl Floor Tile & Mastic Beige w/Tan Swirls	ROOM 2104 (CAFETERIA)	3986 Sq Ft	N	>1-4 CH (TILE), 10-15 CH (MASTIC)	5
Comments: TILE CHIPPED WITH MASTIC EXPOSED NEAR SERVING LINE, CHIPPED TILE, AND IN SW CORNER ALONG QUARRY TILE BORDER. LOOSE TILE AT SOUTH END OF RADIATOR ON EAST WALL. SEALED WITH WAX. MONITOR.						Sample #: 2001-01105-26, ; 2001-1901-ZZ-32B	
215 CAD #:	K0C	9" x 9" Vinyl Floor Tile & Mastic Beige w/Tan Swirls	ROOM 2105 (FACULTY DINING)	378 Sq Ft	N	>1-4 CH (TILE), 10-15 CH (MASTIC)	5
Comments:						Sample #:	
217 CAD #:	K0C	9" x 9" Vinyl Floor Tile & Mastic Beige w/Tan Swirls	ROOM 2106C (KITCHEN OFFICE)	80 Sq Ft	N	>1-4 CH (TILE), 10-15 CH (MASTIC)	5
Comments: TILE WORN UNDER CHAIR. RECOMMEND INSTALLING CHAIR MAT.						Sample #:	