

## Chart B - Assessment of Asbestos-Containing Building Materials (ACBM)

All asbestos-containing events listed here are to be inspected during each six-month periodic surveillance for changes in condition. The Institute for Environmental assessment (IEA) highly recommends an in-depth "front end" inspection prior to any general renovation or remodeling to determine if those activities may disrupt building materials that may involve existing or undiscovered asbestos. Potentially inaccessible or exempt asbestos-containing materials not included in this plan may include: adhesives, caulking, putty, woven blankets, curtains, gloves and gaskets, electrical wiring insulation and heat shields above lights, paints and coatings, roofing felts, flashings and shingles, and mineral core fire doors.

Damaged materials which require corrective action to reduce a potential hazard are indicated on Chart A. All non-damaged ACBM identified in Chart B should be monitored through scheduled inspections and removed prior to renovation or demolition activities, or when their condition deteriorates.

District administration will direct another formal inspection by a federally-certified inspector within three (3) years, and will maintain an on-going file for each building. Specific recommendations on how to manage the different types of Asbestos-containing material are identified in the Asbestos Management Plan.

**PLEASE NOTE:** Based on EPA recommendations, materials analyzed utilizing PLM and found to contain between 0% and 10% should be assumed asbestos containing unless building owner wishes the laboratory to utilize "point counting." For samples analyzed prior to 1994 containing 1% or less (trace) of asbestos, resampling utilizing the 1993 EPA Test Method or point counting is strongly recommended for purposes of demolition or renovation before treating these materials as non-asbestos containing. Contact your local IEA office for questions or additional information.

| EPA ASSESSMENT CATEGORIES:                                                                               |               | 1 = Damaged or significantly damaged TSI ACM<br>2 = Damaged friable surfacing ACM<br>3 = Significantly damaged friable surfacing ACM<br>4 = Damaged or significantly damaged friable miscellaneous ACM |                                              | 5 = ACBM with potential for damage<br>6 = ACBM with potential for significant damage<br>7 = Remaining friable ACBM or friable suspect ACBM |                                            |                                                                                 |                         |
|----------------------------------------------------------------------------------------------------------|---------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------|---------------------------------------------------------------------------------|-------------------------|
| IEA Event No.                                                                                            | Material Type | Material Description/Id                                                                                                                                                                                | Location                                     | Estimated Amount Total                                                                                                                     | Friability                                 | % of Asbestos                                                                   | EPA Assessment Category |
| 9<br>CAD #:                                                                                              | S0A           | Wood Floor Felt / Vapor Barrier<br>1921 Original Building                                                                                                                                              | THROUGHOUT 1921 ORIGINAL BUILDING            | 10000 Sq Ft                                                                                                                                | N                                          | ASSUMED                                                                         | 5                       |
| Comments:                                                                                                |               |                                                                                                                                                                                                        |                                              |                                                                                                                                            | Sample #:                                  |                                                                                 |                         |
| 13<br>CAD #:                                                                                             | D2A           | Interior Boiler Insulation<br>Firebox Insulation                                                                                                                                                       | BOILER ROOM (1114)                           | 100 Sq Ft                                                                                                                                  | N                                          | ASSUMED                                                                         | 5                       |
| Comments: TWO (2) BOILERS.                                                                               |               |                                                                                                                                                                                                        |                                              |                                                                                                                                            | Sample #:                                  |                                                                                 |                         |
| 21<br>CAD #:                                                                                             | X0R           | Miscellaneous Material<br>Firebox Brick and Mortar                                                                                                                                                     | CUSTODIAL STORAGE (1114A) OFF OF BOILER ROOM | 40 Sq Ft                                                                                                                                   | N                                          | NONE<br>DETECTED<br>(BRICK AND<br>HARD<br>MORTAR), 7-<br>15 CH (SOFT<br>MORTAR) | 5                       |
| Comments: 1114A IS NO LONGER ACCESSIBLE. AREA HAS BEEN FILLED IN. MATERIAL REMAINS IN ABANDONED FIREBOX. |               |                                                                                                                                                                                                        |                                              |                                                                                                                                            | Sample #: 070924-BF-1, 2, 3, 4, 5, 6, 7, 8 |                                                                                 |                         |
| 23<br>CAD #:                                                                                             | K2H           | 12" x 12" Vinyl Floor Tile & Mastic<br>Off-White w/Brown Streaks                                                                                                                                       | SUB-BASEMENT OFF OF BOILER ROOM              | 25 Sq Ft                                                                                                                                   | N                                          | <1 CH (TILE), 5<br>CH (MASTIC)                                                  | 5                       |
| Comments: STACKED ON SHELF.                                                                              |               |                                                                                                                                                                                                        |                                              |                                                                                                                                            | Sample #:                                  |                                                                                 |                         |
| 25<br>CAD #:                                                                                             | S0C           | Wood Floor Felt / Vapor Barrier<br>1931 Addition                                                                                                                                                       | THROUGHOUT 1931 ADDITION                     | 5000 Sq Ft                                                                                                                                 | N                                          | ASSUMED                                                                         | 5                       |
| Comments:                                                                                                |               |                                                                                                                                                                                                        |                                              |                                                                                                                                            | Sample #:                                  |                                                                                 |                         |

| IEA<br>Event<br>No.                                                                                              | Material<br>Type | Material Description/Id                                          | Location                                              | Estimated<br>Amount Total | Friability                           | % of<br>Asbestos                   | EPA Assess<br>Category |
|------------------------------------------------------------------------------------------------------------------|------------------|------------------------------------------------------------------|-------------------------------------------------------|---------------------------|--------------------------------------|------------------------------------|------------------------|
| 27<br>CAD #:                                                                                                     | B1C              | Air Cell Pipe Insulation<br>1931 Addition                        | CAFETERIA (1101)                                      | 180 Lin Ft                | N                                    | ASSUMED                            | 5                      |
| Comments: ESTIMATED IN CEILING & WALL SOFFITS. SOME VISIBLE AT PENETRATION NEAR STAGE. INACCESSIBLE FOR REMOVAL. |                  |                                                                  |                                                       |                           | Sample #:                            |                                    |                        |
| 28<br>CAD #:                                                                                                     | A1C              | Mudded Pipe Joints on Air Cell Insulation<br>1931 Addition       | CAFETERIA (1101)                                      | 15 Joints                 | N                                    | ASSUMED                            | 5                      |
| Comments: ESTIMATED IN CEILING & WALL SOFFITS. SOME VISIBLE AT PENETRATION NEAR STAGE. INACCESSIBLE FOR REMOVAL. |                  |                                                                  |                                                       |                           | Sample #:                            |                                    |                        |
| 37<br>CAD #:                                                                                                     | X0L              | Miscellaneous Material<br>Corkboard Adhesive (1931)              | ROOM 1105                                             | 100 Sq Ft                 | N                                    | ASSUMED                            | 5                      |
| Comments: THIN METAL CASING. FOUR (4) BOARDS.                                                                    |                  |                                                                  |                                                       |                           | Sample #:                            |                                    |                        |
| 38<br>CAD #:                                                                                                     | X0I              | Miscellaneous Material<br>Corkboard Adhesive (1931)              | ROOM 1105                                             | 16 Sq Ft                  | N                                    | 3 CH                               | 5                      |
| Comments: SOUTHWEST CORNER. PARTIALLY REMOVED. SOME REMAINS BEHIND FALSE WALL BY SINK.                           |                  |                                                                  |                                                       |                           | Sample #: 062911BF-1                 |                                    |                        |
| 39<br>CAD #:                                                                                                     | X0I              | Miscellaneous Material<br>Corkboard Adhesive (1931)              | ROOM 1105                                             | 10 Sq Ft                  | N                                    | 3 CH                               | 5                      |
| Comments: ONE (1) BOARD NEAR ENTRANCE.                                                                           |                  |                                                                  |                                                       |                           | Sample #:                            |                                    |                        |
| 40<br>CAD #:                                                                                                     | X0P              | Miscellaneous Material<br>Black Wall Coating                     | STORAGE 1109                                          | 125 Sq Ft                 | N                                    | ASSUMED                            | 5                      |
| Comments:                                                                                                        |                  |                                                                  |                                                       |                           | Sample #:                            |                                    |                        |
| 41<br>CAD #:                                                                                                     | X0P              | Miscellaneous Material<br>Black Wall Coating                     | MECHANICAL 1110                                       | 250 Sq Ft                 | N                                    | ASSUMED                            | 5                      |
| Comments:                                                                                                        |                  |                                                                  |                                                       |                           | Sample #:                            |                                    |                        |
| 42<br>CAD #:                                                                                                     | X0I              | Miscellaneous Material<br>Corkboard Adhesive (1931)              | STAIRWELL 1199A                                       | 5 Sq Ft                   | N                                    | 3 CH                               | 5                      |
| Comments: ONE (1) BOARD AT BOTTOM OF STAIRWELL.                                                                  |                  |                                                                  |                                                       |                           | Sample #:                            |                                    |                        |
| 44<br>CAD #:                                                                                                     | X0C              | Miscellaneous Material<br>Wood Frame Chalkboard Adhesive (1921)  | ROOM 1113                                             | 10 Sq Ft                  | N                                    | ASSUMED                            | 5                      |
| Comments:                                                                                                        |                  |                                                                  |                                                       |                           | Sample #:                            |                                    |                        |
| 48<br>CAD #:                                                                                                     | X0O              | Miscellaneous Material<br>Wood Frame Corkboard Adhesive (1921)   | 1921 ORIGINAL BUILDING 1ST FLOOR HALLWAY NEAR KITCHEN | 15 Sq Ft                  | N                                    | ASSUMED                            | 5                      |
| Comments: ONE (1) BOARD.                                                                                         |                  |                                                                  |                                                       |                           | Sample #:                            |                                    |                        |
| 52<br>CAD #:                                                                                                     | X0C              | Miscellaneous Material<br>Wood Frame Chalkboard Adhesive (1921)  | ROOM 1123                                             | 10 Sq Ft                  | N                                    | ASSUMED                            | 5                      |
| Comments: ESTIMATED BEHIND WHITEBOARD.                                                                           |                  |                                                                  |                                                       |                           | Sample #:                            |                                    |                        |
| 58<br>CAD #:                                                                                                     | S0B              | Wood Floor Felt / Vapor Barrier<br>1924 Addition                 | THROUGHOUT 1924 ADDITION                              | 5000 Sq Ft                | N                                    | ASSUMED                            | 5                      |
| Comments:                                                                                                        |                  |                                                                  |                                                       |                           | Sample #:                            |                                    |                        |
| 63<br>CAD #:                                                                                                     | X0J              | Miscellaneous Material<br>Corkboard Adhesive (1924)              | ROOM 1135                                             | 40 Sq Ft                  | N                                    | ASSUMED                            | 5                      |
| Comments: THIN METAL CASING. TWO (2) BOARDS.                                                                     |                  |                                                                  |                                                       |                           | Sample #:                            |                                    |                        |
| 76<br>CAD #:                                                                                                     | K2C              | 12" x 12" Vinyl Floor Tile & Mastic<br>Off-White w/Tan Smudges   | IMC SOUTHEAST ENTRY (1299B)                           | 90 Sq Ft                  | N                                    | <1 CH (TILE),<br>10 CH<br>(MASTIC) | 5                      |
| Comments: INCLUDES CLOSET. TILES CHIPPING W/EXPOSED MASTIC LEFT OF STAIRS.                                       |                  |                                                                  |                                                       |                           | Sample #: 012109ML-42; 2001-0301-JC3 |                                    |                        |
| 77<br>CAD #:                                                                                                     | K3B              | Miscellaneous Flooring<br>Tan w/White Swirls Stair Treads        | IMC SOUTHEAST ENTRY (1299B)                           | 50 Sq Ft                  | N                                    | 2 CH (TREAD)                       | 5                      |
| Comments: MASTIC IS NON-ACM.                                                                                     |                  |                                                                  |                                                       |                           | Sample #: 012109ML-43                |                                    |                        |
| 78<br>CAD #:                                                                                                     | K0C              | 9" x 9" Vinyl Floor Tile & Mastic<br>Tan w/Brown & White Streaks | IMC SOUTHEAST ENTRY (1299B)                           | 2 Sq Ft                   | N                                    | 5 CH (TILE &<br>MASTIC)            | 5                      |
| Comments: TOP OF STAIRS. CHIPPED AT EXIT W/EXPOSED MASTIC.                                                       |                  |                                                                  |                                                       |                           | Sample #: 2001-1501-AG20             |                                    |                        |

| IEA Event No.                                   | Material Type | Material Description/Id                                                    | Location                                             | Estimated Amount Total | Friability                            | % of Asbestos                              | EPA Assess Category |
|-------------------------------------------------|---------------|----------------------------------------------------------------------------|------------------------------------------------------|------------------------|---------------------------------------|--------------------------------------------|---------------------|
| 79<br>CAD #:                                    | K2G           | 12" x 12" Vinyl Floor Tile & Mastic<br>Light Brown w/Brown & White Smudges | IMC OFFICE (1201)                                    | 300 Sq Ft              | N                                     | 10 CH (MASTIC)                             | 5                   |
| Comments:                                       |               |                                                                            |                                                      |                        | Sample #: 012109ML-40; 2001-1501-AG14 |                                            |                     |
| 80<br>CAD #:                                    | K3D           | Miscellaneous Flooring<br>1' X 2' Brown Stair Treads                       | STAIRS (1200A) TO UPPER FAN ROOM                     | 50 Sq Ft               | N                                     | 5 CH (TREAD),<br>NONE<br>DETECTED (MASTIC) | 5                   |
| Comments: ONE (1) LOOSE & CRACKED TREAD.        |               |                                                                            |                                                      |                        | Sample #: 012109ML-17                 |                                            |                     |
| 92<br>CAD #:                                    | K2H           | 12" x 12" Vinyl Floor Tile & Mastic<br>Off-White w/Brown Streaks           | HALLWAY RAMP TO REC CENTER & REC CENTER COMMONS AREA | 780 Sq Ft              | N                                     | <1 CH (TILE), 5 CH (MASTIC)                | 5                   |
| Comments: BLACK TRACTION SPECS ON TOP OF TILES. |               |                                                                            |                                                      |                        | Sample #: 2001-1501-AG15              |                                            |                     |
| 94<br>CAD #:                                    | K2H           | 12" x 12" Vinyl Floor Tile & Mastic<br>Off-White w/Brown Streaks           | REC CENTER KITCHEN                                   | 130 Sq Ft              | N                                     | <1 CH (TILE), 5 CH (MASTIC)                | 5                   |
| Comments:                                       |               |                                                                            |                                                      |                        | Sample #: 012109ML-48                 |                                            |                     |
| 96<br>CAD #:                                    | K2H           | 12" x 12" Vinyl Floor Tile & Mastic<br>Off-White w/Brown Streaks           | ACTIVITY ROOM (1321) NEXT TO KITCHEN                 | 420 Sq Ft              | N                                     | <1 CH (TILE), 5 CH (MASTIC)                | 5                   |
| Comments: PARTIALLY CARPETED.                   |               |                                                                            |                                                      |                        | Sample #:                             |                                            |                     |
| 100<br>CAD #:                                   | K2H           | 12" x 12" Vinyl Floor Tile & Mastic<br>Off-White w/Brown Streaks           | STORAGE ROOM (1321A) OFF ACTIVITY ROOM               | 225 Sq Ft              | N                                     | <1 CH (TILE), 5 CH (MASTIC)                | 5                   |
| Comments:                                       |               |                                                                            |                                                      |                        | Sample #:                             |                                            |                     |
| 106<br>CAD #:                                   | K2H           | 12" x 12" Vinyl Floor Tile & Mastic<br>Off-White w/Brown Streaks           | STORAGE ROOM EAST OF KITCHEN                         | 180 Sq Ft              | N                                     | <1 CH (TILE), 5 CH (MASTIC)                | 5                   |
| Comments: INCLUDES SMALL STORAGE CLOSET.        |               |                                                                            |                                                      |                        | Sample #:                             |                                            |                     |
| 118<br>CAD #:                                   | X0G           | Miscellaneous Material<br>Wood Frame Chalkboard Adhesive (1931)            | ROOM 2103                                            | 15 Sq Ft               | N                                     | ASSUMED                                    | 5                   |
| Comments: BEHIND NEW WHITEBOARD.                |               |                                                                            |                                                      |                        | Sample #:                             |                                            |                     |
| 123<br>CAD #:                                   | X0G           | Miscellaneous Material<br>Wood Frame Chalkboard Adhesive (1931)            | ROOM 2109                                            | 20 Sq Ft               | N                                     | ASSUMED                                    | 5                   |
| Comments: BEHIND NEW WHITEBOARD/TACKBOARD.      |               |                                                                            |                                                      |                        | Sample #:                             |                                            |                     |
| 125<br>CAD #:                                   | X0C           | Miscellaneous Material<br>Wood Frame Chalkboard Adhesive (1921)            | ROOM 2113                                            | 20 Sq Ft               | N                                     | ASSUMED                                    | 5                   |
| Comments: BEHIND NEW WHITEBOARD/TACKBOARD.      |               |                                                                            |                                                      |                        | Sample #:                             |                                            |                     |
| 126<br>CAD #:                                   | X0O           | Miscellaneous Material<br>Wood Frame Corkboard Adhesive (1921)             | 1921 ORIGINAL BUILDING 2ND FLOOR HALLWAY             | 45 Sq Ft               | N                                     | ASSUMED                                    | 5                   |
| Comments: THREE (3) BOARDS.                     |               |                                                                            |                                                      |                        | Sample #:                             |                                            |                     |
| 135<br>CAD #:                                   | X0C           | Miscellaneous Material<br>Wood Frame Chalkboard Adhesive (1921)            | ROOM 2123                                            | 15 Sq Ft               | N                                     | ASSUMED                                    | 5                   |
| Comments: ESTIMATED BEHIND WHITEBOARD.          |               |                                                                            |                                                      |                        | Sample #:                             |                                            |                     |
| 139<br>CAD #:                                   | K2B           | 12" x 12" Vinyl Floor Tile & Mastic<br>Off-White w/Black Streaks           | 1924 ADDITION 2ND FLOOR HALLWAY                      | 430 Sq Ft              | N                                     | <1 CH (TILE),<br>10 CH (MASTIC)            | 5                   |
| Comments:                                       |               |                                                                            |                                                      |                        | Sample #: 012109ML-36                 |                                            |                     |
| 141<br>CAD #:                                   | X0H           | Miscellaneous Material<br>Wood Frame Chalkboard Adhesive (1924)            | ROOM 2137                                            | 20 Sq Ft               | N                                     | ASSUMED                                    | 5                   |
| Comments:                                       |               |                                                                            |                                                      |                        | Sample #:                             |                                            |                     |
| 142<br>CAD #:                                   | X0H           | Miscellaneous Material<br>Wood Frame Chalkboard Adhesive (1924)            | ROOM 2138                                            | 20 Sq Ft               | N                                     | ASSUMED                                    | 5                   |
| Comments: BEHIND NEW WHITEBOARDS & TACKBOARDS.  |               |                                                                            |                                                      |                        | Sample #:                             |                                            |                     |
| 144<br>CAD #:                                   | X0H           | Miscellaneous Material<br>Wood Frame Chalkboard Adhesive (1924)            | ROOM 2139                                            | 20 Sq Ft               | N                                     | ASSUMED                                    | 5                   |
| Comments: BEHIND NEW WHITEBOARDS & TACKBOARDS.  |               |                                                                            |                                                      |                        | Sample #:                             |                                            |                     |

| IEA Event No.                                                                          | Material Type | Material Description/Id                                          | Location                                 | Estimated Amount Total | Friability | % of Asbestos                   | EPA Assess Category |
|----------------------------------------------------------------------------------------|---------------|------------------------------------------------------------------|------------------------------------------|------------------------|------------|---------------------------------|---------------------|
| 145<br>CAD #:                                                                          | X0H           | Miscellaneous Material<br>Wood Frame Chalkboard Adhesive (1924)  | ROOM 2142                                | 20 Sq Ft               | N          | ASSUMED                         | 5                   |
| Comments: BEHIND NEW WHITEBOARDS & TACKBOARDS.                                         |               |                                                                  |                                          |                        | Sample #:  |                                 |                     |
| 147<br>CAD #:                                                                          | K2B           | 12" x 12" Vinyl Floor Tile & Mastic<br>Off-White w/Black Streaks | 1924 ADDITION 3RD FLOOR HALLWAY          | 400 Sq Ft              | N          | <1 CH (TILE),<br>10 CH (MASTIC) | 5                   |
| Comments: CRACKED TILES ALONG THRESHOLD AND THROUGHOUT AREA. SEALED WITH WAX. MONITOR. |               |                                                                  |                                          |                        | Sample #:  | 2001-1501-AG10                  |                     |
| 148<br>CAD #:                                                                          | K2R           | 12" x 12" Vinyl Floor Tile & Mastic<br>Light Gray w/Gray Smudges | 1924 ADDITION 3RD FLOOR HALLWAY          | 40 Sq Ft               | N          | 5 CH (MASTIC ONLY)              | 5                   |
| Comments: REPLACEMENT TILES.                                                           |               |                                                                  |                                          |                        | Sample #:  | 476-05                          |                     |
| 150<br>CAD #:                                                                          | X0H           | Miscellaneous Material<br>Wood Frame Chalkboard Adhesive (1924)  | ROOM 3142                                | 20 Sq Ft               | N          | ASSUMED                         | 5                   |
| Comments: BEHIND NEW WHITEBOARDS & TACKBOARDS.                                         |               |                                                                  |                                          |                        | Sample #:  |                                 |                     |
| 153<br>CAD #:                                                                          | X0H           | Miscellaneous Material<br>Wood Frame Chalkboard Adhesive (1924)  | ROOM 3139                                | 20 Sq Ft               | N          | ASSUMED                         | 5                   |
| Comments: BEHIND NEW WHITEBOARDS & TACKBOARDS.                                         |               |                                                                  |                                          |                        | Sample #:  |                                 |                     |
| 154<br>CAD #:                                                                          | X0H           | Miscellaneous Material<br>Wood Frame Chalkboard Adhesive (1924)  | ROOM 3138                                | 20 Sq Ft               | N          | ASSUMED                         | 5                   |
| Comments: BEHIND NEW WHITEBOARDS & TACKBOARDS.                                         |               |                                                                  |                                          |                        | Sample #:  |                                 |                     |
| 155<br>CAD #:                                                                          | X0H           | Miscellaneous Material<br>Wood Frame Chalkboard Adhesive (1924)  | ROOM 3137                                | 20 Sq Ft               | N          | ASSUMED                         | 5                   |
| Comments: BEHIND NEW WHITEBOARDS & TACKBOARDS.                                         |               |                                                                  |                                          |                        | Sample #:  |                                 |                     |
| 159<br>CAD #:                                                                          | X0C           | Miscellaneous Material<br>Wood Frame Chalkboard Adhesive (1921)  | 1921 ORIGINAL BUILDING 3RD FLOOR HALLWAY | 30 Sq Ft               | N          | ASSUMED                         | 5                   |
| Comments: TWO (2) BOARDS.                                                              |               |                                                                  |                                          |                        | Sample #:  |                                 |                     |
| 160<br>CAD #:                                                                          | X0C           | Miscellaneous Material<br>Wood Frame Chalkboard Adhesive (1921)  | ROOM 3124                                | 20 Sq Ft               | N          | ASSUMED                         | 5                   |
| Comments: BEHIND NEW WHITEBOARDS & TACKBOARDS.                                         |               |                                                                  |                                          |                        | Sample #:  |                                 |                     |
| 161<br>CAD #:                                                                          | X0C           | Miscellaneous Material<br>Wood Frame Chalkboard Adhesive (1921)  | ROOM 3123                                | 20 Sq Ft               | N          | ASSUMED                         | 5                   |
| Comments: BEHIND NEW WHITEBOARDS & TACKBOARDS.                                         |               |                                                                  |                                          |                        | Sample #:  |                                 |                     |
| 165<br>CAD #:                                                                          | X0C           | Miscellaneous Material<br>Wood Frame Chalkboard Adhesive (1921)  | ROOM 3114                                | 20 Sq Ft               | N          | ASSUMED                         | 5                   |
| Comments: BEHIND NEW WHITEBOARDS & TACKBOARDS.                                         |               |                                                                  |                                          |                        | Sample #:  |                                 |                     |
| 166<br>CAD #:                                                                          | X0C           | Miscellaneous Material<br>Wood Frame Chalkboard Adhesive (1921)  | ROOM 3113                                | 20 Sq Ft               | N          | ASSUMED                         | 5                   |
| Comments: BEHIND NEW WHITEBOARDS.                                                      |               |                                                                  |                                          |                        | Sample #:  |                                 |                     |
| 168<br>CAD #:                                                                          | X0G           | Miscellaneous Material<br>Wood Frame Chalkboard Adhesive (1931)  | ROOM 3109                                | 10 Sq Ft               | N          | ASSUMED                         | 5                   |
| Comments: BEHIND NEW WHITEBOARDS & TACKBOARDS.                                         |               |                                                                  |                                          |                        | Sample #:  |                                 |                     |
| 173<br>CAD #:                                                                          | X0G           | Miscellaneous Material<br>Wood Frame Chalkboard Adhesive (1931)  | ROOM 3103                                | 20 Sq Ft               | N          | ASSUMED                         | 5                   |
| Comments: BEHIND NEW WHITEBOARDS.                                                      |               |                                                                  |                                          |                        | Sample #:  |                                 |                     |