

Chart B - Assessment of Asbestos-Containing Building Materials (ACBM)

All asbestos-containing events listed here are to be inspected during each six-month periodic surveillance for changes in condition. The Institute for Environmental assessment (IEA) highly recommends an in-depth "front end" inspection prior to any general renovation or remodeling to determine if those activities may disrupt building materials that may involve existing or undiscovered asbestos. Potentially inaccessible or exempt asbestos-containing materials not included in this plan may include: adhesives, caulking, putty, woven blankets, curtains, gloves and gaskets, electrical wiring insulation and heat shields above lights, paints and coatings, roofing felts, flashings and shingles, and mineral core fire doors.

Damaged materials which require corrective action to reduce a potential hazard are indicated on Chart A. All non-damaged ACBM identified in Chart B should be monitored through scheduled inspections and removed prior to renovation or demolition activities, or when their condition deteriorates.

District administration will direct another formal inspection by a federally-certified inspector within three (3) years, and will maintain an on-going file for each building. Specific recommendations on how to manage the different types of Asbestos-containing material are identified in the Asbestos Management Plan.

PLEASE NOTE: Based on EPA recommendations, materials analyzed utilizing PLM and found to contain between 0% and 10% should be assumed asbestos containing unless building owner wishes the laboratory to utilize "point counting." For samples analyzed prior to 1994 containing 1% or less (trace) of asbestos, resampling utilizing the 1993 EPA Test Method or point counting is strongly recommended for purposes of demolition or renovation before treating these materials as non-asbestos containing. Contact your local IEA office for questions or additional information.

EPA ASSESSMENT CATEGORIES:		1 = Damaged or significantly damaged TSI ACM 2 = Damaged friable surfacing ACM 3 = Significantly damaged friable surfacing ACM 4 = Damaged or significantly damaged friable miscellaneous ACM		5 = ACBM with potential for damage 6 = ACBM with potential for significant damage 7 = Remaining friable ACBM or friable suspect ACBM			
IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assessment Category
8 CAD #:	D2A	Interior Boiler Insulation Burner Refractory (1963)	BOILER ROOM	90 Sq Ft	N	ASSUMED	5
Comments: THREE (3) BOILERS.					Sample #:		
14 CAD #:	J2A	Transite Piping/Ducting 6" Electrical Conduit	BASEMENT HIGH VOLTAGE ELECTRICAL ROOM (SMALL ROOM) OFF OUTSIDE AREA	10 Sq Ft	N	30 CH	5
Comments:					Sample #: 324-PDT-A (NOVA)		
15 CAD #:	J3A	Miscellaneous Cementitious Material Black Panels	BASEMENT HIGH VOLTAGE ELECTRICAL ROOM (SMALL ROOM) OFF OUTSIDE AREA	36 Sq Ft	N	ASSUMED	5
Comments: THREE (3) PANELS.					Sample #:		
18 CAD #:	L0A	Flexible Duct Connector Green Canvas	1963 ORIGINAL BUILDING PENTHOUSE MECHANICAL ROOM	4 Sq Ft	N	ASSUMED	5
Comments: TWO (2) JOINTS.					Sample #:		
22 CAD #:	J1D	Cementitious Panels Exterior Kiln Walls	KILN ROOM 1220 OFF RECEIVING	80 Sq Ft	N	ASSUMED	5
Comments: TWO (2) KILNS.					Sample #:		
23 CAD #:	X0N	Miscellaneous Material Interior Kiln Insulation	KILN ROOM 1220 OFF RECEIVING	80 Sq Ft	Y	45 CH	5
Comments: TWO (2) KILNS. INTERIOR INSULATION EXPOSED DUE TO BROKEN EXTERIOR KILN PANEL ON RIGHT SIDE.					Sample #: 082615JP-01		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
38 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	AUDITORIUM	3 Joints	N	20 CH, 10 AM	5
Comments: VISIBLE FROM CATWALK. ROOF DRAIN LINE.					Sample #:		
39 CAD #:	K0D	9" x 9" Vinyl Floor Tile & Mastic Gray Marble w/Black Flecks	AUDITORIUM	2700 Sq Ft	N	7 CH (TILE & MASTIC)	5
Comments: AISLE AREAS. SMALL PIECES MISSING IN AISLE THAT RUNS EAST/WEST, BY METAL RAILING LEGS. TILES CHIPPED W/PIECES MISSING NEXT TO SEATS C1 M15/16, N16 F1, M1, Z15, M31, N29, M33, M45, B1, T1, B12, Q13-15, Q33, Q35. RECOMMEND SEALING WITH WAX. MASTIC EXPOSED AND WEARING.					Sample #: 215-12		
40 CAD #:	S0A	Wood Floor Felt / Vapor Barrier Elevated (1963)	AUDITORIUM STAGE (1231)	3500 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
41 CAD #:	K3G	Miscellaneous Flooring Gray Stair Treads w/Raised Circles	AUDITORIUM STAGE (1231)	100 Sq Ft	N	ASSUMED	5
Comments: STAIRS AND RAMP IN NORTHEAST CORNER.					Sample #:		
42 CAD #:	X0B	Miscellaneous Material White Proscenium Curtain	AUDITORIUM STAGE (1231)	1200 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
43 CAD #:	T0A	Light Cord Insulation White, Fuzzy	AUDITORIUM STAGE (1231)	80 Lin Ft	N	ASSUMED	5
Comments: STORED UNDER SPIRAL STAIRCASE TO CATWALK.					Sample #:		
44 CAD #:	P0B	Fire Doors Wood Composite - 1 Hr Rating (Weldwood)	AUDITORIUM STAGE (1231)	20 Sq Ft	N	10 CH, 5 AM	5
Comments: ONE (1) DOOR TO CATWALK.					Sample #: 120109-JC-07		
48 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	GIRLS' STAGE DRESSING ROOM (1233)	110 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: TILES CHIPPING AT WEST ENTRANCE.					Sample #:		
52 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	GIRLS' STAGE DRESSING ROOM RESTROOM (1233A)	21 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
55 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	BOYS' STAGE DRESSING ROOM AREA (1232)	110 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: TILE CHIPPING AT WEST ENTRANCE.					Sample #:		
59 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	BOYS' STAGE DRESSING ROOM RESTROOM (1232A)	21 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
63 CAD #:	S0A	Wood Floor Felt / Vapor Barrier Elevated (1963)	ROOM 1215 (THEATRE ARTS)	300 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
66 CAD #:	S0A	Wood Floor Felt / Vapor Barrier Elevated (1963)	ROOMS 1215A & B	260 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
79 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	RESTROOMS 1201 & 1202	600 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
83 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1244	5 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
86 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1242	5 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
88 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1245	5 Sq Ft	N	ASSUMED	5
Comments: BEHIND WHITEBOARD.					Sample #:		
92 CAD #:	J2A	Transite Piping/Ducting 6" Electrical Conduit	HIGH VOLTAGE ELECTRICAL ROOM 1250A	10 Sq Ft	N	30 CH	5
Comments:					Sample #:		
94 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1240 (WOOD SHOP)	5 Sq Ft	N	ASSUMED	5
Comments: ESTIMATED BEHIND WHITEBOARD.					Sample #:		
99 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1301	900 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: TILE WEAR AT TEACHERS DESK. ONE MISSING TILE AND ONE CHIPPED TILE BY FIRE EXTINGUISHER. SEALED WITH WAX. FIVE TILES MISSING IN CENTER OF ROOM. MORE TILES COMING LOOSE					Sample #:		
100 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1301	5 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
102 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1303	80 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: CHIPPED TILE NEAR DESK.					Sample #:		
103 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1302	1400 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: TILE WEAR AT ENTRANCE. SEALED WITH WAX. MONITOR.					Sample #: 120309-MV-28		
105 CAD #:	J3D	Miscellaneous Cementitious Material 1-1/4" Gray Countertop	ROOM 1302	25 Sq Ft	N	10 CH	5
Comments: COVERED WITH WOOD SHEETING.					Sample #: 120309-MV-25		
106 CAD #:	J3I	Miscellaneous Cementitious Material Gray 1/4" Pottery Trays	ROOM 1302	50 Sq Ft	N	ASSUMED	5
Comments: FIFTY (50) CIRCULAR & SQUARE-SHAPED TRAYS STORED ON NORTHEAST SHELF.					Sample #:		
107 CAD #:	V0B	Sink Undercoating Black	ROOM 1302	20 Sq Ft	N	10 CH	5
Comments: THREE (3) SINKS.					Sample #: 120309-MV-43		
111 CAD #:	X00	Miscellaneous Material Milkboard Adhesive	ROOM 1302 STORAGE/WORK ROOM	72 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
114 CAD #:	X0I	Miscellaneous Material Black Wall Panel Adhesive	ROOM 1304	10 Sq Ft	N	3 CH	5
Comments: INCLUDES SOME EXPOSED MATERIAL BEHIND SHELF ON WEST WALL.					Sample #: 120309-MV-12		
116 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1305	784 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: WORN AT TEACHER'S DESK, RECOMMEND CHAIR MAT. SEALED WITH WAX.					Sample #: 120309-MV-29		
118 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1305	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
120 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1306	1300 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: TILE CHIPPED AT ENTRANCE AND BY COURTYARD EXIT. SEALED WITH WAX.					Sample #:		
124 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1307	784 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: INCLUDES FIFTEEN (15) GREEN REPLACEMENT TILES. SEALED WITH WAX.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
126 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1307	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
129 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1308	1000 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: CHIPPED TILES. SEALED WITH WAX.					Sample #:		
134 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1308	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
137 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1308A (STORAGE)	130 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: TILE IS WEARING. RECOMMEND SEALING WITH WAX.					Sample #:		
140 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1308B (OFFICE)	130 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: CHIPPED TILES AND WORN TILES. RECOMMEND SEALING WITH WAX AND INSTALLING A CHAIR MAT.					Sample #:		
143 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1309	280 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
145 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1310	1000 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: TILE MISSING EAST END BY SINK. CHIPPED TILE NORTHWEST SIDE. SEALED WITH WAX.					Sample #:		
146 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1310	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
153 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1310A (STORAGE)	130 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
156 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1311	784 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: UNDER CARPET.					Sample #:		
157 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1311	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
160 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1313	1120 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: TILE WORN UNDER CHAIRS. SEALED WITH WAX.					Sample #:		
162 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1313	6 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
164 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1312	1000 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: TILE CHIPPED AROUND ROUND METAL FLOOR COVERS AND ON EAST SIDE. SEALED WITH WAX.					Sample #:		
167 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1312	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
173 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1312A (STORAGE)	130 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: RECOMMEND SEALING WITH WAX.					Sample #:		
176 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1314 (OFFICE)	70 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: TILE WORN UNDER TEACHER'S CHAIR, RECOMMEND CHAIR MAT. SEALED WITH WAX.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
180 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1315	784 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: CHIPPED TILES. SEALED WITH WAX.					Sample #:		
182 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1315	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
184 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1317	784 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: CRACKING AT ENTRANCE. SEALED WITH WAX.					Sample #:		
186 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1317	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
189 CAD #:	J2A	Transite Piping/Ducting 6" Electrical Conduit	HIGH VOLTAGE ELECTRICAL ROOM 1321	10 Sq Ft	N	30 CH	5
Comments: USE CAUTION IN AREA. ELECTRICAL HAZARDS.					Sample #:		
191 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	RESTROOMS 1318 & 1322	900 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
195 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1316	1000 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: INCLUDES TWO (2) ROWS OF 12" TILES AT WEST WALL. SCRATCHED TILE. SEALED WITH WAX.					Sample #:		
198 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1316	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
200 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1316A (OFFICE)	130 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
204 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1325	1300 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: THREE (3) TILES BROKEN IN NORTHWEST OF ROOM AND ONE (1) IN THE CENTER OF ROOM. SEALED WITH WAX.					Sample #:		
205 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1325	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
206 CAD #:	J1A	Cementitious Panels Loose Panels	ROOM 1325	40 Sq Ft	N	30 CH	5
Comments: APPROXIMATELY TWENTY (20) PANELS. STORED IN LAB TABLES.					Sample #: 324-PTP-A		
210 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1327 (OFFICE)	150 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: WORN TILE. RECOMMEND SEALING WITH WAX AND INSTALLING A CHAIRMAT.					Sample #:		
212 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1327 (OFFICE) STORAGE 1327A	150 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
215 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1325A (STORAGE)	130 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
218 CAD #:	U0A	Light Pad Insulation Light Fixtures	ROOM 1326	96 Sq Ft	Y	75 CH	5
Comments: TWELVE (12) 2' X 4' FIXTURES. ONE (1) FIXTURE MISSING COVER.					Sample #:		
220 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1328	1300 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: MISSING TILE UNDER LAB TABLE LEG.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
223 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1328	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
228 CAD #:	U0A	Light Pad Insulation Light Fixtures	ROOM 1340 (IMC)	96 Sq Ft	Y	75 CH	5
Comments: TWELVE (12) 2' X 4' FIXTURES.					Sample #:		
231 CAD #:	U0A	Light Pad Insulation Light Fixtures	ROOM 1340A	8 Sq Ft	Y	75 CH	5
Comments: TWO (2) 1' X 4' LIGHT FIXTURES.					Sample #:		
232 CAD #:	U0A	Light Pad Insulation Light Fixtures	ROOM 1343	16 Sq Ft	Y	75 CH	5
Comments: FOUR (4) 1' X 4' LIGHT FIXTURES.					Sample #:		
233 CAD #:	U0A	Light Pad Insulation Light Fixtures	ROOM 1344	16 Sq Ft	N	75 CH	5
Comments: FOUR (4) 1' X 4' LIGHT FIXTURES.					Sample #:		
234 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1344	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
236 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1329	1300 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
241 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1329	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
243 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1331	150 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
247 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1333	1300 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: MISSING TILE AT NORTH END OF ROOM.					Sample #:		
252 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1333	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
253 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1346	95 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: TILE MISSING AT ENTRANCE TO ROOM 1346A.					Sample #:		
254 CAD #:	P0E	Fire Doors Wood - 1 Hr Rating (Bayer)	ROOM 1346	20 Sq Ft	N	ASSUMED	5
Comments: ONE (1) DOOR.					Sample #:		
256 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1334	1300 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
261 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1334	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
263 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1335	120 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
264 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1335A	120 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
265 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1334A	100 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments:					Sample #:		
267 CAD #:	J2A	Transite Piping/Ducting 6" Electrical Conduit	HIGH VOLTAGE ELECTRICAL ROOM 1353	10 Sq Ft	N	30 CH	5
Comments: USE CAUTION IN AREA. ELECTRICAL HAZARDS.					Sample #:		
277 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	ROOM 1356A STORAGE	48 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
278 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	RESTROOMS 1357A & 1357C	800 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
283 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1358	6 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
290 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1359	6 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: SOUTHEAST CORNER. SMALL PIECE MISSING. SEALED WITH WAX.					Sample #:		
296 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1361	350 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: UNDER CARPET.					Sample #:		
300 CAD #:	X1B	Miscellaneous Material 2" X 2" Beige Ceramic Floor Tile System	RESTROOM 1361A	64 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
304 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1363	620 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: UNDER CARPET.					Sample #:		
307 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	ROOM 1364	825 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: UNDER CARPET.					Sample #:		
310 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1380 (HEALTH SERVICES)	100 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: REMAINS UNDER WALLS.					Sample #:		
318 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1366	900 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: UNDER CARPET.					Sample #:		
338 CAD #:	X1G	Miscellaneous Material 2" X 2" Gray Ceramic Floor Tile System	RESTROOM NEAR ROOM 1133	64 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
360 CAD #:	K3J	Miscellaneous Flooring 18" X 18" Tan w/Raised Circles	COMMONS/LINK (TA38) TO CAFETERIA	300 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
363 CAD #:	R0H	Baseboard/Mopboard Adhesive 4" Black Baseboard (1995)	CAFETERIA ENTRY & STORE 1101A	50 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
369 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	CAFETERIA 1101 - SOUTH END	1 Joints	N	20 CH, 10 AM	5
Comments: ROOF DRAIN ABOVE CEILING.					Sample #:		
371 CAD #:	X1C	Miscellaneous Material 6" Red Quarry Tile System	CAFETERIA DISHWASHING ROOM (ROOM 1101C)	240 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
376 CAD #:	X1C	Miscellaneous Material 6" Red Quarry Tile System	KITCHEN 1102	1200 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
378 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	KITCHEN OFFICE 1103	250 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: CHIIPPED TILE AT NORTH ENTRANCE. BULGING TILE AT SOUTH ENTRANCE. MONITOR.					Sample #:		
385 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	HALLWAY TO KITCHEN LOADING DOCK 1104	160 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: TILES CHIPPED AT HALLWAY ENTRANCES.					Sample #: 215-2		
388 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	KITCHEN LOCKER/BREAK ROOM 1105	2 Joints	N	20 CH, 10 AM	5
Comments: ABOVE CEILING. ROOF DRAIN. VISIBLE FROM CEILING HATCH.					Sample #:		
393 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	RESTROOM OFF OF KITCHEN LOCKER ROOM	32 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
397 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	ROOM 1107	265 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
399 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Light Gray w/Light Swirls	GYMNASIUM STORAGE 1108	1 Sq Ft	N	4-5 CH (TILE ONLY)	5
Comments: FOUR (4) PARTIAL TILES REMAINING ONLY AT ENTRANCE. MASTIC THROUGHOUT. RECOMMEND REMOVAL.					Sample #:		
401 CAD #:	J2A	Transite Piping/Ducting 6" Electrical Conduit	ELECTRICAL ROOM 1108A	10 Sq Ft	N	30 CH	5
Comments:					Sample #:		
410 CAD #:	L0A	Flexible Duct Connector Green Canvas	GYMNASIUM/POOL PENTHOUSE 1199C	20 Sq Ft	N	ASSUMED	5
Comments: FIVE (5) JOINTS.					Sample #:		
415 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	GIRLS' POOL LOCKER ROOM 1113 SHOWER AREAS	700 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
416 CAD #:	X1F	Miscellaneous Material 1" X 1" Beige Ceramic Tile System	GIRLS' POOL LOCKER ROOM 1113 SHOWER AREAS	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
417 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	GIRLS' POOL LOCKER ROOM 1113 RESTROOM AREAS	500 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
421 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	GIRLS' POOL LOCKER ROOM COACHES' OFFICE RESTROOM 1114B	48 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
422 CAD #:	G2A	Trowelled-On Acoustical Finish White	POOL AREA 1115	1000 Sq Ft	Y	ASSUMED	5
Comments: FOUR (4), 4' WIDE SECTIONS & TWO (2) STRIPS AT WALLS. NEED LIFT OR EXTENSION LADDER TO SAMPLE.					Sample #:		
423 CAD #:	X1D	Miscellaneous Material 1" Blue Ceramic Tile System (Pool)	POOL AREA 1115	4000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
426 CAD #:	X1E	Miscellaneous Material 1" X 1" Yellow Ceramic Floor Tile System	GIRLS' VARSITY LOCKER ROOM 0112 SHOWERS	400 Sq Ft	N	ASSUMED	5
Comments: INCLUDES RESTROOM AREA.					Sample #:		
427 CAD #:	X1E	Miscellaneous Material 1" X 1" Yellow Ceramic Floor Tile System	GIRLS' VARSITY LOCKER ROOM 0112 COACHES' SHOWERS	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
438 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	BOYS' POOL LOCKER ROOM 1116	800 Sq Ft	N	ASSUMED	5
Comments: RESTROOM & SHOWER AREAS.					Sample #:		
439 CAD #:	X1F	Miscellaneous Material 1" X 1" Beige Ceramic Tile System	BOYS' POOL LOCKER ROOM 1116	100 Sq Ft	N	ASSUMED	5
Comments: SHOWER AREA.					Sample #:		
443 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	BOYS' POOL LOCKER ROOM COACHES' OFFICE RESTROOM 1117B	48 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
446 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	BOYS' VARSITY LOCKER ROOM 1118 SHOWERS	500 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
447 CAD #:	X1F	Miscellaneous Material 1" X 1" Beige Ceramic Tile System	BOYS' VARSITY LOCKER ROOM 1118 SHOWERS	50 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
451 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	BOYS' VARSITY LOCKER ROOM COACHES' OFFICE RESTROOM 1119B	48 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
452 CAD #:	X1F	Miscellaneous Material 1" X 1" Beige Ceramic Tile System	BOYS' VARSITY LOCKER ROOM COACHES' OFFICE RESTROOM 1119B	3 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
453 CAD #:	L0A	Flexible Duct Connector Green Canvas	BOYS' VARSITY LOCKER ROOM STORAGE 1118D	6 Sq Ft	N	ASSUMED	5
Comments: TWO (2) JOINTS.					Sample #:		
462 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	ROOM 1122 OFF HALLWAY BY WRESTLING ROOM	200 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
463 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	UNEXCAVATED AREA UNDER 1963 ORIGINAL BUILDING GYMNASIUM	1 Joints	N	20 CH, 10 AM	5
Comments: MATERIAL ENCAPSULATED IN PIPE PENETRATION IN SOUTHEAST CORNER OF CRAWL SPACE. ACCESS OFF HALLWAY THROUGH DOOR NEXT TO "BALCONY" DOOR.					Sample #:		
466 CAD #:	X1G	Miscellaneous Material 2" X 2" Gray Ceramic Floor Tile System	RESTROOMS 1125A & 1125C	572 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
467 CAD #:	X1H	Miscellaneous Material 4" X 4" White w/Gray Flecks Ceramic Wall Tile System	RESTROOMS 1125A & 1125C	224 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
475 CAD #:	K3G	Miscellaneous Flooring Gray Stair Treads w/Raised Circles	1995 ADDITION MAIN HALLWAY	600 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
483 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1402	6 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
487 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1404	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
488 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	ROOM 1403	2 Joints	N	20 CH, 10 AM	5
Comments: INACCESSIBLE IN WALL UNDER SINK.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
499 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1407	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
502 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1406	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
507 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1410	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
511 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1409	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
515 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1411	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
519 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1412	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
524 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	BOYS' RESTROOM BY ROOM 1413	200 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
527 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	GIRLS' RESTROOM BY ROOM 1415	200 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
531 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1415	4 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: <u>VISIBLE UNDER WOOD CABINET.</u>					Sample #:		
535 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1416	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
542 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1420	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: <u>UNDER CARPET.</u>					Sample #:		
546 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1423	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
551 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1425	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
554 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1424	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: <u>UNDER CARPET.</u>					Sample #:		
557 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1427	6 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
563 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	FAN ROOM BELOW ROOM 1430	40 Joints	N	20 CH, 10 AM	5
Comments: <u>ACCESS THROUGH FLOOR HATCH. UNDER FIBERGLASS & PVC. AMOUNT ESTIMATED.</u>					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
568 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1433	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: SLIGHT CRACKING ALONG SOUTH WALL.					Sample #: 2001-1501-AE-2;; 2001-1901-XX-40B		
569 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1433	6 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
574 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1435	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: CHIPPED PIECE BY TEACHER'S DESK. WORN AT TEACHER'S DESK, RECOMMEND CHAIR MAT. SEALED WITH WAX.					Sample #:		
575 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1435	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
580 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1437	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: SLIGHT CRACKING ALONG SOUTH WALL. CHIPPED TILE SIX (6) FEET FROM ENTRY. MISSING TILE ON EAST WALL. SEALED WITH WAX.					Sample #:		
581 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1437	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
584 CAD #:	R0H	Baseboard/Mopboard Adhesive 4" Black Baseboard (1995)	COPY ROOM 1439	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
593 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1419	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
597 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1440	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
610 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1445	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: ONE (1) MISSING TILE AT ENTRANCE. BROKEN TILE AT CENTER OF ROOM. OTHER TILES COMING LOOSE THROUGHOUT. INCLUDES TWENTY-FIVE (25) MAROON TILES.					Sample #:		
611 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1445	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
614 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1446	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: CHIPPED AT ENTRANCE. SEALED WITH WAX.					Sample #:		
615 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1446	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
617 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	GIRLS' RESTROOM BY ROOM 1446	200 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
621 CAD #:	X1A	Miscellaneous Material 2" X 2" Tan/Gray/White Ceramic Floor Tile System	BOYS' RESTROOM BY ROOM 1448	200 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
624 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1448	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: INCLUDES REPLACEMENT TILES.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
625 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1448	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
629 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1450	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: CHIPPED TILES. SEALED WITH WAX.					Sample #:		
630 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1450	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
633 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1451	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: CHIPPED PIECES OF TILE AND CRACKING ALONG NORTH WALL. SIX (6) VARIOUS REPLACEMENT TILES.					Sample #:		
634 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1451	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
637 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1453	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: CHIPPED AT ENTRANCE. SEALED WITH WAX.					Sample #:		
638 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1453	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
639 CAD #:	A4A	Mudded Pipe Joints on Fiberglass Insulation 1963 Original Building	ROOM 1452	2 Joints	N	20 CH, 10 AM	5
Comments: INACCESSIBLE IN WALL. UNDER SINK. MAY HAVE BEEN REMOVED, BUT UNABLE TO VERIFY.					Sample #: 2001-01125-4		
642 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1452	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: UNDER CARPET.					Sample #:		
646 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1454	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: SMALL CHIP AT ENTRANCE. SEALED WITH WAX.					Sample #:		
647 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1454	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
650 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1455	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: CRACKING ALONG NORTH AND SOUTH WALL. INCLUDES REPLACEMENT TILES.					Sample #:		
651 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1455	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
654 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1456	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: CHIPPED PIECE MIDDLE OF ROOM TOWARDS WHITEBOARDS AND AT ENTRANCE. TEN (10) GREEN REPLACEMENT TILES.					Sample #:		
655 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1456	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
658 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1457	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: SLIGHT CRACKING ALONG WALL NEXT TO ENTRANCE. THREE (3) WHITE REPLACEMENT TILES.					Sample #:		
659 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1457	14 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
664 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Gray w/White & Black Streaks	ROOM 1459	800 Sq Ft	N	8 CH (TILE ONLY)	5
Comments: SMALL CHIP AT ENTRANCE AND 8 FT IN FRONT OF ENTRANCE. WEARING UNDER TEACHERS DESK. RECOMMEND SEALING WITH WAX AND INSTALLING A CHAIR MAT.					Sample #:		
665 CAD #:	X0H	Miscellaneous Material Black Chalkboard Adhesive	ROOM 1459	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		