

30 East Baker Street, Saint Paul, MN 55107

Chart C - All Materials List

The following list contains all events observed by the inspector, whether or not they actually contained asbestos, and are grouped by homogeneous area (material type).

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
A2A	Mudded Pipe Joints on Millboard Insulation 1924 Original Building					Total Amount - 4 Joints
	57	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) GYMNASIUM 1301	ASSUMED			4 Joints
A4A	Mudded Pipe Joints on Fiberglass Insulation Unknown Installation Date					Total Amount - 2 Joints
	24	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) HALLWAY 1640 OUTSIDE BOILER ROOM	NONE DETECTED	08142012MA-01		2 Joints
A4C	Mudded Pipe Joints on Fiberglass Insulation 1959 Addition					Total Amount - 28 Joints
	124	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) HALLWAY OUTSIDE CAFETERIA	NONE DETECTED	2001-01378-24B, 25B, 26B	24B,25B,26B: JUNIOR HIGH ROOM 1721 BACK STORAGE (SINCE REMOVED).	4 Joints
	186	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2105	NONE DETECTED	041614MV-03, 04; 101408-MA-11, 12; 1378-27B, 28B	11: ROOF DRAIN. 12: HEATING LINE.	24 Joints
A4D	Mudded Pipe Joints on Fiberglass Insulation 1975 Addition					Total Amount - 1924 Joints
	230	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2300J (MEN'S LOCKER ROOM)	NONE DETECTED			13 Joints
	232	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2300G (GYMNASIUM)	NONE DETECTED			11 Joints

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	235	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) GYMNASIUM STORAGE ROOM 3146	NONE DETECTED	030718CN-01, 02, 03, 04	CN-01,02,03: ROOM 1504. CN-04: HALLWAY BY ROOM 1301 (SINCE REMOVED).	55 Joints
	236	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2300K (WOMEN'S LOCKER ROOM)	NONE DETECTED			16 Joints
	241	THROUGHOUT SENIOR HIGH SCHOOL	NONE DETECTED	032023BF-1; 062017ML-01, 02, 03; 2001-1378-22B, 23B	BF-1: ROOM 1403 (ROOF DRAIN). ML-01: HALLWAY NEAR ROOM 1248. ML-02: HALLWAY NEAR LOCKER 2087. ML-03: ROOM 1244 RESTROOM. 22B,23B: 1ST FLOOR HALLWAY.	1280 Joints
	256	SENIOR HIGH ROOM 3138 (BOILER ROOM)	NONE DETECTED	510-B-17		32 Joints
	259	SENIOR HIGH ROOM 3143	NONE DETECTED			23 Joints
	261	SENIOR HIGH ROOM 3145	NONE DETECTED			23 Joints
	263	SENIOR HIGH ROOM 3144 (POOL MECH)	NONE DETECTED			22 Joints
	265	SENIOR HIGH ROOM 1101 (POOL) HALLWAY & FAN ROOM	NONE DETECTED	206 C9A		135 Joints
	272	SENIOR HIGH ROOM 1125 (STAGE)	NONE DETECTED			4 Joints
	275	SENIOR HIGH AUDITORIUM MECHANICAL ROOM	NONE DETECTED			100 Joints
	277	SENIOR HIGH ROOM 1124	NONE DETECTED			2 Joints
	281	SENIOR HIGH ROOM 1401 (MAIN GYMNASIUM)	NONE DETECTED			20 Joints
	284	SENIOR HIGH ROOM 1401A CUSTODIAL CLOSET	NONE DETECTED			2 Joints
	287	SENIOR HIGH ROOM 1402 (WRESTLING ROOM)	NONE DETECTED	206 C7A		22 Joints

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	288	SENIOR HIGH ROOM 3127 (WOMEN'S LOCKER ROOM)	NONE DETECTED			20 Joints
	290	SENIOR HIGH ROOM 3128	NONE DETECTED			14 Joints
	291	SENIOR HIGH ROOM 3129	NONE DETECTED			6 Joints
	292	SENIOR HIGH ROOM 3130	NONE DETECTED			4 Joints
	294	SENIOR HIGH ROOM 3123	NONE DETECTED			9 Joints
	295	SENIOR HIGH ROOM 3116	NONE DETECTED			6 Joints
	297	SENIOR HIGH ROOM 3119 (MEN'S LOCKER ROOM)	NONE DETECTED			26 Joints
	299	SENIOR HIGH ROOM 1407A	NONE DETECTED			13 Joints
	300	SENIOR HIGH ROOM 1407C	NONE DETECTED			13 Joints
	307	SENIOR HIGH 1800B CUSTODIAL CLOSET	NONE DETECTED			1 Joints
	309	SENIOR HIGH ROOM 1206	NONE DETECTED	062017ML-04	ML-04: SENIOR HIGH ROOM 1259 (SINCE REMOVED).	1 Joints
	318	SENIOR HIGH ROOM 1238	NONE DETECTED			46 Joints
	323	SENIOR HIGH ROOM 2215	NONE DETECTED			1 Joints
	331	SENIOR HIGH ROOM 3211	NONE DETECTED			4 Joints
B1A	Air Cell Pipe Insulation 1909 Original Building		Total Amount - 15 Lin Ft			
	46	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1304	ASSUMED			15 Lin Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
B2A	Millboard Pipe Insulation 1924 Original Building					Total Amount - 20 Lin Ft
	56	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) GYMNASIUM 1301	ASSUMED			20 Lin Ft
D1A	Boiler Gaskets Fiberglass					Total Amount - 10 Sq Ft
	257	SENIOR HIGH ROOM 3138 (BOILER ROOM)	NONE DETECTED	051613JD-02, 03, 05		10 Sq Ft
D2A	Interior Boiler Insulation Door Refractory					Total Amount - 70 Sq Ft
	258	SENIOR HIGH ROOM 3138 (BOILER ROOM)	NONE DETECTED	051613JD-01, 04		70 Sq Ft
G1C	Sprayed-On Acoustical Finish Fluffy, White (1975)					Total Amount - 15750 Sq Ft
	266	SENIOR HIGH ROOM 2300I (POOL)	NONE DETECTED	450-WWA-2, 3, 4, 5, 6, 7, 8		15750 Sq Ft
G1D	Sprayed-On Acoustical Finish White Texture					Total Amount - 9000 Sq Ft
	269	SENIOR HIGH ROOM 1120 (AUDITORIUM)	NONE DETECTED	009-011		1000 Sq Ft
	276	SENIOR HIGH AUDITORIUM CATWALK	NONE DETECTED	450-WW-A-9, 10, 11; 100-V-9A, 9B, 9C		1000 Sq Ft
	280	SENIOR HIGH ROOM 1401 (MAIN GYMNASIUM)	NONE DETECTED	ACB450WW-A13, A14, A15, A16, A17, A18; OWA-01J-01B		7000 Sq Ft
H1A	Sprayed-On Structural Fireproofing Gray					Total Amount - 14325 Sq Ft
	20	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) UNISEX RESTROOM BY ROOM 1215	NONE DETECTED			40 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	33	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) STAFF RESTROOM & ENTRY	NONE DETECTED	100-U5A-C	SEE ORIG.	30 Sq Ft
	68	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1207	NONE DETECTED			20 Sq Ft
	71	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1206	NONE DETECTED			30 Sq Ft
	79	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) MAIN OFFICE	NONE DETECTED			70 Sq Ft
	119	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) CAFETERIA 1101	NONE DETECTED	100V-5A-C	SEE ORIG.	550 Sq Ft
	127	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) MEZZANINE ROOM 1504	NONE DETECTED			300 Sq Ft
	135	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2209	NONE DETECTED			170 Sq Ft
	137	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2207	NONE DETECTED			5 Sq Ft
	182	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2210	NONE DETECTED	101-319	101-319: ROOM 3648.	20 Sq Ft
	185	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2105	NONE DETECTED	510-B-3, 4, 5, 6, 7		1000 Sq Ft
	239	THROUGHOUT SENIOR HIGH SCHOOL	NONE DETECTED	225-2, 3, 4, 5	2,3: ROOM 3202. 4,5: STAIRWELL 3299C.	10000 Sq Ft
	255	SENIOR HIGH ROOM 3138 (BOILER ROOM)	NONE DETECTED	100-V-8A, 8B, 8C		440 Sq Ft
	264	SENIOR HIGH ROOM 1101 (POOL) HALLWAY & FAN ROOM	NONE DETECTED	ACB450WW-A019	A019: POOL FAN ROOM.	1250 Sq Ft
	271	SENIOR HIGH ROOM 1125 (STAGE)	NONE DETECTED	510-B-13, 14; 225-6		400 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
I1A	1' x 1' Acoustical Ceiling Tile Large & Pin Holes in Random Pattern		Total Amount - 1320 Sq Ft			
	22	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) HALLWAY 1640 OUTSIDE BOILER ROOM	NONE DETECTED			200 Sq Ft
	77	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) HALLWAY/RAMP 1600	NONE DETECTED	225-12		440 Sq Ft
	90	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1604	NONE DETECTED	206-C6A		680 Sq Ft
I1B	1' x 1' Acoustical Ceiling Tile Pegboard		Total Amount - 555 Sq Ft			
	37	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) STAFF RESTROOM	NONE DETECTED			10 Sq Ft
	42	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1302 (ELEVATOR EQUIPMENT ROOM)	NONE DETECTED			180 Sq Ft
	214	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3201	NONE DETECTED	510-B-11P; 225-13	510-B-11P: JUNIOR HIGH ROOM 1615 (SINCE REMOVED). 225-13: ROOM 2639A.	365 Sq Ft
I2A	2' x 2' Acoustical Ceiling Tile Fissures w/Nail & Pin Holes		Total Amount - 12845 Sq Ft			
	28	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1221 & ENTRY	NONE DETECTED	510-B-12		850 Sq Ft
	31	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1221 STORAGE	NONE DETECTED			60 Sq Ft
	36	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) STAFF RESTROOM	NONE DETECTED			70 Sq Ft
	41	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) 1909 ORIGINAL BUILDING HALLWAY TO GYMNASIUM (1301)	NONE DETECTED	510-B-12		800 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	53	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1305A	NONE DETECTED			140 Sq Ft
	54	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1305B & HALLWAY 1305	NONE DETECTED			370 Sq Ft
	66	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1208	NONE DETECTED			120 Sq Ft
	69	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1207	NONE DETECTED			510 Sq Ft
	72	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1206	NONE DETECTED			170 Sq Ft
	74	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1204	NONE DETECTED			300 Sq Ft
	76	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1212	NONE DETECTED			625 Sq Ft
	80	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1601A	NONE DETECTED			180 Sq Ft
	81	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1601	NONE DETECTED			130 Sq Ft
	84	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1607	NONE DETECTED			120 Sq Ft
	85	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1605	NONE DETECTED			110 Sq Ft
	106	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) STORAGE ROOM 1401 OUTSIDE GYMNASIUM 1301	NONE DETECTED			130 Sq Ft
	145	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) 2ND FLOOR HALLWAY 2600	NONE DETECTED	101508-MA-10		650 Sq Ft
	152	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2601 (WOMEN'S RESTROOM)	NONE DETECTED			45 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	161	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) AUDITORIUM STAGE (2300) STORAGE 2407	NONE DETECTED			320 Sq Ft
	163	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) 2ND FLOOR HALLWAY BY STAIRS 2599C	NONE DETECTED			90 Sq Ft
	169	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) 2ND FLOOR HALLWAY 2603	NONE DETECTED			200 Sq Ft
	171	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2609	NONE DETECTED			900 Sq Ft
	174	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2609 OFFICE	NONE DETECTED			225 Sq Ft
	177	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2610	NONE DETECTED			900 Sq Ft
	183	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2202	NONE DETECTED			730 Sq Ft
	187	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2105	NONE DETECTED			2000 Sq Ft
	226	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3204	NONE DETECTED			900 Sq Ft
	227	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3206	NONE DETECTED			1200 Sq Ft
I2B	2' x 2' Acoustical Ceiling Tile Light Texture w/Revealed Edge (2014)					Total Amount - 15000 Sq Ft
	9	THROUGHOUT OPEN WORLD LEARNING (HUMBOLDT JUNIOR)	NONE DETECTED	062123BF-1, 2	BF-1,2: ROOM 1504.	15000 Sq Ft
I2C	2' x 2' Acoustical Ceiling Tile Gouges & Pin Holes					Total Amount - 30000 Sq Ft
	8	THROUGHOUT OPEN WORLD LEARNING (HUMBOLDT JUNIOR)	NONE DETECTED	082715BV-13		30000 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
I2D	2' x 2' Acoustical Ceiling Tile Concentric Gouges & Pin Holes		Total Amount - 3454 Sq Ft			
	189	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2108	NONE DETECTED	225-16	225-16: JUNIOR HIGH ROOM 1716A (SINCE REMOVED).	1064 Sq Ft
	191	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2110	NONE DETECTED			1000 Sq Ft
	195	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2114	NONE DETECTED			1150 Sq Ft
	197	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOMS 2116A,B & C	NONE DETECTED			240 Sq Ft
I2E	2' x 2' Acoustical Ceiling Tile Dense Fissures, Dents & Pin Holes		Total Amount - 500 Sq Ft			
	231	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2300L (LOCKER ROOM OFFICE)	NONE DETECTED	101708-MA-06; 225-14	MA-06: ROOM 1304 (SENIOR HIGH, SINCE REMOVED). 225-14: 3RD FLOOR SOUTHWEST HALLWAY (SENIOR HIGH, SINCE REMOVED).	500 Sq Ft
I2F	2' x 2' Acoustical Ceiling Tile Vinyl-Coated Gypsum		Total Amount - 2782 Sq Ft			
	245	SENIOR HIGH ROOM 1106	NSM			176 Sq Ft
	247	SENIOR HIGH ROOM 1107	NSM			176 Sq Ft
	249	SENIOR HIGH ROOM 1108	NSM			600 Sq Ft
	251	SENIOR HIGH ROOM 1109	NSM			520 Sq Ft
	253	SENIOR HIGH ROOM 1114	NSM			1000 Sq Ft
	254	SENIOR HIGH ROOM 1114B	NSM			310 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
I2H	2' x 2' Acoustical Ceiling Tile Light Texture w/Revealed Edge (2018)					Total Amount - 6000 Sq Ft
	312	THROUGHOUT GUIDANCE OFFICE/MAIN OFFICE	NEW			6000 Sq Ft
I2I	2' x 2' Acoustical Ceiling Tile Light Texture with Revealed Edge (2019)					Total Amount - 70925 Sq Ft
	242	THROUGHOUT SENIOR HIGH SCHOOL	NEW			50000 Sq Ft
	310	SENIOR HIGH ROOM 1206	NEW			425 Sq Ft
	311	SENIOR HIGH ROOM 1205	NEW			500 Sq Ft
	319	THROUGHOUT 2ND FLOOR SR. HIGH	NEW			10000 Sq Ft
	326	THROUGHOUT 3RD FLOOR SR. HIGH	NEW			10000 Sq Ft
I3A	2' x 4' Ceiling Tile Textured w/Gouges, Nail & Pin Holes					Total Amount - 1250 Sq Ft
	286	SENIOR HIGH ROOMS 1401B & 1401C	NONE DETECTED	101708-MA-04		1250 Sq Ft
I3B	2' x 4' Ceiling Tile Pin Holes					Total Amount - 958 Sq Ft
	296	SENIOR HIGH ROOM 3117	NONE DETECTED	101708-MA-05		238 Sq Ft
	301	SENIOR HIGH HALLWAY G110	NONE DETECTED			620 Sq Ft
	305	SENIOR HIGH ROOM 3152	NONE DETECTED			100 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
I3C	2' x 4' Ceiling Tile Vinyl-Coated Sheetrock (2014)					Total Amount - 2000 Sq Ft
	10	THROUGHOUT OPEN WORLD LEARNING (HUMBOLDT JUNIOR)	NSM			2000 Sq Ft
J3A	Miscellaneous Cementitious Material Slate Window Sills (1959)					Total Amount - 200 Sq Ft
	116	THROUGHOUT OPEN WORLD LEARNING (HUMBOLDT JUNIOR) 1ST FLOOR 1959 ADDITION	NONE DETECTED	225-23		76 Sq Ft
	190	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2108	NONE DETECTED			32 Sq Ft
	192	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2110	NONE DETECTED			32 Sq Ft
	193	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2112	NONE DETECTED			32 Sq Ft
	196	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2114	NONE DETECTED			4 Sq Ft
	198	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOMS 2116A,B & C	NONE DETECTED			24 Sq Ft
J3B	Miscellaneous Cementitious Material Black Desk Tops					Total Amount - 160 Sq Ft
	223	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3202	NONE DETECTED	101408-MA-01	MA-01: JUNIOR HIGH MEZZANINE ROOM 1920 (SINCE REMOVED).	160 Sq Ft
J3C	Miscellaneous Cementitious Material Black Countertops					Total Amount - 640 Sq Ft
	201	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3209	NONE DETECTED	101408-MA-20		75 Sq Ft
	207	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3215	NONE DETECTED			125 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	219	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3210	NONE DETECTED			380 Sq Ft
	222	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3202	NONE DETECTED			60 Sq Ft
K0N	9" x 9" Vinyl Floor Tile & Mastic Tan w/Dark Brown & White Streaks					Total Amount - 1000 Sq Ft
	199	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2118A	3 CH (TILE), 10 CH (MASTIC)	101408-MA-13		1000 Sq Ft
K1B	Sheet Vinyl Flooring & Adhesive Tan/Beige Terrazzo					Total Amount - 380 Sq Ft
	285	SENIOR HIGH ROOM 1401A CUSTODIAL CLOSET	NONE DETECTED	101708-MA-01		380 Sq Ft
K2B	12" x 12" Vinyl Floor Tile & Mastic Light Brown Pebble-Look					Total Amount - 4096 Sq Ft
	238	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) 1ST FLOOR HALLWAY 1500	NONE DETECTED			2200 Sq Ft
	246	SENIOR HIGH ROOM 1106	NONE DETECTED	101508-MA-13		176 Sq Ft
	248	SENIOR HIGH ROOM 1107	NONE DETECTED			600 Sq Ft
	250	SENIOR HIGH ROOM 1108	NONE DETECTED			600 Sq Ft
	252	SENIOR HIGH ROOM 1109	NONE DETECTED			520 Sq Ft
K2C	12" x 12" Vinyl Floor Tile & Mastic Light Tan w/Brown Flecks					Total Amount - 1282 Sq Ft
	293	SENIOR HIGH ROOM 3126	3 CH (TILE), 5-10 CH (MASTIC)			520 Sq Ft
	302	SENIOR HIGH HALLWAY G110	3 CH (TILE), 5-10 CH (MASTIC)			620 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	303	SENIOR HIGH GYMNASIUM 2300C ENTRY	3 CH (TILE), 5-10 CH (MASTIC)			42 Sq Ft
	306	SENIOR HIGH ROOM 3152	3 CH (TILE), 5-10 CH (MASTIC)	101508-MA-12	MA-12: SENIOR HIGH ROOM 1248 (SINCE REMOVED).	100 Sq Ft
K2J	12" x 12" Vinyl Floor Tile & Mastic Gray w/Black Specks					Total Amount - 6070 Sq Ft
	206	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3215	NONE DETECTED	101408-MA-21		1080 Sq Ft
	209	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3214	NONE DETECTED			340 Sq Ft
	210	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3212	NONE DETECTED			700 Sq Ft
	218	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3210	NONE DETECTED			1250 Sq Ft
	220	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3208	NONE DETECTED			800 Sq Ft
	221	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3202	NONE DETECTED			1000 Sq Ft
	224	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3204	NONE DETECTED			900 Sq Ft
K3A	Miscellaneous Flooring Black Floor Tile Mastic					Total Amount - 285 Sq Ft
	60	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) 1924 ADDITION GYMNASIUM STORAGE ROOM 1302A	NONE DETECTED	101308-MA-06		110 Sq Ft
	61	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) 1924 ADDITION GYMNASIUM STORAGE ROOM 1302B	NONE DETECTED			175 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
K3G	Miscellaneous Flooring 2' x 2' Gray w/Dark Gray Specks (2014)					Total Amount - 15000 Sq Ft
	12	THROUGHOUT OPEN WORLD LEARNING (HUMBOLDT JUNIOR)	NEW			15000 Sq Ft
K3H	Miscellaneous Flooring 2' X 2' Gray w/Gold & White Flecks (2018)					Total Amount - 16600 Sq Ft
	314	GUIDANCE OFFICE/MAIN OFFICE WORK ROOM	NEW			600 Sq Ft
	320	THROUGHOUT 2ND FLOOR SR. HIGH	NEW			8000 Sq Ft
	327	THROUGHOUT 3RD FLOOR SR. HIGH	NEW			8000 Sq Ft
K3I	Miscellaneous Flooring Poured Rubber Floor (2020)					Total Amount - 2000 Sq Ft
	58	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) GYMNASIUM 1301	NEW			2000 Sq Ft
LOA	Flexible Duct Connector Coarse White					Total Amount - 14 Sq Ft
	117	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1106	ASSUMED			14 Sq Ft
M0A	Plaster 1909 Original Building					Total Amount - 100800 Sq Ft
	16	THROUGHOUT OPEN WORLD LEARNING (HUMBOLDT JUNIOR) 1909 ORIGINAL BUILDING	NONE DETECTED	101308-MA-05, 12; 101408-MA-06; 101508-MA-02	02: ROOM 3612 (CEILING). 05: WALL UNDER AHU. 06: ROOM 2703 (WALL). 12: ROOM 1639 (CEILING).	100000 Sq Ft
	17	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1213 (BOILER ROOM)	NONE DETECTED	101508-MA-01		800 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
M0B	Plaster 1924 Addition	Total Amount - 15000 Sq Ft				
	89	THROUGHOUT OPEN WORLD LEARNING (HUMBOLDT JUNIOR) 1924 ADDITION	NONE DETECTED	101508-MA-07, 08, 09, 11; 110613MV-04	MA-07: 1ST FLOOR HALLWAY (WALL). MA-08: ROOM 1605 (WALL). MA-09: ROOM 2608 (WALL). MA-11: STAIRWELL BY ROOM 1606 (CEILING).; MV-04: GYM 1603	15000 Sq Ft
M0C	Plaster 1959 Addition	Total Amount - 25000 Sq Ft				
	115	THROUGHOUT OPEN WORLD LEARNING (HUMBOLDT JUNIOR) 1959 ADDITION	NONE DETECTED	101308-MA-19, 22; 1378-1B, 2B, 6B, 7B, 8B, 9B, 20B; 450-WWA-20	MA-19: SOFFIT OUTSIDE ROOM 1714. MA-22: ROOM 1716. 1B: WOOD SHOP MECHANICAL. WWA-20: 2ND FLOOR. 7B: 2ND FLOOR HALLWAY. 8B: MUSIC AREA ENTRY. 9B: 2ND FLOOR CUSTODIAL CLOSET.	25000 Sq Ft
M0D	Plaster 1975 Addition	Total Amount - 10000 Sq Ft				
	240	THROUGHOUT SENIOR HIGH SCHOOL	NONE DETECTED	510-B-19; 225-40, 41	225-40: ABOVE AUDITORIUM CEILING. 225-41: AUDITORIUM CEILING.	10000 Sq Ft
M0E	Plaster Trowelled	Total Amount - 740 Sq Ft				
	120	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1104	NONE DETECTED	101308-MA-21; 225-7, 8; 225-9, 10	MA-21: JUNIOR HIGH ROOM 1716C (SINCE REMOVED).	320 Sq Ft
	194	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2114	NONE DETECTED	225-11		420 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
NOA	Drywall/Joint Compound 1975 Addition/Installation		Total Amount - 80000 Sq Ft			
	1	THROUGHOUT BUILDING COMPLEX	NONE DETECTED	510-B-18; 225-43, 44, 45	18: MAIN OFFICE. 43: JUNIOR HIGH 3RD FLOOR. 44: JUNIOR HIGH 2ND FLOOR. 45: JUNIOR HIGH STAGE.	80000 Sq Ft
POA	Fire Doors Wood Composite - 1 Hr Rating (Eggers)		Total Amount - 380 Sq Ft			
	19	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1215 (ELECTRICAL ROOM)	20 AM			20 Sq Ft
	39	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) STAFF RESTROOM 1219A	20 AM			20 Sq Ft
	40	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) STAIRWELL BY BOILER ROOM	20 AM			24 Sq Ft
	44	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1302 (ELEVATOR EQUIPMENT ROOM)	20 AM			20 Sq Ft
	83	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1601	20 AM			20 Sq Ft
	98	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1604	20 AM			20 Sq Ft
	114	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1608	20 AM			24 Sq Ft
	125	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) MEZZANINE OFF STAIRWELL 1999B	20 AM			24 Sq Ft
	126	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) MEZZANINE ROOM 1501	20 AM			24 Sq Ft
	129	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) MEZZANINE ROOM 1504	20 AM			20 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	131	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) 2ND FLOOR STAIRWELL BY ROOM 2215	20 AM			40 Sq Ft
	164	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) 2ND FLOOR HALLWAY BY STAIRS 2699C	20 AM			40 Sq Ft
	229	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1524 BY MEN'S LOCKER ROOM	20 AM			24 Sq Ft
	329	SENIOR HIGH 3RD FLOOR STAIRWELL 3299D BY ROOM 3202	20 AM			40 Sq Ft
	330	SENIOR HIGH 3RD FLOOR ROOF ACCESS STAIRWELL 3299E	20 AM			20 Sq Ft
POD	Fire Doors Wood Core - 20 Min Rating (Eggers)					Total Amount - 424 Sq Ft
	67	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1208	NSM			20 Sq Ft
	70	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1207	NSM			20 Sq Ft
	73	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1206	NSM			20 Sq Ft
	75	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1204	NSM			20 Sq Ft
	148	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2601	NSM			20 Sq Ft
	154	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2604	NSM			20 Sq Ft
	162	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) AUDITORIUM STAGE (2300) STORAGE 2407	NSM			20 Sq Ft
	172	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2609	NSM			20 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	180	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2610	NSM			20 Sq Ft
	237	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1521 BY WOMEN'S LOCKER ROOM	NSM			24 Sq Ft
	260	SENIOR HIGH ROOM 3143	NSM			20 Sq Ft
	262	SENIOR HIGH ROOM 3145	NSM			20 Sq Ft
	270	SENIOR HIGH ROOM 1120 (AUDITORIUM)	NSM			100 Sq Ft
	289	SENIOR HIGH ROOM 3127 (WOMEN'S LOCKER ROOM)	NSM			40 Sq Ft
	298	SENIOR HIGH ROOM 3119 (MEN'S LOCKER ROOM)	NSM			40 Sq Ft
P0E	Fire Doors Wood Composite - 3/4 Hr Rating (Eggers)					Total Amount - 40 Sq Ft
	159	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) AUDITORIUM 2300	35 AM			40 Sq Ft
P0F	Fire Doors Wood Composite - 1 Hr Rating (Eggers)					Total Amount - 20 Sq Ft
	107	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) STORAGE ROOM 1401 OUTSIDE GYMNASIUM 1301	NEW			20 Sq Ft
P0I	Fire Doors Metal - 3 Hr Rating (DKS Steel) (2016)					Total Amount - 64 Sq Ft
	105	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1606	NEW			20 Sq Ft
	332	SENIOR HIGH ROOM 3211	NEW			24 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	333	SENIOR HIGH ROOM 3213	NEW			20 Sq Ft
P0J	Fire Doors Metal -1.5 Hr Rating (interteck -2018)					Total Amount - 60 Sq Ft
	322	SENIOR HIGH STAIRWELL 2299C OUTSIDE ROOM 2217	NEW			60 Sq Ft
P0K	Fire Doors Metal -3 Hr Rating (interteck -2018)					Total Amount - 20 Sq Ft
	325	SENIOR HIGH ROOM 2211	NEW			20 Sq Ft
P0L	Fire Doors Wood 1 Hr Rating (Warnock Hersey)					Total Amount - 40 Sq Ft
	308	SENIOR HIGH 1800B CUSTODIAL CLOSET	ASSUMED			20 Sq Ft
	324	SENIOR HIGH ROOM 2316	ASSUMED			20 Sq Ft
P0M	Fire Doors Wood -1.5 Hr Rating Intertek (2022)					Total Amount - 40 Sq Ft
	18	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1213 (BOILER ROOM)	NEW			20 Sq Ft
	166	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2608	NEW			20 Sq Ft
Q0A	Carpet Adhesive Gray/Dark Gray Carpet Tiles (2014)					Total Amount - 8000 Sq Ft
	11	THROUGHOUT OPEN WORLD LEARNING (HUMBOLDT JUNIOR)	NEW			8000 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
Q0B	Carpet Adhesive Orange Carpet	Total Amount - 72500 Sq Ft				
2	THROUGHOUT BUILDING COMPLEX	NONE DETECTED	112114MV-05; 101308-MA-10; 225-46	MV-05: IMC.	72500 Sq Ft	
Q0C	Carpet Adhesive Green, Red & White Berber Carpet	Total Amount - 500 Sq Ft				
86	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1602	NONE DETECTED	082715BV-03	BV-03: ROOM 1602.	500 Sq Ft	
Q0D	Carpet Adhesive Green, Brown & Gray Berber Carpet	Total Amount - 1254 Sq Ft				
92	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1604	NONE DETECTED	082715BV-05	BV-05: ROOM 1604.	418 Sq Ft	
100	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1606	NONE DETECTED			418 Sq Ft	
109	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1608	NONE DETECTED			418 Sq Ft	
Q0E	Carpet Adhesive Multi-Colored Berber Carpet	Total Amount - 2000 Sq Ft				
244	THROUGHOUT SENIOR HIGH SCHOOL	NONE DETECTED	060517-BF-2; 082715BV-10	BF-2: ROOM 1245.	2000 Sq Ft	
Q0F	Carpet Adhesive Blue/Green Carpet Squares (2017)	Total Amount - 1490 Sq Ft				
30	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1221 & ENTRY	NEW			650 Sq Ft	
278	SENIOR HIGH ROOM 1124	NEW			840 Sq Ft	

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
Q0G	Carpet Adhesive Dark Gray W/orange & White Streaks Carpet Squares (2018)					Total Amount - 6000 Sq Ft
	313	THROUGHOUT GUIDANCE OFFICE/MAIN OFFICE	NEW			6000 Sq Ft
ROA	Baseboard/Mopboard Adhesive 6" Dark Brown Baseboard					Total Amount - 5000 Sq Ft
	3	THROUGHOUT BUILDING COMPLEX	NONE DETECTED	112114MV-06; 101408-MA-08; 2001-1901-HJH-2C; 225-47	MV-06: IMC. 2C: JUNIOR HIGH OFFICE NORTHWEST CORNER. 47: SENIOR HIGH ROOM 1234.	5000 Sq Ft
ROB	Baseboard/Mopboard Adhesive 6" Dark Gray Baseboard (2014)					Total Amount - 2000 Sq Ft
	13	THROUGHOUT OPEN WORLD LEARNING (HUMBOLDT JUNIOR)	NEW			2000 Sq Ft
ROC	Baseboard/Mopboard Adhesive 4" Brown Baseboard					Total Amount - 25 Sq Ft
	45	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1302 (ELEVATOR EQUIPMENT ROOM)	NONE DETECTED	082715BV-01	BV-01: ROOM 1302.	5 Sq Ft
	94	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1604	NONE DETECTED			5 Sq Ft
	101	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1606	NONE DETECTED			10 Sq Ft
	153	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2601 (WOMEN'S RESTROOM)	NONE DETECTED			5 Sq Ft
ROD	Baseboard/Mopboard Adhesive 4" Gray Baseboard					Total Amount - 15 Sq Ft
	50	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1304A	NEW			5 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	55	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1305B & HALLWAY 1305	NEW			10 Sq Ft
R0E	Baseboard/Mopboard Adhesive 4" Black Baseboard					Total Amount - 50 Sq Ft
	87	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1602	NONE DETECTED	082715BV-04	BV-04: ROOM 1602.	10 Sq Ft
	110	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1608	NONE DETECTED			10 Sq Ft
	149	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2601	NONE DETECTED			30 Sq Ft
R0F	Baseboard/Mopboard Adhesive 6" Brown 90-Degree Angle Baseboard					Total Amount - 60 Sq Ft
	234	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) GYMNASIUM 2300G	NONE DETECTED	082715BV-07	BV-07: GYMNASIUM 1510.	60 Sq Ft
R0G	Baseboard/Mopboard Adhesive 6" Black 90-Degree Angle Baseboard (2015)					Total Amount - 50 Sq Ft
	283	SENIOR HIGH ROOM 1401 (MAIN GYMNASIUM)	NEW			50 Sq Ft
R0H	Baseboard/Mopboard Adhesive 4" Black (2018)					Total Amount - 4100 Sq Ft
	315	THROUGHOUT GUIDANCE OFFICE/MAIN OFFICE	NEW			100 Sq Ft
	321	THROUGHOUT 2ND FLOOR SR. HIGH	NEW			2000 Sq Ft
	328	THROUGHOUT 3RD FLOOR SR. HIGH	NEW			2000 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
S0B	Wood Floor Felt / Vapor Barrier 1924 Addition (On-Grade)		Total Amount - 2020 Sq Ft			
	93	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1604	6 CH	110613MV-01	MV-01: JUNIOR HIGH 1924 ADDITION GYMNASIUM 1301 (SINCE REMOVED).	680 Sq Ft
	99	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1606	6 CH			680 Sq Ft
	108	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1608	6 CH			660 Sq Ft
S0D	Wood Floor Felt / Vapor Barrier 1975 Addition		Total Amount - 6500 Sq Ft			
	233	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2300G (GYMNASIUM)	2 CH	112114MV-01	MV-01: GYMNASIUM 1401 (SINCE REMOVED).	6500 Sq Ft
S0E	Wood Floor Felt / Vapor Barrier 1909 Original Building (Elevated)		Total Amount - 15175 Sq Ft			
	132	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2215	NSM			880 Sq Ft
	136	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2209	NSM			1100 Sq Ft
	139	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2207	NSM			600 Sq Ft
	146	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2602	NSM			900 Sq Ft
	158	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) AUDITORIUM 2300	NSM			4800 Sq Ft
	160	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) AUDITORIUM STAGE (2300)	NSM			1500 Sq Ft
	184	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2202-2210	NSM			1630 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	200	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3209	NSM			900 Sq Ft
	212	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3205	NSM			280 Sq Ft
	213	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3203	NSM			120 Sq Ft
	216	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3201	NSM			365 Sq Ft
	225	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3204	NSM			900 Sq Ft
	228	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3206	NSM			1200 Sq Ft
S0F	Wood Floor Felt / Vapor Barrier 1924 Addition (Elevated)				Total Amount - 1320 Sq Ft	
	155	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2606	ASSUMED			660 Sq Ft
	165	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2608	ASSUMED			660 Sq Ft
S0G	Wood Floor Felt / Vapor Barrier Stage (1975)				Total Amount - 3500 Sq Ft	
	273	SENIOR HIGH ROOM 1125 (STAGE)	ASSUMED			3500 Sq Ft
S0H	Wood Floor Felt / Vapor Barrier 2015 Installation				Total Amount - 12000 Sq Ft	
	282	SENIOR HIGH ROOM 1401 (MAIN GYMNASIUM)	NEW			12000 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
VOB		Sink Undercoating Pink	Total Amount - 18 Sq Ft			
	82	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1601	5-8 CH			4 Sq Ft
	140	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2207	5-8 CH			4 Sq Ft
	175	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2609 OFFICE	5-8 CH			5 Sq Ft
	217	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3201	5-8 CH	082715BV-11	BV-11: ROOM 3222 (SINCE REMOVED).	5 Sq Ft
VOH		Sink Undercoating Gray Bottom Only (200X)	Total Amount - 11 Sq Ft			
	97	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1604	NEW			5 Sq Ft
	104	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1606	NEW			5 Sq Ft
	113	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1608	NEW			1 Sq Ft
VOI		Sink Undercoating Black w/Four Holes Under Faucet (2014)	Total Amount - 40 Sq Ft			
	118	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1106	NEW			10 Sq Ft
	121	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1104	NEW			10 Sq Ft
	122	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1110	NEW			10 Sq Ft
	141	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2207	NEW			5 Sq Ft
	188	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) PRODUCTION SHOP ROOM 2105A	NEW			5 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
V0J	Sink Undercoating Deep Black					Total Amount - 24 Sq Ft
	130	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) MEZZANINE ROOM 1504	NONE DETECTED	082715BV-06	BV-06: ROOM 3209.	8 Sq Ft
	203	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3209	NONE DETECTED			8 Sq Ft
	208	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3215	NONE DETECTED			8 Sq Ft
W1A	1' x 1' Ceiling Tile Adhesive Associated w/I1A					Total Amount - 1380 Sq Ft
	23	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) HALLWAY 1640 OUTSIDE BOILER ROOM	NONE DETECTED	101308-MA-03		50 Sq Ft
	78	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) HALLWAY/RAMP 1600	NONE DETECTED			100 Sq Ft
	91	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1604	NONE DETECTED			175 Sq Ft
	138	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2207	NONE DETECTED			30 Sq Ft
	143	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2205	NONE DETECTED	101408-MA-05		210 Sq Ft
	144	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2203	NONE DETECTED	110613MV-07	MV-07: JUNIOR HIGH ROOM 2631A (SINCE REMOVED).	65 Sq Ft
	170	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2609	NONE DETECTED			200 Sq Ft
	173	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2609 OFFICE	NONE DETECTED			50 Sq Ft
	176	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2610	NONE DETECTED			200 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	181	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2202-2210	NONE DETECTED			300 Sq Ft
W1B	1' x 1' Ceiling Tile Adhesive Associated w/I1B					Total Amount - 410 Sq Ft
	29	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1221 & ENTRY	<1 ANT	101308-MA-02		200 Sq Ft
	32	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1221 STORAGE	<1 ANT			15 Sq Ft
	38	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) STAFF RESTROOM	<1 ANT			25 Sq Ft
	43	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1302 (ELEVATOR EQUIPMENT ROOM)	<1 ANT	510-B-11P	510-B-11P: ROOM 1615 (SINCE REMOVED).	40 Sq Ft
	47	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1304	<1 ANT			50 Sq Ft
	215	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3201	<1 ANT	101508-MA-04	MA-04: JUNIOR HIGH ROOM 3632A (SINCE REMOVED).	80 Sq Ft
X0AA	Miscellaneous Material Exterior Brick Mortar					Total Amount - 5000 Sq Ft
	336	THROUGHOUT EXTERIOR BUILDING	NONE DETECTED	060517-BF-13		5000 Sq Ft
X0B	Miscellaneous Material Gray Floor Filler					Total Amount - 190 Sq Ft
	49	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1304A	NONE DETECTED			10 Sq Ft
	51	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1305A, 1305B & HALLWAY 1305	NONE DETECTED	101308-MA-10		140 Sq Ft
	62	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) 1924 ADDITION GYMNASIUM STORAGE ROOM 1302B	NONE DETECTED			40 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
X0BB	Miscellaneous Material Interior Expansion Joint Caulk					Total Amount - 100 Sq Ft
	6	THROUGHOUT BUILDING COMPLEX	5-7 CH	060818-BF-1, 3; 062817-BF-1	BF-1: ROOM 1233C. BF-3: HALLWAY BY ROOM 1252. BF-1: STAIRWELL NEAR DOOR 33.	100 Sq Ft
X0C	Miscellaneous Material Whiteboard Adhesive -Tan					Total Amount - 1000 Sq Ft
	15	THROUGHOUT OPEN WORLD LEARNING (HUMBOLDT JUNIOR)	NONE DETECTED	110613MV-10	ROOM 3616	1000 Sq Ft
X0CC	Miscellaneous Material Caulking Around Columns					Total Amount - 100 Sq Ft
	7	THROUGHOUT BUILDING COMPLEX	5 CH	060818-BF-2, 4; 062617BV-01	BF-2: HALLWAY BY ROOM 1258. BF-4: HALLWAY BY ROOM 1252. BV-01: ROOM 1244.	100 Sq Ft
X0D	Miscellaneous Material Wood Frame Slate Chalkboard Adhesive (1909)					Total Amount - 6 Sq Ft
	88	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1602	ASSUMED			6 Sq Ft
X0E	Miscellaneous Material Wood Frame Tackboard Adhesive (1924)					Total Amount - 48 Sq Ft
	103	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1606	ASSUMED			16 Sq Ft
	112	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1608	ASSUMED			15 Sq Ft
	157	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2606	ASSUMED			6 Sq Ft
	168	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2608	ASSUMED			6 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	179	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2610	ASSUMED			5 Sq Ft
X0EE	Miscellaneous Material Expansion Joint Caulk					Total Amount - 100 Sq Ft
	334	THROUGHOUT EXTERIOR BUILDING	NONE DETECTED	060517-BF-11		100 Sq Ft
X0M	Miscellaneous Material Tan Tackboard Adhesive					Total Amount - 20 Sq Ft
	211	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3212	NONE DETECTED	110613MV-12, 16	MV-12: JUNIOR HIGH ROOM 3208 (SINCE REMOVE). MV-16: JUNIOR HIGH ROOM 3639.	20 Sq Ft
X0N	Miscellaneous Material Wood Frame Slate Chalkboard Adhesive (1924)					Total Amount - 101 Sq Ft
	95	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1604	ASSUMED			6 Sq Ft
	102	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1606	ASSUMED			10 Sq Ft
	111	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1608	ASSUMED			20 Sq Ft
	156	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2606	ASSUMED			30 Sq Ft
	167	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2608	ASSUMED			30 Sq Ft
	178	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2610	ASSUMED			5 Sq Ft
X0O	Miscellaneous Material Wood Frame Tackboard Adhesive (1909)					Total Amount - 50 Sq Ft
	59	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) GYMNASIUM 1301	ASSUMED			5 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	147	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2602	ASSUMED			45 Sq Ft
X0T	Miscellaneous Material Tackboard Adhesive					Total Amount - 20 Sq Ft
	202	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3209	NONE DETECTED	110613MV-17		20 Sq Ft
X0U	Miscellaneous Material Thin Metal Frame Tackboard Adhesive					Total Amount - 120 Sq Ft
	96	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1604	ASSUMED			120 Sq Ft
X0V	Miscellaneous Material White Woven Fire Curtain					Total Amount - 900 Sq Ft
	274	SENIOR HIGH ROOM 1125 (STAGE)	35 CH	082715BV-08	BV-08: STAGE 1125.	900 Sq Ft
X0W	Miscellaneous Material Beige w/White & Gray Specks Rubber Flooring (2015)					Total Amount - 30000 Sq Ft
	243	THROUGHOUT SENIOR HIGH SCHOOL	NEW			30000 Sq Ft
X0X	Miscellaneous Material Light Gray Rubber Flooring (200X)					Total Amount - 3600 Sq Ft
	304	SENIOR HIGH AUXILIARY GYMNASIUM 2300C	NEW			3600 Sq Ft
X0Z	Miscellaneous Material Black Dampproofing					Total Amount - 5000 Sq Ft
	335	THROUGHOUT EXTERIOR BUILDING	10 CH	060517-BF-12		5000 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
X1A	Miscellaneous Material 1" Ceramic Floor Tile System, Tan & Brown					Total Amount - 1500 Sq Ft
	128	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) MEZZANINE ROOM 1504	NONE DETECTED	020314JD-04, 05, 06		1500 Sq Ft
X1B	Miscellaneous Material 4" Cream Ceramic Wall Tile System (2014)					Total Amount - 890 Sq Ft
	21	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) UNISEX RESTROOM BY ROOM 1215	NEW			90 Sq Ft
	133	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) GIRLS' RESTROOM 2213	NEW			200 Sq Ft
	134	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) BOYS' RESTROOM 2211	NEW			200 Sq Ft
	204	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) GIRLS' RESTROOM BY ROOM 3209	NEW			200 Sq Ft
	205	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) BOYS' RESTROOM BY ROOM 3215	NEW			200 Sq Ft
X1C	Miscellaneous Material 1' x 2' Gray Ceramic Floor Tile System (2014)					Total Amount - 500 Sq Ft
	25	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) GIRLS' RESTROOM 1222	NEW			240 Sq Ft
	63	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) BOYS' RESTROOM 1220	NEW			260 Sq Ft
X1D	Miscellaneous Material 4" x 6" White Ceramic Wall Tile System (2014)					Total Amount - 640 Sq Ft
	26	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) GIRLS' RESTROOM 1222	NEW			240 Sq Ft
	35	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) STAFF RESTROOM	NEW			100 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
	64	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) BOYS' RESTROOM 1220	NEW			260 Sq Ft
	142	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2207 RESTROOM	NEW			40 Sq Ft
X1E	Miscellaneous Material 6" Light Blue Ceramic Wall Tile System (2014)					Total Amount - 100 Sq Ft
	27	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) GIRLS' RESTROOM 1222	NEW			50 Sq Ft
	65	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) BOYS' RESTROOM 1220	NEW			50 Sq Ft
X1F	Miscellaneous Material 2" Gray w/White Specks Ceramic Floor Tile System (2014)					Total Amount - 50 Sq Ft
	34	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) STAFF RESTROOM	NEW			50 Sq Ft
X1G	Miscellaneous Material Multi-Sized Gray w/Blue Triangles Ceramic Floor Tile System					Total Amount - 725 Sq Ft
	48	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1304A	NONE DETECTED			215 Sq Ft
	52	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1305A, 1305B & HALLWAY 1305	NONE DETECTED	082715BV-02	BV-02: ROOM 1305.	510 Sq Ft
X1H	Miscellaneous Material 6" Green Ceramic Wall Tile System (2014)					Total Amount - 500 Sq Ft
	14	THROUGHOUT OPEN WORLD LEARNING (HUMBOLDT JUNIOR)	NEW			500 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
X1I	Miscellaneous Material 2" Beige & Brown Ceramic Floor Tile System (2014)					Total Amount - 4000 Sq Ft
	4	THROUGHOUT BUILDING COMPLEX	NEW			4000 Sq Ft
X1J	Miscellaneous Material 6" Gray Quarry Tile (2014)					Total Amount - 1200 Sq Ft
	123	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) THROUGHOUT KITCHEN AREA	NEW			1200 Sq Ft
X1K	Miscellaneous Material 6" Mauve Ceramic Floor Tile System					Total Amount - 100 Sq Ft
	150	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2601 RESTROOMS	NEW			100 Sq Ft
X1L	Miscellaneous Material Multi-Sized Brown Ceramic Floor Tile System					Total Amount - 18 Sq Ft
	151	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2601 RESTROOMS	ASSUMED			18 Sq Ft
X1M	Miscellaneous Material 6" Beige Quarry Tile					Total Amount - 2500 Sq Ft
	5	THROUGHOUT BUILDING COMPLEX	ASSUMED			2500 Sq Ft
X1N	Miscellaneous Material 1" Brown, Beige & Black Ceramic Floor Tile System					Total Amount - 5500 Sq Ft
	267	SENIOR HIGH ROOM 2300I (POOL)	ASSUMED			5500 Sq Ft
X1O	Miscellaneous Material 2" x 2" Tan & Brown Ceramic Floor Tile System (2017)					Total Amount - 400 Sq Ft
	279	SENIOR HIGH RESTROOMS OFF OF ROOM 1124	NEW			400 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
X1P	Miscellaneous Material 6" X 6" Gray Ceramic Wall Tile System (2018)					Total Amount - 250 Sq Ft
	316	GUIDANCE OFFICE/MAIN OFFICE WORK ROOM	NEW			250 Sq Ft
X1Q	Miscellaneous Material 1' X 1' Gray Ceramic Floor Tile System (2018)					Total Amount - 80 Sq Ft
	317	GUIDANCE OFFICE/MAIN OFFICE WORK ROOM	NEW			80 Sq Ft
X1S	Miscellaneous Material 12" X 12" Dark Gray Ceramic Floor Tile System (2020)					Total Amount - 800 Sq Ft
	268	RESTROOMS OUTSIDE OF SOUTH POOL ENTRANCE	NEW			800 Sq Ft