

Chart B - Assessment of Asbestos-Containing Building Materials (ACBM)

All asbestos-containing events listed here are to be inspected during each six-month periodic surveillance for changes in condition. The Institute for Environmental assessment (IEA) highly recommends an in-depth "front end" inspection prior to any general renovation or remodeling to determine if those activities may disrupt building materials that may involve existing or undiscovered asbestos. Potentially inaccessible or exempt asbestos-containing materials not included in this plan may include: adhesives, caulking, putty, woven blankets, curtains, gloves and gaskets, electrical wiring insulation and heat shields above lights, paints and coatings, roofing felts, flashings and shingles, and mineral core fire doors.

Damaged materials which require corrective action to reduce a potential hazard are indicated on Chart A. All non-damaged ACBM identified in Chart B should be monitored through scheduled inspections and removed prior to renovation or demolition activities, or when their condition deteriorates.

District administration will direct another formal inspection by a federally-certified inspector within three (3) years, and will maintain an on-going file for each building. Specific recommendations on how to manage the different types of Asbestos-containing material are identified in the Asbestos Management Plan.

PLEASE NOTE: Based on EPA recommendations, materials analyzed utilizing PLM and found to contain between 0% and 10% should be assumed asbestos containing unless building owner wishes the laboratory to utilize "point counting." For samples analyzed prior to 1994 containing 1% or less (trace) of asbestos, resampling utilizing the 1993 EPA Test Method or point counting is strongly recommended for purposes of demolition or renovation before treating these materials as non-asbestos containing. Contact your local IEA office for questions or additional information.

EPA ASSESSMENT CATEGORIES:	1 = Damaged or significantly damaged TSI ACM 2 = Damaged friable surfacing ACM 3 = Significantly damaged friable surfacing ACM 4 = Damaged or significantly damaged friable miscellaneous ACM	5 = ACBM with potential for damage 6 = ACBM with potential for significant damage 7 = Remaining friable ACBM or friable suspect ACBM
-----------------------------------	--	--

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
5 CAD #:	X1M	Miscellaneous Material 6" Beige Quarry Tile	THROUGHOUT BUILDING COMPLEX	2500 Sq Ft	N	ASSUMED	5
Comments: AT ENTRANCES.					Sample #:		
6 CAD #:	X0BB	Miscellaneous Material Interior Expansion Joint Caulk	THROUGHOUT BUILDING COMPLEX	100 Sq Ft	N	5-7 CH	5
Comments: AMOUNT ESTIMATED.					Sample #:	060818-BF-1, 3; 062817-BF-1	
7 CAD #:	X0CC	Miscellaneous Material Caulking Around Columns	THROUGHOUT BUILDING COMPLEX	100 Sq Ft	N	5 CH	5
Comments: CAULKING AT WHERE COLUMNS MEET WALLS.					Sample #:	060818-BF-2, 4; 062617BV-01	
19 CAD #:	P0A	Fire Doors Wood Composite - 1 Hr Rating (Eggers)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1215 (ELECTRICAL ROOM)	20 Sq Ft	N	20 AM	5
Comments: ONE (1) DOOR.					Sample #:		
39 CAD #:	P0A	Fire Doors Wood Composite - 1 Hr Rating (Eggers)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) STAFF RESTROOM 1219A	20 Sq Ft	N	20 AM	5
Comments: ONE (1) DOOR.					Sample #:		
40 CAD #:	P0A	Fire Doors Wood Composite - 1 Hr Rating (Eggers)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) STAIRWELL BY BOILER ROOM	24 Sq Ft	N	20 AM	5
Comments: ONE (1) DOOR. TO LOWER 1ST FLOOR.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
44 CAD #:	P0A	Fire Doors Wood Composite - 1 Hr Rating (Eggers)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1302 (ELEVATOR EQUIPMENT ROOM)	20 Sq Ft	N	20 AM	5
Comments: ONE (1) DOOR.					Sample #:		
46 CAD #:	B1A	Air Cell Pipe Insulation 1909 Original Building	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1304	15 Lin Ft	N	ASSUMED	5
Comments: IN WALL CHASE ON NORTH WALL BEHIND SHEETROCK. INACCESSIBLE.					Sample #:		
56 CAD #:	B2A	Millboard Pipe Insulation 1924 Original Building	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) GYMNASIUM 1301	20 Lin Ft	N	ASSUMED	5
Comments: NORTHWEST CORNER WALL CHASE. ACCESS THROUGH WOOD PANEL. SCREWS STARTING TO STRIP. DIFFICULT TO ACCESS.					Sample #:		
57 CAD #:	A2A	Mudded Pipe Joints on Millboard Insulation 1924 Original Building	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) GYMNASIUM 1301	4 Joints	N	ASSUMED	5
Comments: NORTHWEST CORNER WALL CHASE. ACCESS THROUGH WOOD PANEL. SCREWS STARTING TO STRIP. DIFFICULT TO ACCESS.					Sample #:		
59 CAD #:	X0O	Miscellaneous Material Wood Frame Tackboard Adhesive (1909)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) GYMNASIUM 1301	5 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
82 CAD #:	V0B	Sink Undercoating Pink	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1601	4 Sq Ft	N	5-8 CH	5
Comments: ONE (1) SINK.					Sample #:		
83 CAD #:	P0A	Fire Doors Wood Composite - 1 Hr Rating (Eggers)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1601	20 Sq Ft	N	20 AM	5
Comments: ONE (1) DOOR.					Sample #:		
88 CAD #:	X0D	Miscellaneous Material Wood Frame Slate Chalkboard Adhesive (1909)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1602	6 Sq Ft	N	ASSUMED	5
Comments: ONE (1) CHALKBOARD.					Sample #:		
93 CAD #:	S0B	Wood Floor Felt / Vapor Barrier 1924 Addition (On-Grade)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1604	680 Sq Ft	N	6 CH	5
Comments: UNDER CARPET.					Sample #: 110613MV-01		
95 CAD #:	X0N	Miscellaneous Material Wood Frame Slate Chalkboard Adhesive (1924)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1604	6 Sq Ft	N	ASSUMED	5
Comments: ONE (1) CHALKBOARD.					Sample #:		
96 CAD #:	X0U	Miscellaneous Material Thin Metal Frame Tackboard Adhesive	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1604	120 Sq Ft	N	ASSUMED	5
Comments: THREE (3) BOARDS.					Sample #:		
98 CAD #:	P0A	Fire Doors Wood Composite - 1 Hr Rating (Eggers)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1604	20 Sq Ft	N	20 AM	5
Comments: ONE (1) DOOR.					Sample #:		
99 CAD #:	S0B	Wood Floor Felt / Vapor Barrier 1924 Addition (On-Grade)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1606	680 Sq Ft	N	6 CH	5
Comments:					Sample #:		
102 CAD #:	X0N	Miscellaneous Material Wood Frame Slate Chalkboard Adhesive (1924)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1606	10 Sq Ft	N	ASSUMED	5
Comments: ONE (1) CHALKBOARD.					Sample #:		
103 CAD #:	X0E	Miscellaneous Material Wood Frame Tackboard Adhesive (1924)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1606	16 Sq Ft	N	ASSUMED	5
Comments: TWO (2) TACKBOARDS.					Sample #:		
108 CAD #:	S0B	Wood Floor Felt / Vapor Barrier 1924 Addition (On-Grade)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1608	660 Sq Ft	N	6 CH	5
Comments:					Sample #:		
111 CAD #:	X0N	Miscellaneous Material Wood Frame Slate Chalkboard Adhesive (1924)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1608	20 Sq Ft	N	ASSUMED	5
Comments: THREE (3) CHALKBOARDS.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
112 CAD #:	X0E	Miscellaneous Material Wood Frame Tackboard Adhesive (1924)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1608	15 Sq Ft	N	ASSUMED	5
Comments: FOUR (4) TACKBOARDS.					Sample #:		
114 CAD #:	P0A	Fire Doors Wood Composite - 1 Hr Rating (Eggers)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1608	24 Sq Ft	N	20 AM	5
Comments: ONE (1) DOOR. TAG MISSING.					Sample #:		
117 CAD #:	L0A	Flexible Duct Connector Coarse White	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1106	14 Sq Ft	N	ASSUMED	5
Comments: ABOVE CEILING. TWO (2) JOINTS.					Sample #:		
125 CAD #:	P0A	Fire Doors Wood Composite - 1 Hr Rating (Eggers)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) MEZZANINE OFF STAIRWELL 1999B	24 Sq Ft	N	20 AM	5
Comments: ONE (1) DOOR. ACROSS FROM ELIVATOR UP THE STAIRS FROM THE BOILER ROOM.					Sample #:		
126 CAD #:	P0A	Fire Doors Wood Composite - 1 Hr Rating (Eggers)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) MEZZANINE ROOM 1501	24 Sq Ft	N	20 AM	5
Comments: ONE (1) DOOR.					Sample #:		
129 CAD #:	P0A	Fire Doors Wood Composite - 1 Hr Rating (Eggers)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) MEZZANINE ROOM 1504	20 Sq Ft	N	20 AM	5
Comments: ONE (1) DOOR. STAIRWELL 1999C.					Sample #:		
131 CAD #:	P0A	Fire Doors Wood Composite - 1 Hr Rating (Eggers)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) 2ND FLOOR STAIRWELL BY ROOM 2215	40 Sq Ft	N	20 AM	5
Comments: TWO (2) DOORS.					Sample #:		
140 CAD #:	V0B	Sink Undercoating Pink	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2207	4 Sq Ft	N	5-8 CH	5
Comments: ONE (1) SINK.					Sample #:		
147 CAD #:	X0O	Miscellaneous Material Wood Frame Tackboard Adhesive (1909)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2602	45 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
151 CAD #:	X1L	Miscellaneous Material Multi-Sized Brown Ceramic Floor Tile System	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2601 RESTROOMS	18 Sq Ft	N	ASSUMED	5
Comments: IN SHOWERS.					Sample #:		
155 CAD #:	S0F	Wood Floor Felt / Vapor Barrier 1924 Addition (Elevated)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2606	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
156 CAD #:	X0N	Miscellaneous Material Wood Frame Slate Chalkboard Adhesive (1924)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2606	30 Sq Ft	N	ASSUMED	5
Comments: THREE (3) CHALKBOARDS.					Sample #:		
157 CAD #:	X0E	Miscellaneous Material Wood Frame Tackboard Adhesive (1924)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2606	6 Sq Ft	N	ASSUMED	5
Comments: SMALL BOARD ABOVE CHALKBOARD.					Sample #:		
159 CAD #:	P0E	Fire Doors Wood Composite - 3/4 Hr Rating (Eggers)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) AUDITORIUM 2300	40 Sq Ft	N	35 AM	5
Comments: TWO (2) DOORS AT SOUTHWEST ENTRANCE.					Sample #:		
164 CAD #:	P0A	Fire Doors Wood Composite - 1 Hr Rating (Eggers)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) 2ND FLOOR HALLWAY BY STAIRS 2699C	40 Sq Ft	Y	20 AM	4
Comments: TWO (2) DOORS. FOUR HOLES AT TOP EDGE OF NW DOOR					Sample #:		
165 CAD #:	S0F	Wood Floor Felt / Vapor Barrier 1924 Addition (Elevated)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2608	660 Sq Ft	N	ASSUMED	5
Comments: UNDER CARPET.					Sample #:		
167 CAD #:	X0N	Miscellaneous Material Wood Frame Slate Chalkboard Adhesive (1924)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2608	30 Sq Ft	N	ASSUMED	5
Comments: THREE (3) CHALKBOARDS.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
168 CAD #:	X0E	Miscellaneous Material Wood Frame Tackboard Adhesive (1924)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2608	6 Sq Ft	N	ASSUMED	5
Comments: ABOVE CHALKBOARDS.					Sample #:		
175 CAD #:	V0B	Sink Undercoating Pink	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2609 OFFICE	5 Sq Ft	N	5-8 CH	5
Comments: ONE (1) SINK.					Sample #:		
178 CAD #:	X0N	Miscellaneous Material Wood Frame Slate Chalkboard Adhesive (1924)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2610	5 Sq Ft	N	ASSUMED	5
Comments: ONE (1) CHALKBOARD.					Sample #:		
179 CAD #:	X0E	Miscellaneous Material Wood Frame Tackboard Adhesive (1924)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2610	5 Sq Ft	N	ASSUMED	5
Comments: ONE (1) TACKBOARD.					Sample #:		
199 CAD #:	K0N	9" x 9" Vinyl Floor Tile & Mastic Tan w/Dark Brown & White Streaks	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2118A	1000 Sq Ft	N	3 CH (TILE), 10 CH (MASTIC)	5
Comments: MASTIC ONLY ON RISERS. UNDER CARPET.					Sample #:	101408-MA-13	
217 CAD #:	V0B	Sink Undercoating Pink	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 3201	5 Sq Ft	N	5-8 CH	5
Comments: ONE (1) SINK.					Sample #:	082715BV-11	
229 CAD #:	P0A	Fire Doors Wood Composite - 1 Hr Rating (Eggers)	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 1524 BY MEN'S LOCKER ROOM	24 Sq Ft	Y	20 AM	4
Comments: ONE (1) DOOR. SEVERAL SCREW HOLES, 2 OPEN EXPOSING INTERIOR OF DOOR.					Sample #:		
233 CAD #:	S0D	Wood Floor Felt / Vapor Barrier 1975 Addition	OPEN WORLD LEARNING (HUMBOLDT JUNIOR) ROOM 2300G (GYMNASIUM)	6500 Sq Ft	N	2 CH	5
Comments:					Sample #:	112114MV-01	
267 CAD #:	X1N	Miscellaneous Material 1" Brown, Beige & Black Ceramic Floor Tile System	SENIOR HIGH ROOM 2300I (POOL)	5500 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
273 CAD #:	S0G	Wood Floor Felt / Vapor Barrier Stage (1975)	SENIOR HIGH ROOM 1125 (STAGE)	3500 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
274 CAD #:	X0V	Miscellaneous Material White Woven Fire Curtain	SENIOR HIGH ROOM 1125 (STAGE)	900 Sq Ft	N	35 CH	5
Comments: ON WALL ABOVE STAGE OPENING.					Sample #:	082715BV-08	
293 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Light Tan w/Brown Flecks	SENIOR HIGH ROOM 3126	520 Sq Ft	N	3 CH (TILE), 5- 10 CH (MASTIC)	5
Comments: MISSING 3 FULL TILES EXPOSING MASTIC. TILE WEARING. RECOMMEND INSTALLATION OF CHAIR MATS.					Sample #:		
302 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Light Tan w/Brown Flecks	SENIOR HIGH HALLWAY G110	620 Sq Ft	N	3 CH (TILE), 5- 10 CH (MASTIC)	5
Comments: CRACKING & CHIPPING AT ENTRANCE. PIECES OF TILE MISSING AT ENTRANCE. TILES LOOSENING W/SPACES IN BETWEEN.					Sample #:		
303 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Light Tan w/Brown Flecks	SENIOR HIGH GYMNASIUM 2300C ENTRY	42 Sq Ft	N	3 CH (TILE), 5- 10 CH (MASTIC)	5
Comments: ENTRY TO AUXILIARY GYMNASIUM.					Sample #:		
306 CAD #:	K2C	12" x 12" Vinyl Floor Tile & Mastic Light Tan w/Brown Flecks	SENIOR HIGH ROOM 3152	100 Sq Ft	N	3 CH (TILE), 5- 10 CH (MASTIC)	5
Comments:					Sample #:	101508-MA-12	

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
308 CAD #:	P0L	Fire Doors Wood 1 Hr Rating (Warnock Hersey)	SENIOR HIGH 1800B CUSTODIAL CLOSET	20 Sq Ft	Y	ASSUMED	4
Comments: 1/4" HOLE IN CENTER OF INSIDE OF DOOR. INTERIOR CORE EXPOSED.					Sample #:		
324 CAD #:	P0L	Fire Doors Wood 1 Hr Rating (Warnock Hersey)	SENIOR HIGH ROOM 2316	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
329 CAD #:	P0A	Fire Doors Wood Composite - 1 Hr Rating (Eggers)	SENIOR HIGH 3RD FLOOR STAIRWELL 3299D BY ROOM 3202	40 Sq Ft	N	20 AM	5
Comments: TWO (2) DOORS.					Sample #:		
330 CAD #:	P0A	Fire Doors Wood Composite - 1 Hr Rating (Eggers)	SENIOR HIGH 3RD FLOOR ROOF ACCESS STAIRWELL 3299E	20 Sq Ft	N	20 AM	5
Comments: ONE (1) DOOR.					Sample #:		
335 CAD #:	X0Z	Miscellaneous Material Black Dampproofing	THROUGHOUT EXTERIOR BUILDING	5000 Sq Ft	N	10 CH	5
Comments: ASSUMED PRESENT BELOW GRADE. AMOUNT ESTIMATED. VISIBLE OUTSIDE ART ROOM 1259.					Sample #:	060517-BF-12	