

1157 Selby Avenue, Saint Paul, MN 55104

Chart C - All Materials List		The following list contains all events observed by the inspector, whether or not they actually contained asbestos, and are grouped by homogeneous area (material type).				
Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
K3A	Miscellaneous Flooring Epoxy Flooring -Red, Black, Gray, White (2021)					Total Amount - 700 Sq Ft
	1	THROUGHOUT BUILDING	NEW			700 Sq Ft
N0A	Drywall/Joint Compound Ceiling					Total Amount - 1175 Sq Ft
	4	GARAGE	<1 CH	041509ML-03	ML-03: ABOVE STORAGE.	750 Sq Ft
	5	OFFICE	<1 CH			350 Sq Ft
	6	RESTROOM	<1 CH			25 Sq Ft
	10	STORAGE WITH OUTSIDE ENTRANCE	<1 CH			50 Sq Ft
X0A	Miscellaneous Material Interior White Window Glazing					Total Amount - 7 Sq Ft
	2	GARAGE	2 CH	041509ML-01	ML-01: ABOVE STORAGE.	7 Sq Ft
X0B	Miscellaneous Material Interior Dark Window Glazing					Total Amount - 17 Sq Ft
	3	GARAGE	2 CH	041509ML-02		16 Sq Ft
	9	RESTROOM	2 CH			1 Sq Ft

Homogeneous Area ID Code (Material Type)	IEA Event No.	Location	% Asbestos	Sample No.	Sample Location	Estimated Total Amount
X1A	Miscellaneous Material 4" x 4" Pink Ceramic Wall Tile System					Total Amount - 90 Sq Ft
	7	RESTROOM	ASSUMED			90 Sq Ft
X1B	Miscellaneous Material 4" x 4" Blue Ceramic Floor Tile System					Total Amount - 25 Sq Ft
	8	RESTROOM	ASSUMED			25 Sq Ft