

Chart B - Assessment of Asbestos-Containing Building Materials (ACBM)

All asbestos-containing events listed here are to be inspected during each six-month periodic surveillance for changes in condition. The Institute for Environmental assessment (IEA) highly recommends an in-depth "front end" inspection prior to any general renovation or remodeling to determine if those activities may disrupt building materials that may involve existing or undiscovered asbestos. Potentially inaccessible or exempt asbestos-containing materials not included in this plan may include: adhesives, caulking, putty, woven blankets, curtains, gloves and gaskets, electrical wiring insulation and heat shields above lights, paints and coatings, roofing felts, flashings and shingles, and mineral core fire doors.

Damaged materials which require corrective action to reduce a potential hazard are indicated on Chart A. All non-damaged ACBM identified in Chart B should be monitored through scheduled inspections and removed prior to renovation or demolition activities, or when their condition deteriorates.

District administration will direct another formal inspection by a federally-certified inspector within three (3) years, and will maintain an on-going file for each building. Specific recommendations on how to manage the different types of Asbestos-containing material are identified in the Asbestos Management Plan.

PLEASE NOTE: Based on EPA recommendations, materials analyzed utilizing PLM and found to contain between 0% and 10% should be assumed asbestos containing unless building owner wishes the laboratory to utilize "point counting." For samples analyzed prior to 1994 containing 1% or less (trace) of asbestos, resampling utilizing the 1993 EPA Test Method or point counting is strongly recommended for purposes of demolition or renovation before treating these materials as non-asbestos containing. Contact your local IEA office for questions or additional information.

EPA ASSESSMENT CATEGORIES:		1 = Damaged or significantly damaged TSI ACM 2 = Damaged friable surfacing ACM 3 = Significantly damaged friable surfacing ACM 4 = Damaged or significantly damaged friable miscellaneous ACM		5 = ACBM with potential for damage 6 = ACBM with potential for significant damage 7 = Remaining friable ACBM or friable suspect ACBM			
IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assessment Category
6 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1915 Original Building	THROUGHOUT 1915 ORIGINAL BUILDING	20000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
8 CAD #:	S0B	Wood Floor Felt / Vapor Barrier 1920 Addition (Elevated)	THROUGHOUT 1920 ADDITION	3000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
11 CAD #:	S0C	Wood Floor Felt / Vapor Barrier 1923 Addition	THROUGHOUT 1923 ADDITION	6000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
12 CAD #:	D3A	Gasket Header Flange Gaskets	BOILER ROOM (TB1)	10 Sq Ft	N	ASSUMED	5
Comments: TEN (10) GATE VALVES.					Sample #:		
14 CAD #:	L0D	Flexible Duct Connector White Woven	CRAWL SPACE/MECHANICAL 1201	6 Sq Ft	N	60 CH	5
Comments: TWO (2) CONNECTORS.					Sample #: 545-3		
23 CAD #:	X0D	Miscellaneous Material Chalkboard Adhesive (1920)	ROOM 1405	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
24 CAD #:	X0J	Miscellaneous Material Corkboard Adhesive (1920)	ROOM 1405	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
27 CAD #:	X0F	Miscellaneous Material Chalkboard Adhesive (1923)	ROOM 1407	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
28 CAD #:	X0K	Miscellaneous Material Corkboard Adhesive (1923)	ROOM 1407	130 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
31 CAD #:	X0F	Miscellaneous Material Chalkboard Adhesive (1923)	ROOM 1409	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
32 CAD #:	X0K	Miscellaneous Material Corkboard Adhesive (1923)	ROOM 1409	130 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
33 CAD #:	X1A	Miscellaneous Material 4" X 4" White with Green or Beige Accents Ceramic Wall Tile System	BOYS' AND GIRLS' RESTROOM ACROSS FROM ROOM 1409	420 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
34 CAD #:	X1B	Miscellaneous Material 2" X 2" Gray with White Specks Ceramic Floor Tile System	BOYS' AND GIRLS' RESTROOM ACROSS FROM ROOM 1409	160 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
38 CAD #:	X0F	Miscellaneous Material Chalkboard Adhesive (1923)	ROOM 1411	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
39 CAD #:	X0K	Miscellaneous Material Corkboard Adhesive (1923)	ROOM 1411	130 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
42 CAD #:	X0F	Miscellaneous Material Chalkboard Adhesive (1923)	ROOM 1415	30 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
43 CAD #:	X0K	Miscellaneous Material Corkboard Adhesive (1923)	ROOM 1415	130 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
46 CAD #:	X0F	Miscellaneous Material Chalkboard Adhesive (1923)	1923 ADDITION HALLWAY (1400)	2 Sq Ft	N	ASSUMED	5
Comments: NEAR CUSTODIAL OFFICE.					Sample #:		
47 CAD #:	X0K	Miscellaneous Material Corkboard Adhesive (1923)	1923 ADDITION HALLWAY (1400)	4 Sq Ft	N	ASSUMED	5
Comments: NEAR CUSTODIAL OFFICE.					Sample #:		
49 CAD #:	S0D	Wood Floor Felt / Vapor Barrier 1920 Addition (On-Grade)	GYMNASIUM (1203)	3000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
55 CAD #:	X0D	Miscellaneous Material Chalkboard Adhesive (1920)	ROOM 2210	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
56 CAD #:	X0K	Miscellaneous Material Corkboard Adhesive (1923)	ROOM 2210	50 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
58 CAD #:	X0D	Miscellaneous Material Chalkboard Adhesive (1920)	ROOM 2211	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
59 CAD #:	X0K	Miscellaneous Material Corkboard Adhesive (1923)	ROOM 2211	24 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
60 CAD #:	X0M	Miscellaneous Material Thin Metal Frame Corkboard Adhesive	ROOM 2211	24 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
63 CAD #:	X0D	Miscellaneous Material Chalkboard Adhesive (1920)	ROOM 2208	5 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
64 CAD #:	X0M	Miscellaneous Material Thin Metal Frame Corkboard Adhesive	ROOM 2208	24 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
65 CAD #:	X0Q	Miscellaneous Material Milkboard Adhesive	ROOM 2209	8 Sq Ft	N	ASSUMED	5
Comments: SLOP SINK					Sample #:		
72 CAD #:	X0N	Miscellaneous Material Metal Frame Chalkboard Adhesive	ROOM 2207	5 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
73 CAD #:	X0M	Miscellaneous Material Thin Metal Frame Corkboard Adhesive	ROOM 2207	30 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
74 CAD #:	X0R	Miscellaneous Material Wired Window Caulk	ROOM 2207	2 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
78 CAD #:	X0C	Miscellaneous Material Chalkboard Adhesive (1915)	ROOM 2206	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
79 CAD #:	X0O	Miscellaneous Material Corkboard Adhesive (1915)	ROOM 2206	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
80 CAD #:	X0M	Miscellaneous Material Thin Metal Frame Corkboard Adhesive	ROOM 2206	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
83 CAD #:	X0C	Miscellaneous Material Chalkboard Adhesive (1915)	ROOM 2204	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
84 CAD #:	X0O	Miscellaneous Material Corkboard Adhesive (1915)	ROOM 2204	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
85 CAD #:	X0M	Miscellaneous Material Thin Metal Frame Corkboard Adhesive	ROOM 2204	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
90 CAD #:	X0C	Miscellaneous Material Chalkboard Adhesive (1915)	ROOM 2202	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
91 CAD #:	X0O	Miscellaneous Material Corkboard Adhesive (1915)	ROOM 2202	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
92 CAD #:	X0M	Miscellaneous Material Thin Metal Frame Corkboard Adhesive	ROOM 2202	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
96 CAD #:	X0C	Miscellaneous Material Chalkboard Adhesive (1915)	ROOM 2005	5 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
97 CAD #:	X0O	Miscellaneous Material Corkboard Adhesive (1915)	ROOM 2005	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
99 CAD #:	X0M	Miscellaneous Material Thin Metal Frame Corkboard Adhesive	ROOM 2005	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
101 CAD #:	X1B	Miscellaneous Material 2" X 2" Gray with White Specks Ceramic Floor Tile System	ROOM 2006 RESTROOM	80 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
102 CAD #:	X1C	Miscellaneous Material 6" X 6" White with Light Green Accents Ceramic Wall Tile System	ROOM 2006 RESTROOM	190 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
106 CAD #:	X1C	Miscellaneous Material 6" X 6" White with Light Green Accents Ceramic Wall Tile System	ROOM 2004A RESTROOM	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
107 CAD #:	X1B	Miscellaneous Material 2" X 2" Gray with White Specks Ceramic Floor Tile System	ROOM 2004A RESTROOM	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
108 CAD #:	X0C	Miscellaneous Material Chalkboard Adhesive (1915)	ROOM 3100	20 Sq Ft	N	ASSUMED	5
Comments: ROOM ABOVE MAIN ENTRANCE					Sample #:		
125 CAD #:	X0O	Miscellaneous Material Corkboard Adhesive (1915)	ROOM 2312	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
128 CAD #:	X0M	Miscellaneous Material Thin Metal Frame Corkboard Adhesive	ROOM 2313	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
130 CAD #:	X0C	Miscellaneous Material Chalkboard Adhesive (1915)	ROOM 2315	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
131 CAD #:	X0O	Miscellaneous Material Corkboard Adhesive (1915)	ROOM 2315	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
139 CAD #:	X1A	Miscellaneous Material 4" X 4" White with Green or Beige Accents Ceramic Wall Tile System	BOYS' & GIRLS' RESTROOMS (2222 & 2224)	810 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
140 CAD #:	X1B	Miscellaneous Material 2" X 2" Gray with White Specks Ceramic Floor Tile System	BOYS' & GIRLS' RESTROOMS (2222 & 2224)	400 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
142 CAD #:	X1D	Miscellaneous Material 6" X 6" Tan Quarry Tile System	KITCHEN (2221)	670 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
156 CAD #:	X0D	Miscellaneous Material Chalkboard Adhesive (1920)	ROOM 2402	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
157 CAD #:	X0J	Miscellaneous Material Corkboard Adhesive (1920)	ROOM 2402	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
162 CAD #:	X0F	Miscellaneous Material Chalkboard Adhesive (1923)	1923 ADDITION HALLWAY (2400)	2 Sq Ft	N	ASSUMED	5
Comments: NEAR STAFF LOUNGE.					Sample #:		
163 CAD #:	X0K	Miscellaneous Material Corkboard Adhesive (1923)	1923 ADDITION HALLWAY (2400)	4 Sq Ft	N	ASSUMED	5
Comments: NEAR STAFF LOUNGE.					Sample #:		
167 CAD #:	X0F	Miscellaneous Material Chalkboard Adhesive (1923)	ROOM 2407	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
168 CAD #:	X0K	Miscellaneous Material Corkboard Adhesive (1923)	ROOM 2407	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
170 CAD #:	X0F	Miscellaneous Material Chalkboard Adhesive (1923)	ROOM 2409	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
171 CAD #:	X0K	Miscellaneous Material Corkboard Adhesive (1923)	ROOM 2409	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
172 CAD #:	X1A	Miscellaneous Material 4" X 4" White with Green or Beige Accents Ceramic Wall Tile System	RESTROOMS ACROSS FROM ROOM 2409	420 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
173 CAD #:	X1B	Miscellaneous Material 2" X 2" Gray with White Specks Ceramic Floor Tile System	RESTROOMS ACROSS FROM ROOM 2409	160 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
175 CAD #:	X0F	Miscellaneous Material Chalkboard Adhesive (1923)	ROOM 2411	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
176 CAD #:	X0K	Miscellaneous Material Corkboard Adhesive (1923)	ROOM 2411	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
178 CAD #:	X0F	Miscellaneous Material Chalkboard Adhesive (1923)	ROOM 2415	40 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
179 CAD #:	X0K	Miscellaneous Material Corkboard Adhesive (1923)	ROOM 2415	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
181 CAD #:	X0Q	Miscellaneous Material Milkboard Adhesive	MAINTENANCE STORAGE NEXT TO ROOM 2410	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		