

Chart B - Assessment of Asbestos-Containing Building Materials (ACBM)

All asbestos-containing events listed here are to be inspected during each six-month periodic surveillance for changes in condition. The Institute for Environmental assessment (IEA) highly recommends an in-depth "front end" inspection prior to any general renovation or remodeling to determine if those activities may disrupt building materials that may involve existing or undiscovered asbestos. Potentially inaccessible or exempt asbestos-containing materials not included in this plan may include: adhesives, caulking, putty, woven blankets, curtains, gloves and gaskets, electrical wiring insulation and heat shields above lights, paints and coatings, roofing felts, flashings and shingles, and mineral core fire doors.

Damaged materials which require corrective action to reduce a potential hazard are indicated on Chart A. All non-damaged ACBM identified in Chart B should be monitored through scheduled inspections and removed prior to renovation or demolition activities, or when their condition deteriorates.

District administration will direct another formal inspection by a federally-certified inspector within three (3) years, and will maintain an on-going file for each building. Specific recommendations on how to manage the different types of Asbestos-containing material are identified in the Asbestos Management Plan.

PLEASE NOTE: Based on EPA recommendations, materials analyzed utilizing PLM and found to contain between 0% and 10% should be assumed asbestos containing unless building owner wishes the laboratory to utilize "point counting." For samples analyzed prior to 1994 containing 1% or less (trace) of asbestos, resampling utilizing the 1993 EPA Test Method or point counting is strongly recommended for purposes of demolition or renovation before treating these materials as non-asbestos containing. Contact your local IEA office for questions or additional information.

EPA ASSESSMENT CATEGORIES:		1 = Damaged or significantly damaged TSI ACM 2 = Damaged friable surfacing ACM 3 = Significantly damaged friable surfacing ACM 4 = Damaged or significantly damaged friable miscellaneous ACM		5 = ACBM with potential for damage 6 = ACBM with potential for significant damage 7 = Remaining friable ACBM or friable suspect ACBM			
IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assessment Category
6 CAD #:	S0A	Wood Floor Felt / Vapor Barrier 1930 Original Building	THROUGHOUT 1930 ORIGINAL BUILDING	5000 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
10 CAD #:	X0E	Miscellaneous Material Thick, Black Tar	ELECTRICAL ROOM 0009	1 Sq Ft	N	60 CH	5
Comments: ON PERIMETER OF LARGE EXHAUST-TYPE PENETRATION. COVERED WITH CP11.					Sample #: 120909MV-8		
12 CAD #:	E1B	Stack Gasket Boiler #2	1974 ADDITION BOILER ROOM (0002)	2 Sq Ft	N	65 CH	5
Comments: TWO (2) GASKETS.					Sample #: 120909MV-2		
13 CAD #:	D2A	Interior Boiler Insulation Boiler #2	1974 ADDITION BOILER ROOM (0002)	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
14 CAD #:	D2B	Interior Boiler Insulation Boiler #1	1974 ADDITION BOILER ROOM (0002)	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
17 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic Light Beige w/Brown Streaks	ROOM 0001	700 Sq Ft	N	5 CH (TILE), 10 CH (MASTIC)	5
Comments: ENTRANCE FROM BOILER ROOM OR ACROSS HALL FROM MAIN OFFICE. TILE MISSING BY BOILER ROOM ENTRANCE WITH EXPOSED MASTIC. TILES LOOSE IN CENTER.					Sample #: 120909MV-11		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
19 CAD #:	X0J	Miscellaneous Material Metal Frame Chalkboard Adhesive (1974)	ROOM 0001	5 Sq Ft	N	ASSUMED	5
Comments: ONE (1) BOARD.					Sample #:		
20 CAD #:	K0B	9" x 9" Vinyl Floor Tile & Mastic Dark Brown	1930 ORIGINAL BUILDING 1ST FLOOR HALLWAY	350 Sq Ft	N	5 CH (TILE & MASTIC)	5
Comments: ASSUMED UNDER CARPET.					Sample #: 2001-1501-M8		
21 CAD #:	K0C	9" x 9" Vinyl Floor Tile & Mastic Light Brown	1930 ORIGINAL BUILDING 1ST FLOOR HALLWAY	350 Sq Ft	N	5 CH (TILE & MASTIC)	5
Comments: ASSUMED UNDER CARPET.					Sample #: 2001-1501-M9		
22 CAD #:	K3A	Miscellaneous Flooring 10" x 20" Dark Brown Tile	1930 ORIGINAL BUILDING 1ST FLOOR HALLWAY	115 Sq Ft	N	5 CH (TILE & MASTIC)	5
Comments: ASSUMED UNDER CARPET.					Sample #: 541-23		
27 CAD #:	V0C	Sink Undercoating Pink	NURSE'S OFFICE ROOM 1006	4 Sq Ft	N	12 CH	5
Comments: ONE (1) SINK.					Sample #:		
31 CAD #:	X1B	Miscellaneous Material Multi Sized Brown Ceramic Floor Tile System	NURSE'S OFFICE RESTROOM 1006B	30 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
36 CAD #:	X1C	Miscellaneous Material 6" X 6" Maroon Quarry Floor Tile System	STAIRWELL 1099B	150 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
37 CAD #:	X0G	Miscellaneous Material Wood Frame Corkboard Adhesive (1930)	STAIRWELL 1099E	8 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
38 CAD #:	V0A	Sink Undercoating Black	STAFF LOUNGE (1014)	4 Sq Ft	N	3-5 CH	5
Comments: ONE (1) SINK.					Sample #: 120909MV-9		
41 CAD #:	V0C	Sink Undercoating Pink	MAIN OFFICE COPY ROOM 1002	4 Sq Ft	N	12 CH	5
Comments: ONE (1) SINK.					Sample #: 120909MV-14		
44 CAD #:	X1C	Miscellaneous Material 6" X 6" Maroon Quarry Floor Tile System	1930 ORIGINAL BUILDING STAIRWELL 1099A	150 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
47 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 2011 (STORAGE)	30 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments:					Sample #:		
51 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 2007	1000 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: NEAR SINK. CHIPPED PIECE UNDER SINK. UNDER CARPET					Sample #:		
53 CAD #:	X0F	Miscellaneous Material Wood Frame Chalkboard Adhesive (1930)	ROOM 2007	20 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
54 CAD #:	X0G	Miscellaneous Material Wood Frame Corkboard Adhesive (1930)	ROOM 2007	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
55 CAD #:	K0G	9" x 9" Vinyl Floor Tile & Mastic Red	ROOM 2006	50 Sq Ft	N	5-6 CH (TILE)	5
Comments: UNDER CARPET & 12" TILE.					Sample #:		
56 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 2006	50 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: UNDER CARPET.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
57 CAD #:	K0G	9" x 9" Vinyl Floor Tile & Mastic Red	ROOM 2009	100 Sq Ft	N	5-6 CH (TILE)	5
Comments: UNDER CARPET & 12" TILE.					Sample #:		
58 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 2009	100 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: UNDER CARPET.					Sample #:		
59 CAD #:	K0G	9" x 9" Vinyl Floor Tile & Mastic Red	ROOM 2008 CLOSET	120 Sq Ft	N	5-6 CH (TILE)	5
Comments: UNDER CARPET.					Sample #:	120909MV-19;2001-1901-PL-01	
63 CAD #:	X0G	Miscellaneous Material Wood Frame Corkboard Adhesive (1930)	ROOM 2003	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
66 CAD #:	X0G	Miscellaneous Material Wood Frame Corkboard Adhesive (1930)	ROOM 2004	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
70 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 2002	1000 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: MOSTLY CARPETED. VISIBLE UNDER SINK.					Sample #:		
72 CAD #:	X0G	Miscellaneous Material Wood Frame Corkboard Adhesive (1930)	ROOM 2002	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
76 CAD #:	X0G	Miscellaneous Material Wood Frame Corkboard Adhesive (1930)	ROOM 2001	100 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
81 CAD #:	X0A	Miscellaneous Material Wired Window Glaze Compound	THROUGHOUT 1974 ADDITION	100 Sq Ft	N	5 CH	5
Comments:					Sample #:	120909MV-38	
84 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	1974 ADDITION 1ST FLOOR ELEVATOR LOBBY	180 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: CHIPPED AT ENTRY DOOR 6.					Sample #:		
85 CAD #:	X1C	Miscellaneous Material 6" X 6" Maroon Quarry Floor Tile System	ENTRANCE 1000A AND RAMP	500 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
86 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	MAIN HALLWAY 1100 (FROM MAIN OFFICE TO ROOM 1113)	1100 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: MULTIPLE CHIPPED TILES.					Sample #:		
89 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	GYMNASIUM ENTRY	330 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: SLIGHT CHIPPING SEALED WITH WAX.					Sample #:		
93 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	GYMNASIUM STORAGE (1102A)	130 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments:					Sample #:		
95 CAD #:	K2E	12" x 12" Vinyl Floor Tile & Mastic White & Tan	GYMNASIUM STORAGE	35 Sq Ft	N	5 CH (TILE), 10 CH (MASTIC)	5
Comments: OLD DIVIDER WALL STORAGE.					Sample #:		
97 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	GYMNASIUM STORAGE (1102B)	260 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments:					Sample #:		
98 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	PHY ED OFFICE 1104	100 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: TILE WEAR UNDER TEACHER'S DESK. RECOMMEND CHAIR MAT. SEALED WITH WAX.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
99 CAD #:	X0M	Miscellaneous Material Metal Frame Corkboard Adhesive (1974)	PHY ED OFFICE 1104	16 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
101 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	CUSTODIAL CLOSET 1105	25 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: SEVERAL TILES MISSING WITH EXPOSED MASTIC. MOISTURE DAMAGE ON REMAINING TILES. MASTIC IS DEGRADING FROM WATER DAMAGE. TILE DEBRIS FOUND. RECOMMEND REMOVAL.					Sample #:		
102 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1106 (ELECTRICAL)	35 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments:					Sample #:		
103 CAD #:	X0M	Miscellaneous Material Metal Frame Corkboard Adhesive (1974)	MUSIC ROOM (1107)	30 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
104 CAD #:	X0J	Miscellaneous Material Metal Frame Chalkboard Adhesive (1974)	MUSIC ROOM (1107)	10 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
105 CAD #:	X0M	Miscellaneous Material Metal Frame Corkboard Adhesive (1974)	CAFETERIA	50 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
113 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1112	200 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: SMALL CHIP IN SOUTHWEST CORNER.					Sample #:		
114 CAD #:	V0C	Sink Undercoating Pink	ROOM 1112	5 Sq Ft	N	12 CH	5
Comments: ONE (1) SINK.					Sample #:		
115 CAD #:	X0M	Miscellaneous Material Metal Frame Corkboard Adhesive (1974)	ROOM 1112	16 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
116 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	HALLWAY 1500	540 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments:					Sample #:		
117 CAD #:	X1B	Miscellaneous Material Multi Sized Brown Ceramic Floor Tile System	GIRLS' RESTROOM (1501)	180 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
118 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	CUSTODIAL CLOSET 1507 (J2 ON MAP)	50 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: MOISTURE DAMAGE, RECOMMEND SEALING WITH WAX.					Sample #:		
122 CAD #:	X0I	Miscellaneous Material AHU Seam Caulk	WEST ROOF FAN ROOM OFF CUSTODIAL CLOSET 1507	10 Sq Ft	N	3 CH	5
Comments:					Sample #: 120909MV-37		
128 CAD #:	X1B	Miscellaneous Material Multi Sized Brown Ceramic Floor Tile System	BOYS' RESTROOM (1506)	180 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
129 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	HALLWAY 1400	1600 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments:					Sample #:		
131 CAD #:	V0A	Sink Undercoating Black	ROOM 1405	5 Sq Ft	N	3-5 CH	5
Comments: ONE (1) SINK.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
134 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1401	15 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: NEAR SINK. TILES BEGINNING TO COME LOOSE, MONITOR.					Sample #:		
135 CAD #:	V0A	Sink Undercoating Black	ROOM 1401	5 Sq Ft	N	3-5 CH	5
Comments: ONE (1) SINK.					Sample #:		
136 CAD #:	X0J	Miscellaneous Material Metal Frame Chalkboard Adhesive (1974)	ROOM 1401	15 Sq Ft	N	ASSUMED	5
Comments: EAST WALL					Sample #:		
138 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1402	15 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: NEAR SINK.					Sample #:		
139 CAD #:	V0A	Sink Undercoating Black	ROOM 1402	5 Sq Ft	N	3-5 CH	5
Comments: ONE (1) SINK.					Sample #:		
140 CAD #:	X0J	Miscellaneous Material Metal Frame Chalkboard Adhesive (1974)	ROOM 1402	15 Sq Ft	N	ASSUMED	5
Comments: BEHIND WHITEBOARD. SOUTH WALL					Sample #:		
142 CAD #:	X0J	Miscellaneous Material Metal Frame Chalkboard Adhesive (1974)	ROOM 1403	15 Sq Ft	N	ASSUMED	5
Comments: SOUTH WALL					Sample #:		
144 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1403A	25 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: NEAR SINK.					Sample #:		
145 CAD #:	V0A	Sink Undercoating Black	ROOM 1403A	5 Sq Ft	N	3-5 CH	5
Comments: ONE (1) SINK.					Sample #:		
148 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1404A	25 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: NEAR SINK.					Sample #:		
149 CAD #:	V0A	Sink Undercoating Black	ROOM 1404A	5 Sq Ft	N	3-5 CH	5
Comments: ONE (1) SINK.					Sample #:		
150 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1408	40 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: 1/2 TILE MISSING.					Sample #:		
155 CAD #:	X0J	Miscellaneous Material Metal Frame Chalkboard Adhesive (1974)	ROOM 1410	15 Sq Ft	N	ASSUMED	5
Comments: BEHIND WHITEBOARD. SOUTH WALL					Sample #:		
157 CAD #:	X0J	Miscellaneous Material Metal Frame Chalkboard Adhesive (1974)	ROOM 1411	15 Sq Ft	N	ASSUMED	5
Comments: BEHIND WHITEBOARD. SOUTH WALL					Sample #:		
158 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1411A	25 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: NEAR SINK.					Sample #:		
160 CAD #:	V0A	Sink Undercoating Black	ROOM 1411A	5 Sq Ft	N	3-5 CH	5
Comments: ONE (1) SINK.					Sample #:		
162 CAD #:	X0J	Miscellaneous Material Metal Frame Chalkboard Adhesive (1974)	ROOM 1412	15 Sq Ft	N	ASSUMED	5
Comments: WEST WALL					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
163 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1412A	25 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: TILES STARTING TO COME LOOSE. MONITOR.					Sample #:		
165 CAD #:	V0A	Sink Undercoating Black	ROOM 1412A	5 Sq Ft	N	3-5 CH	5
Comments: ONE (1) SINK.					Sample #:	120909MV-46	
170 CAD #:	X0J	Miscellaneous Material Metal Frame Chalkboard Adhesive (1974)	ROOM 1416	15 Sq Ft	N	ASSUMED	5
Comments: BEHIND WHITEBOARD. SOUTH WALL					Sample #:		
172 CAD #:	X0J	Miscellaneous Material Metal Frame Chalkboard Adhesive (1974)	ROOM 1417	15 Sq Ft	N	ASSUMED	5
Comments: SOUTH WALL					Sample #:		
173 CAD #:	V0A	Sink Undercoating Black	ROOM 1417	5 Sq Ft	N	3-5 CH	5
Comments: ONE (1) SINK.					Sample #:		
174 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1417	15 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: NEAR SINK.					Sample #:		
176 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1418	15 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: LARGE PIECES MISSING, MASTIC EXPOSED. SEVERAL LOOSE TILES.					Sample #:		
177 CAD #:	V0A	Sink Undercoating Black	ROOM 1418	5 Sq Ft	N	3-5 CH	5
Comments: ONE (1) SINK.					Sample #:		
178 CAD #:	X0J	Miscellaneous Material Metal Frame Chalkboard Adhesive (1974)	ROOM 1418	15 Sq Ft	N	ASSUMED	5
Comments: WEST WALL					Sample #:		
179 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	HALLWAY 1400A	700 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments:					Sample #:		
180 CAD #:	X1B	Miscellaneous Material Multi Sized Brown Ceramic Floor Tile System	GIRLS' RESTROOM BY ROOM 1419	180 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
182 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1419 CUSTODIAL	20 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: ONLY MASTIC REMAINS. MASTIC IS WEARING AWAY.					Sample #:		
183 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	HALLWAY 1300	760 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments:					Sample #:		
186 CAD #:	V0A	Sink Undercoating Black	ROOM 1303	5 Sq Ft	N	3-5 CH	5
Comments: ONE (1) SINK.					Sample #:		
187 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1303A STORAGE	30 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: TILES STARTING TO COME LOOSE AT PERIMETER OF ROOM. MONITOR.					Sample #:		
188 CAD #:	X1B	Miscellaneous Material Multi Sized Brown Ceramic Floor Tile System	ROOM 1303B RESTROOM	30 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
196 CAD #:	V0A	Sink Undercoating Black	ROOM 1301	5 Sq Ft	N	3-5 CH	5
Comments: ONE (1) SINK.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
197 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1301B STORAGE	35 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments:					Sample #: 061108-BF-1		
198 CAD #:	X1B	Miscellaneous Material Multi Sized Brown Ceramic Floor Tile System	ROOM 1301A RESTROOM	35 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
201 CAD #:	V0A	Sink Undercoating Black	ROOM 1304	5 Sq Ft	N	3-5 CH	5
Comments: ONE (1) SINK.					Sample #:		
202 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1304A STORAGE (1302A)	30 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: TILES STARTING TO BECOME LOOSE. MONITOR.					Sample #:		
203 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	HALLWAY 1200B	700 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: CRACKING OUTSIDE ROOM 1223 W/FOUR (4) PIECES OF TILE MISSING.					Sample #:		
204 CAD #:	X1B	Miscellaneous Material Multi Sized Brown Ceramic Floor Tile System	ROOM 1304B RESTROOM	30 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
205 CAD #:	X1B	Miscellaneous Material Multi Sized Brown Ceramic Floor Tile System	BOYS' RESTROOM (1224)	180 Sq Ft	N	ASSUMED	5
Comments:					Sample #:		
207 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1223	15 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: NEAR SINK.					Sample #:		
208 CAD #:	V0A	Sink Undercoating Black	ROOM 1223	5 Sq Ft	N	3-5 CH	5
Comments: ONE (1) SINK.					Sample #:		
210 CAD #:	X0J	Miscellaneous Material Metal Frame Chalkboard Adhesive (1974)	ROOM 1222	15 Sq Ft	N	ASSUMED	5
Comments: BEHIND WHITEBOARDS.					Sample #:		
211 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1222	15 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: NEAR SINK.					Sample #:		
212 CAD #:	V0A	Sink Undercoating Black	ROOM 1222	5 Sq Ft	N	3-5 CH	5
Comments: ONE (1) SINK.					Sample #:		
215 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1200D	35 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: TILE WEAR AT DOOR.					Sample #:		
217 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	HALLWAY 1200	1160 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: PIECE OF TILE MISSING OUTSIDE 1200D.					Sample #:		
223 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1219A	25 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: NEAR SINK. 1/2 TILE MISSING AT SINK.					Sample #:		
224 CAD #:	V0A	Sink Undercoating Black	ROOM 1219A	5 Sq Ft	N	3-5 CH	5
Comments: ONE (1) SINK.					Sample #:		
227 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1218A	25 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: NEAR SINK.					Sample #:		

IEA Event No.	Material Type	Material Description/Id	Location	Estimated Amount Total	Friability	% of Asbestos	EPA Assess Category
228 CAD #:	V0A	Sink Undercoating Black	ROOM 1218A	5 Sq Ft	N	3-5 CH	5
Comments: ONE (1) SINK.					Sample #:		
230 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1217	15 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: NEAR SINK.					Sample #:		
231 CAD #:	V0A	Sink Undercoating Black	ROOM 1217	5 Sq Ft	N	3-5 CH	5
Comments: ONE (1) SINK.					Sample #:		
233 CAD #:	K2A	12" x 12" Vinyl Floor Tile & Mastic Beige w/Brown & White Smudges	ROOM 1216	10 Sq Ft	N	3 CH (TILE), 8 CH (MASTIC)	5
Comments: NEAR SINK.					Sample #:		
234 CAD #:	V0A	Sink Undercoating Black	ROOM 1216	5 Sq Ft	N	3-5 CH	5
Comments: ONE (1) SINK.					Sample #:		
235 CAD #:	X0J	Miscellaneous Material Metal Frame Chalkboard Adhesive (1974)	ROOM 1216	15 Sq Ft	N	ASSUMED	5
Comments: EAST WALL					Sample #:		