


INSPECTION CERTIFICATION for Saint Paul Public Schools -- Wheelock Early Education

STATEMENT OF BUILDING ACCESS

On behalf of Saint Paul Public Schools for Wheelock Early Education , I certify that I have provided access to all areas within the building to IEA's inspector identified below for the purpose of inspecting for asbestos-containing building materials (ACBM) as mandated by 40 CFR 763.85, "Inspections and Reinspections."

Additionally, I have discussed any concerns I have regarding identified or non-identified ACBM within this building.




Signature

8 / 8 / 2024

Date of Inspection

INSPECTOR

As mandated by 40 CFR 763.85, "Inspections and Reinspections," I certify that I have inspected all accessible areas in Wheelock Early Education for the purpose of identifying and assessing asbestos-containing building materials. I have completed an EPA-approved course and all appropriate refresher courses and am an accredited AHERA Inspector. A copy of my certification/accreditation is attached.



Signature
Grant Gervais

Print Name

8 / 8 / 2024

Date of Inspection
AI 15101

State Certification/Accreditation Number

MANAGEMENT PLANNER

I certify that I have reviewed all of the inspection data for Wheelock Early Education and have appropriately provided assessments and response actions for identified asbestos-containing building materials. I have completed an EPA-approved course and all appropriate refresher courses and am an accredited AHERA Management Planner. A copy of my certification/accreditation is attached.



Signature
Matt Lindberg

Print Name

10/10/2024

Date of Review
Am 3626

State Certification/Accreditation Number

Inspector State Certification/Accreditation



m ASBESTOS
DEPARTMENT OF HEALTH INSPECTOR

Certified by:
State of Minnesota
Department of Health
Expires: 05/16/2025

Grant O. Gervais
1031 13th Ave Se
Minneapolis, MN 55414

SPH

Director, Env. Health Div.

No. AI15101

Issued: 06/06/2024

Inspector State Certification/Accreditation



m ASBESTOS
DEPARTMENT OF HEALTH INSPECTOR

Certified by:
State of Minnesota
Department of Health
Expires: 10/26/2024

Brenda K Fischer
15937 Vale St NW
Andover, MN 55304

SPH

Director, Env. Health Div.

No. AI2296

Issued: 11/09/2023

Management Planner State Certification/Accreditation



m ASBESTOS
DEPARTMENT OF HEALTH MANAGEMENT
PLANNER

Certified by:
State of Minnesota
Department of Health
Expires: 08/02/2025

Matt A Lindberg
11816 Ghia St NE
Blaine, MN 55449

SPH

Director, Env. Health Div.

No. AM3896

Issued: 08/20/2024

Chart A - Immediate Response Situations

The following is a list of those events that contain damaged asbestos material and should be considered to be potential hazards. It is imperative that the following immediate response situations are corrected as soon as possible but no later than six months from the date of this inspection to avoid increased risk of exposure to airborne asbestos fibers. The district should take extra precaution to ensure that properly trained personnel use appropriate techniques to implement these responses.

Following is an explanation of the immediate Response Action codes identified in this report.

EPA ASSESSMENT CATEGORY				RESPONSE ACTION			
1 = Damaged or significantly damaged TSI ACM.				A = Cleanup ACM debris.			
2 = Damaged friable surfacing ACM.				B = Encapsulate slight damage on TSI.			
3 = Significantly damaged friable surfacing ACM.				C = Patch TSI and/or repair ACM cover.			
4 = Damaged or significantly damaged friable miscellaneous ACM.				D = Enclose or protect accessible sections with protective barrier.			
5 = ACBM with potential for damage.				E = Remove section of damaged ACM.			
6 = ACBM with potential for significant damage.				F = Remove ACM and replace with non-ACM.			
7 = Remaining friable ACBM or friable suspected ACBM.				G = Isolate area until repaired/removed.			
				H = Encapsulate slight damage.			
				I = Remove and replace damaged or loose tile section.			
				J = Monitor condition of material(s).			

IEA Event No.	Material Type	Material Id/Desc	Location	Estimated Amount Total	Estimated Amount of Damage	EPA Assess.	Immediate Response Action	Comments
14 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic White w/Light Streaks	THROUGHOUT MAIN OFFICE 1001	1500 Sq Ft	3 Sq Ft	5	D	INCLUDES ROOMS 1002-1006. WEARING UNDER RECEPTIONIST'S DESK & NURSE'S OFFICE & PRINCIPAL'S OFFICE. RECOMMEND CHAIR MATS. CHIPPED AT DOOR 1000B.
37 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic White w/Light Streaks	ROOM 1203	1200 Sq Ft	2 Sq Ft	5	I	SLIGHT WEARING NEAR ENTRANCE. SEVERAL TILES LOOSE NEAR WEST WHITEBOARD. RAISED CRACK FLOOR CAUSING A ROW OF TILES TO LIFT BY WHITEBOARD, 3 HAVE BEEN REPLACED. MONITOR.
46 CAD #:	K0A	9" x 9" Vinyl Floor Tile & Mastic White w/Light Streaks	ROOM 1206	1200 Sq Ft	2 Sq Ft	5	I	SLIGHT WEARING NEAR ENTRANCE. SOME TILES LOOSE NEAR EXTERIOR ENTRANCE. INCLUDES REPLACEMENT TILES AT EXTERIOR ENTRANCE.