


William Paca Middle School



January 14, 2025



William Paca Middle School

Item #	Description	Comments
55	Pavements	All parking lots
56	Sidewalks	Partial sidewalk & curb include extend ADA to/from music exit doors
66	Exterior Walls/Columns	Extended EIF repairs around 2002 addition
69	Exterior Doors	Multiple exterior doors/hardware, Harden all exter. door visions/sidelights
70	Exterior Steps, Stairs, Ramps	Provide handicapped ramp or place of refuge at exit from cafeteria
72	Windows	Window replacements aux. gym, corridor, replace lower porcelein panels
73	Roof and Skylights	Replace entire roof
76	Carpet	Remove/replace w/VCT in storage room
78	Hard Flooring	Epoxy flooring in corridor
80	Ceilings	Replace all old sagging ceiling tile/grid
82	Interior Doors	DW replacement all classrooms, office, assembly places off corridor
88	Ventilation System	7 original RTUs need to be replaced
90	Piped Heating & Cooling Dist. Sys.	Boiler room piping and insulation
92	HVAC Control Systems	Replace obsolete controllers, upgrade remaining pneumatics/exhaust fans
97	Plumbing Fixtures	Reno all multi & single stall bathrooms/any locker room bathrooms
104	Emergency or standby power system	Replace existing generator
107	Communication Systems	Review and Upgrade

Interior doors are mentioned throughout the report.
A districtwide interior door project was approved by
NYSED Facilities Management on 12/5/2024.

Paca Middle School – Proposed Projects

- Redesign and construction of main entrance
- Addition of security office at main entrance
- Expansion and upgrades to existing STEM classrooms, 21st century
- Addition of ADA-compliant restrooms
- Renovation of library to include new indoor/outdoor classroom utilizing courtyard, new technology and casework throughout


Paca Middle School



January 14, 2025



Paca Middle School



Paca Middle School - Library

