




Moriches Elementary School



Moriches Elementary School

Item #	Description	Comments
43	Site Electrical	Replacement of existing primary to transformer
55	Pavements	Replacement of multiple locations - main lots and roundways
56	Sidewalks	Replacement of partial sidewalk/curbing multiple locations
69	Exterior Doors	Replace door/frame from pump room/harden all glass/sidelights
72	Windows	Replacement of double hung windows in 1993 wing
73	Roof and Skylights	Install roof access to lower roofs via fan room
75	Other Interior Walls	Further discussion required partitions vs. permanent walls
77	Resilient Tiles or Sheet Flooring	Recommend VCT flooring throughout new addition
80	Ceilings	Replacement of old ceiling 1993 wing/Led Lighting reinstalled
82	Interior Doors	DW replacement classrooms, office & assembly places off corridor
88	Ventilation System	Replace 8 RTUs in 1992 wing and all UVs in 1993 wing
92	HVAC Control Systems	Replace obsolete controls/upgrade remaining equipment to DDC
93	Water Supply System	Replace hot water mixing valves
97	Plumbing Fixtures	Replace all bathrooms original to building
107	Communication Systems	Recommend full replacement of entire system

Elementary Libraries



January 14, 2025

