

1. Overhead Coiling Doors
 - a. 2.02, A, 8 and 2.03, E, 4 are stating the doors are to be operated with a manual chain hoist. Many of the details in the drawings appear to indicate the doors are hand crank operated instead. There are some additional costs to the hand crank operation. Could you confirm which method of operation is needed for the overhead coiling doors?

Please provide the chain hoist operated coiling doors.
-ZC, 2/11/25

2. Prefinished Metal Fascia and Soffit Panels
 - a. Specifications?

Please refer to the updated spec section in addendum 1. Please refer to the updated 07 41 13 - Metal Roof Panels specification in addendum 1.
-ZC, 2/11/25

3. Roof Panels
 - a. Widths?

Roof panel widths should be 16". Please refer to the updated 07 41 13 - Metal Roof Panels specification in addendum 1.
-ZC, 2/11/25