Lead in School Drinking Water Report

Cherrydale Primary School

EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per RCW 28A.210.410 sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

RCW 28A.210.410 does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing Location	Room/space where fixture is located (i.e. room number, gym, playground)
Fixture Housing Type	Structure that contains the individual fixtures where water samples were collected from. Fixture housing may contain one or more individual fixture for sampling.
Fixture Location Details	Location within a room or space where fixture housing is located, starting to the left of the entrance and rotating clockwise, of the total number of fixture housings in a room or space (e.g. 1/5, 2/5)
Fixture Type	Tap, Sprayer, Water Fountain, Water Bottle Filler, Icemaker
Fixture Position	Left, Center, Right

Date(s) collected: 2024-10-25
Date(s) analyzed: 2024-11-19, 2024-11-20

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	400953	Main Building	Sink	Room 15	1 of 1	Tap	center	16
2	400866	Main Building	Fountain/Tap Combo	Room S1	1 of 1	Tap	center	10
3	400868	Main Building	Sink	Room S2	1 of 2	Tap	center	9
4	400952	Main Building	Sink	Music Room	1 of 1	Tap	center	9
5	400860	Main Building	Sink	Nurses Office	1 of 1	Tap	center	8
6	400944	Main Building	Sink	Kitchen	1 of 3	Tap	center	7
7	400957	Main Building	Sink	Speech Room B112a	1 of 1	Tap	center	7
8	400955	Main Building	Fountain/Tap Combo	Room 14	1 of 1	Water Fountain	left	6
9	400967	Main Building	Fountain/Tap Combo	Room 10	1 of 1	Water Fountain	left	6
10	400869	Main Building	Sink	Room S2	2 of 2. Kitchen in connecting room	Tap	center	5
11	400956	Main Building	Fountain	Hallway Across From Room 14	1 of 1	Water Fountain	right	5

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
12	400973	Main Building	Fountain/Tap Combo	Room 6	1 of 1	Water Fountain	right	5
13	400862	Main Building	Fountain/Tap Combo	Room 3	1 of 1	Water Fountain	center	4
14	400865	Main Building	Fountain/Tap Combo	Room 1	1 of 1	Water Fountain	right	4
15	400945	Main Building	Sink - Multi-Compartment	Kitchen	2 of 3	Tap	left	4
16	400946	Main Building	Sink - Multi-Compartment	Kitchen	2 of 3	Tap	right	4
17	400949	Main Building	Sink	Room 16	1 of 1	Tap	center	4
18	400959	Main Building	Fountain/Tap Combo	Room 13	1 of 1	Water Fountain	right	4
19	400961	Main Building	Fountain/Tap Combo	Room 12	1 of 1	Water Fountain	left	4
20	400978	Main Building	Fountain/Tap Combo	Room 4	1 of 1	Tap	center	4
21	400870	Main Building	Sink	Office C118	1 of 1	Tap	center	3
22	400872	Main Building	Fountain/Tap Combo	Room S3	1 of 1	Water Fountain	left	3
23	400861	Main Building	Fountain/Tap Combo	Room 3	1 of 1	Tap	center	2

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
24	400948	Main Building	Sink	Staff Room	1 of 1	Tap	center	2
25	400954	Main Building	Fountain/Tap Combo	Room 14	1 of 1	Tap	center	2
26	400963	Main Building	Fountain/Tap Combo	Room 9	1 of 1	Water Fountain	left	2
27	400965	Main Building	Fountain/Tap Combo	Room 11	1 of 1	Water Fountain	right	2
28	400969	Main Building	Fountain/Tap Combo	Room 7	1 of 1	Water Fountain	left	2
29	400971	Main Building	Fountain/Tap Combo	Room 8	1 of 1	Water Fountain	right	2
30	400979	Main Building	Fountain/Tap Combo	Room 4	1 of 1	Water Fountain	right	2
31	400867	Main Building	Fountain/Tap Combo	Room S1	1 of 1	Water Fountain	left	1
32	400871	Main Building	Fountain/Tap Combo	Room S3	1 of 1	Tap	center	1
33	400947	Main Building	Sink	Kitchen	3 of 3	Sprayer	center	1
34	400958	Main Building	Fountain/Tap Combo	Room 13	1 of 1	Tap	center	1
35	400966	Main Building	Fountain/Tap Combo	Room 10	1 of 1	Tap	center	1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
36	400863	Main Building	Sink	Room 2	1 of 1	Tap	center	<1
37	400864	Main Building	Fountain/Tap Combo	Room 1	1 of 1	Tap	center	<1
38	400950	Main Building	Fountain with Bottle Filler	Multi Purpose Room	1 of 1	Water Bottle Filler	center	<1
39	400951	Main Building	Fountain with Bottle Filler	Multi Purpose Room	1 of 1	Water Fountain	right	<1
40	400960	Main Building	Fountain/Tap Combo	Room 12	1 of 1	Tap	center	<1
41	400962	Main Building	Fountain/Tap Combo	Room 9	1 of 1	Tap	center	<1
42	400964	Main Building	Fountain/Tap Combo	Room 11	1 of 1	Tap	center	<1
43	400968	Main Building	Fountain/Tap Combo	Room 7	1 of 1	Tap	center	<1
44	400970	Main Building	Fountain/Tap Combo	Room 8	1 of 1	Tap	center	<1
45	400972	Main Building	Fountain/Tap Combo	Room 6	1 of 1	Tap	center	<1
46	400974	Main Building	Sink	Room 5	1 of 1	Tap	center	<1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
47	400975	Main Building	Fountain - Multi-Level with Bottle Filler	Hallway Across From Room 4	1 of 1. Higher fountain.	Water Fountain	right	<1
48	400976	Main Building	Fountain - Multi-Level with Bottle Filler	Hallway Across From Room 4	1 of 1	Water Bottle Filler	right	<1
49	400977	Main Building	Fountain - Multi-Level with Bottle Filler	Hallway Across From Room 4	1 of 1. Lower fountain	Water Fountain	right	<1