

# Lead in School Drinking Water Report

## Steilacoom High School



Date(s) collected: 2024-02-24

Date(s) analyzed: 2024-03-13, 2024-03-19

| Sample ID | Building Name | Fixture Housing Type        | Fixture Location         | Fixture Location Details | Fixture Type        | Lead Test Result (ppb) |
|-----------|---------------|-----------------------------|--------------------------|--------------------------|---------------------|------------------------|
| 377962    | Main Building | Pot Filler                  | Kitchen                  | 4 of 4                   | Other               | 63                     |
| 377967    | Main Building | Fountain with Bottle Filler | Next To Room 210         | 1 of 1                   | Water Bottle Filler | 36                     |
| 377467    | Main Building | Sink                        | Room 108                 | 3 of 7                   | Tap                 | 27                     |
| 377473    | Main Building | Sink                        | Health Exam Room         | 1 of 1                   | Tap                 | 13                     |
| 378041    | Main Building | Fountain                    | Hallway Next To Room 114 | 1 of 1                   | Water Fountain      | 13                     |
| 377976    | Main Building | Fountain - Multi-Level      | Athletic Training Room   | 1 of 1                   | Water Fountain      | 7                      |
| 377474    | Main          | Sink                        | Nurses                   | 1 of 1                   | Tap                 | 6                      |

| Sample ID | Building Name | Fixture Housing Type                      | Fixture Location                | Fixture Location Details   | Fixture Type        | Lead Test Result (ppb) |
|-----------|---------------|-------------------------------------------|---------------------------------|----------------------------|---------------------|------------------------|
|           | Building      |                                           | Office                          |                            |                     |                        |
| 377478    | Main Building | Sink                                      | Kitchen                         | 2 of 4                     | Tap                 | 5                      |
| 377961    | Main Building | Sink - Multi-Compartment                  | Kitchen                         | 3 of 4                     | Tap                 | 5                      |
| 377472    | Main Building | Sink - Multi-Compartment                  | Sentinel Outpost. Student Store | 1 of 1                     | Sprayer             | 3                      |
| 377975    | Main Building | Fountain - Multi-Level                    | Athletic Training Room          | 1 of 1. Higher fountain    | Water Fountain      | 3                      |
| 377977    | Main Building | Sink                                      | Staff Room                      | 1 of 1                     | Tap                 | 3                      |
| 377477    | Main Building | Sink - Multi-Compartment                  | Kitchen                         | 1 of 4                     | Tap                 | 2                      |
| 378040    | Press Box     | Other                                     | Next To Bleachers               | 1 of 1                     | Tap                 | 2                      |
| 377465    | Main Building | Sink                                      | Room 108                        | 1 of 7. Station 1          | Tap                 | 1                      |
| 377471    | Main Building | Sink                                      | Room 108                        | 7 of 7. Demonstration sink | Tap                 | 1                      |
| 377462    | Main Building | Fountain - Multi-Level with Bottle Filler | Main Entrance Fountain          | 1 of 1. Higher fountain    | Water Fountain      | <1                     |
| 377463    | Main Building | Fountain - Multi-Level with Bottle Filler | Main Entrance Fountain          | 1 of 1                     | Water Bottle Filler | <1                     |
| 377464    | Main Building | Fountain - Multi-Level with Bottle Filler | Main Entrance                   | 1 of 1                     | Water Fountain      | <1                     |
| 377466    | Main Building | Sink                                      | Room 108                        | 2 of 7                     | Tap                 | <1                     |
| 377468    | Main          | Sink                                      | Room 108                        | 4 of 7                     | Tap                 | <1                     |

| Sample ID | Building Name | Fixture Housing Type                      | Fixture Location          | Fixture Location Details | Fixture Type        | Lead Test Result (ppb) |
|-----------|---------------|-------------------------------------------|---------------------------|--------------------------|---------------------|------------------------|
|           | Building      |                                           |                           |                          |                     |                        |
| 377469    | Main Building | Sink                                      | Room 108                  | 5 of 7                   | Tap                 | <1                     |
| 377470    | Main Building | Sink                                      | Room 108                  | 6 of 7                   | Tap                 | <1                     |
| 377475    | Main Building | Sink - Multi-Compartment                  | Kitchen                   | 1 of 4                   | Tap                 | <1                     |
| 377476    | Main Building | Sink - Multi-Compartment                  | Kitchen                   | 1 of 4                   | Sprayer             | <1                     |
| 377479    | Main Building | Sink                                      | Kitchen                   | 2 of 4                   | Sprayer             | <1                     |
| 377963    | Main Building | Fountain - Multi-Level with Bottle Filler | Cafeteria Fountains       | 1 of 1. Lower fountain   | Water Fountain      | <1                     |
| 377964    | Main Building | Fountain - Multi-Level with Bottle Filler | Cafeteria Fountain        | 1 of 1                   | Water Bottle Filler | <1                     |
| 377965    | Main Building | Fountain - Multi-Level with Bottle Filler | Cafeteria Fountain        | 1 of 1                   | Water Fountain      | <1                     |
| 377966    | Main Building | Fountain                                  | Next To Office D206       | 1 of 1                   | Water Fountain      | <1                     |
| 377968    | Main Building | Fountain with Bottle Filler               | Next To Room 210          | 1 of 1                   | Water Fountain      | <1                     |
| 377969    | Main Building | Fountain - Multi-Level with Bottle Filler | Next To Science Prep E204 | 1 of 1                   | Water Bottle Filler | <1                     |
| 377970    | Main Building | Fountain - Multi-Level with Bottle Filler | Next To Science Prep E204 | 1 of 1. Higher fountain  | Water Fountain      | <1                     |
| 377971    | Main Building | Fountain - Multi-Level with Bottle        | Next To Science Prep E204 | 1 of 1                   | Water Fountain      | <1                     |

| Sample ID | Building Name | Fixture Housing Type                      | Fixture Location | Fixture Location Details | Fixture Type        | Lead Test Result (ppb) |
|-----------|---------------|-------------------------------------------|------------------|--------------------------|---------------------|------------------------|
| 377972    | Main Building | Fountain - Multi-Level with Bottle Filler | Outside Main Gym | 1 of 1                   | Water Bottle Filler | <1                     |
| 377973    | Main Building | Fountain - Multi-Level with Bottle Filler | Outside Main Gym | 1 of 1. Higher fountain  | Water Fountain      | <1                     |
| 377974    | Main Building | Fountain - Multi-Level with Bottle Filler | Outside Main Gym | 1 of 1                   | Water Fountain      | <1                     |

#### EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**