

# Lead in School Drinking Water Report

## Pioneer Middle School



### EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: [leadfreekids@doh.wa.gov](mailto:leadfreekids@doh.wa.gov).

## DEFINITIONS

Fixture Housing  
Location

Room/space where  
fixture is located  
(i.e. room number,  
gym, playground)

Fixture Housing Type

Structure that contains  
the individual fixtures  
where water samples  
were collected from.  
Fixture housing may  
contain one or more  
individual fixture for  
sampling.

Fixture Location  
Details

Location within a  
room or space where  
fixture housing is  
located, starting to the  
left of the entrance and  
rotating clockwise, of  
the total number of  
fixture housings in a  
room or space  
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water  
Fountain, Water Bottle  
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2024-11-07, 2024-11-21

Date(s) analyzed: 2024-11-26, 2024-12-05, 2024-12-06, 2024-12-10

| . | Sample ID | Building Name | Fixture Housing Type     | Fixture Location        | Fixture Location Details            | Fixture Type | Fixture Position | Lead Test Result (ppb) |
|---|-----------|---------------|--------------------------|-------------------------|-------------------------------------|--------------|------------------|------------------------|
| 1 | 401996    | Main Building | Sink                     | Snack Bar               | 2 of 2                              | Tap          | center           | 243                    |
| 2 | 401995    | Main Building | Sink                     | Snack Bar               | 1 of 2.<br>Hand washing sink        | Tap          | center           | 87                     |
| 3 | 401986    | Main Building | Sink - Multi-Compartment | Kitchen                 | 1 of 7                              | Tap          | left             | 55                     |
| 4 | 401987    | Main Building | Sink - Multi-Compartment | Kitchen                 | 1 of 7.<br>Across from refrigerator | Tap          | right            | 38                     |
| 5 | 402035    | Main Building | Sink - Multi-Compartment | Room A115               | 1 of 9                              | Tap          | left             | 21                     |
| 6 | 402036    | Main Building | Sink - Multi-Compartment | Room A115               | 1 of 9                              | Tap          | right            | 12                     |
| 7 | 402047    | Main Building | Sink - Multi-Compartment | Room A109               | 1 of 1                              | Tap          | center           | 11                     |
| 8 | 402029    | Main Building | Sink                     | Room B103               | 1 of 1                              | Tap          | left             | 10                     |
| 9 | 401999    | Main Building | Sink                     | Room 101<br>Drama/Stage | 1 of 1                              | Tap          | center           | 9                      |

| .  | Sample ID | Building Name | Fixture Housing Type     | Fixture Location           | Fixture Location Details         | Fixture Type | Fixture Position | Lead Test Result (ppb) |
|----|-----------|---------------|--------------------------|----------------------------|----------------------------------|--------------|------------------|------------------------|
| 10 | 402020    | Main Building | Sink - Multi-Compartment | Asb Store                  | 1 of 1                           | Tap          | center           | 8                      |
| 11 | 402040    | Main Building | Sink                     | Room A115                  | 4 of 9                           | Tap          | left             | 8                      |
| 12 | 402043    | Main Building | Sink                     | Room A115                  | 7 of 9                           | Tap          | left             | 8                      |
| 13 | 402039    | Main Building | Sink                     | Room A115                  | 3 of 9                           | Tap          | left             | 7                      |
| 14 | 402055    | Main Building | Sink                     | Pod Sink Next To Room A104 | 1 of 1                           | Tap          | left             | 7                      |
| 15 | 402016    | Main Building | Sink                     | Pod Sink Next To Room C104 | 1 of 1                           | Tap          | left             | 6                      |
| 16 | 402044    | Main Building | Sink                     | Room A115                  | 8 of 9                           | Tap          | left             | 6                      |
| 17 | 402033    | Main Building | Sink                     | Room A118 Nurses Office    | 1 of 1                           | Tap          | center           | 5                      |
| 18 | 402042    | Main Building | Sink                     | Room A115                  | 6 of 9                           | Tap          | left             | 5                      |
| 19 | 402245    | Main Building | Sink                     | Room B201                  | 1 of 1                           | Tap          | left             | 5                      |
| 20 | 401991    | Main Building | Sink - Multi-Compartment | Kitchen                    | 5 of 7. Sink next to dish washer | Tap          | left             | 4                      |
| 21 | 401993    | Main Building | Sink                     | Kitchen                    | 6 of 7. Sink closest             | Tap          | center           | 4                      |

|    | Sample ID | Building Name | Fixture Housing Type     | Fixture Location         | Fixture Location Details | Fixture Type   | Fixture Position | Lead Test Result (ppb) |
|----|-----------|---------------|--------------------------|--------------------------|--------------------------|----------------|------------------|------------------------|
|    |           |               |                          |                          | to snack bar             |                |                  |                        |
| 22 | 402000    | Main Building | Sink                     | Room 101 Drama/Stage     | 1 of 1                   | Water Fountain | right            | 4                      |
| 23 | 402014    | Main Building | Sink                     | Room C103                | 1 of 1                   | Tap            | left             | 4                      |
| 24 | 402034    | Main Building | Sink                     | Room A119. Health Office | 1 of 1                   | Tap            | center           | 4                      |
| 25 | 402224    | Main Building | Sink                     | Room 129                 | 1 of 1                   | Tap            | left             | 4                      |
| 26 | 402235    | Main Building | Sink                     | Room A202                | 1 of 1                   | Tap            | left             | 4                      |
| 27 | 402241    | Main Building | Sink                     | Room B203                | 1 of 1                   | Tap            | left             | 4                      |
| 28 | 402243    | Main Building | Sink                     | Room B202                | 1 of 1                   | Tap            | left             | 4                      |
| 29 | 402250    | Main Building | Sink                     | Room C209                | 1 of 1                   | Tap            | left             | 4                      |
| 30 | 402253    | Main Building | Sink                     | Room C215                | 1 of 1                   | Tap            | left             | 4                      |
| 31 | 401209    | Main Building | Fountain - Multi-Level   | Next To Restroom C214    | 1 of 1. Lower fountain   | Water Fountain | right            | 3                      |
| 32 | 401992    | Main Building | Sink - Multi-Compartment | Kitchen                  | 5 of 7                   | Tap            | right            | 3                      |
| 33 | 402007    | Main Building | Sink - Multi-Compartment | Room C109                | 1 of 2                   | Tap            | center           | 3                      |
| 34 | 402011    | Main Building | Sink                     | Room C101                | 1 of 1                   | Water Fountain | right            | 3                      |

| .  | Sample ID | Building Name | Fixture Housing Type   | Fixture Location           | Fixture Location Details                 | Fixture Type   | Fixture Position | Lead Test Result (ppb) |
|----|-----------|---------------|------------------------|----------------------------|------------------------------------------|----------------|------------------|------------------------|
| 35 | 402025    | Main Building | Sink                   | Room B101                  | 1 of 1                                   | Tap            | left             | 3                      |
| 36 | 402027    | Main Building | Sink                   | Room B102                  | 1 of 1                                   | Tap            | left             | 3                      |
| 37 | 402031    | Main Building | Sink                   | Pod Sink Next To Room B104 | 1 of 1                                   | Tap            | left             | 3                      |
| 38 | 402037    | Main Building | Sink                   | Room A115                  | 2 of 9                                   | Tap            | left             | 3                      |
| 39 | 402045    | Main Building | Sink                   | Room A115                  | 9 of 9                                   | Tap            | left             | 3                      |
| 40 | 402050    | Main Building | Sink                   | Room A101                  | 1 of 1                                   | Tap            | left             | 3                      |
| 41 | 402052    | Main Building | Sink                   | Room A102                  | 1 of 1                                   | Tap            | left             | 3                      |
| 42 | 402251    | Main Building | Sink                   | Room C210                  | 1 of 1                                   | Tap            | left             | 3                      |
| 43 | 401208    | Main Building | Fountain - Multi-Level | Next To Restroom C214      | 1 of 1. Higher fountain                  | Water Fountain | left             | 2                      |
| 44 | 401989    | Main Building | Sink                   | Kitchen                    | 3 of 7. SW side sink on island by itself | Tap            | center           | 2                      |
| 45 | 401994    | Main Building | Pot Filler             | Kitchen                    | 7 of 7                                   | Other          | center           | 2                      |
| 46 | 402005    | Main Building | Sink                   | Room C126                  | 3 of 4. To the right of                  | Tap            | center           | 2                      |

|    | Sample ID | Building Name | Fixture Housing Type | Fixture Location           | Fixture Location Details | Fixture Type   | Fixture Position | Lead Test Result (ppb) |
|----|-----------|---------------|----------------------|----------------------------|--------------------------|----------------|------------------|------------------------|
|    |           |               |                      |                            | storage C128             |                |                  |                        |
| 47 | 402009    | Main Building | Sink                 | Room C109                  | 2 of 2                   | Water Fountain | right            | 2                      |
| 48 | 402012    | Main Building | Sink                 | Room C102                  | 1 of 1                   | Tap            | left             | 2                      |
| 49 | 402013    | Main Building | Sink                 | Room C102                  | 1 of 1                   | Water Fountain | right            | 2                      |
| 50 | 402015    | Main Building | Sink                 | Room C103                  | 1 of 1                   | Water Fountain | right            | 2                      |
| 51 | 402017    | Main Building | Sink                 | Pod Sink Next To Room C104 | 1 of 1                   | Water Fountain | right            | 2                      |
| 52 | 402021    | Main Building | Sink                 | Room B109                  | 1 of 1                   | Tap            | left             | 2                      |
| 53 | 402022    | Main Building | Sink                 | Room B109                  | 1 of 1                   | Water Fountain | right            | 2                      |
| 54 | 402041    | Main Building | Sink                 | Room A115                  | 5 of 9                   | Tap            | left             | 2                      |
| 55 | 402051    | Main Building | Sink                 | Room A101                  | 1 of 1                   | Water Fountain | right            | 2                      |
| 56 | 402053    | Main Building | Sink                 | Room A102                  | 1 of 1                   | Water Fountain | right            | 2                      |
| 57 | 402223    | Main Building | Sink                 | Room 126                   | 1 of 1                   | Water Fountain | right            | 2                      |
| 58 | 402231    | Main Building | Sink                 | Room A209                  | 1 of 1                   | Tap            | left             | 2                      |
| 59 | 402233    | Main Building | Sink                 | Room A203                  | 1 of 1                   | Tap            | left             | 2                      |
| 60 | 402236    | Main Building | Sink                 | Room A202                  | 1 of 1                   | Water Fountain | right            | 2                      |
| 61 | 402237    | Main Building | Sink                 | Room A201                  | 1 of 1                   | Tap            | left             | 2                      |

| .  | Sample ID | Building Name | Fixture Housing Type   | Fixture Location           | Fixture Location Details | Fixture Type   | Fixture Position | Lead Test Result (ppb) |
|----|-----------|---------------|------------------------|----------------------------|--------------------------|----------------|------------------|------------------------|
| 62 | 402240    | Main Building | Fountain - Multi-Level | Next To Restroom A214      | 1 of 1. Lower fountain   | Water Fountain | right            | 2                      |
| 63 | 402242    | Main Building | Sink                   | Room B203                  | 1 of 1                   | Water Fountain | right            | 2                      |
| 64 | 402259    | Main Building | Sink                   | Room C201                  | 1 of 1                   | Tap            | left             | 2                      |
| 65 | 401988    | Main Building | Sink                   | Kitchen                    | 2 of 7. NE side          | Tap            | center           | 1                      |
| 66 | 402001    | Main Building | Sink                   | Staff Lounge               | 1 of 1                   | Tap            | left             | 1                      |
| 67 | 402006    | Main Building | Sink                   | Room C126                  | 4 of 4                   | Tap            | center           | 1                      |
| 68 | 402008    | Main Building | Sink                   | Room C109                  | 2 of 2                   | Tap            | left             | 1                      |
| 69 | 402010    | Main Building | Sink                   | Room C101                  | 1 of 1                   | Tap            | left             | 1                      |
| 70 | 402026    | Main Building | Sink                   | Room B101                  | 1 of 1                   | Water Fountain | right            | 1                      |
| 71 | 402028    | Main Building | Sink                   | Room B102                  | 1 of 1                   | Water Fountain | right            | 1                      |
| 72 | 402030    | Main Building | Sink                   | Room B103                  | 1 of 1                   | Water Fountain | right            | 1                      |
| 73 | 402032    | Main Building | Sink                   | Pod Sink Next To Room B104 | 1 of 1                   | Water Fountain | right            | 1                      |
| 74 | 402054    | Main Building | Sink                   | Room A103                  | 1 of 1                   | Tap            | left             | 1                      |
| 75 | 402222    | Main Building | Sink                   | Room 126                   | 1 of 1                   | Tap            | left             | 1                      |
| 76 | 402238    | Main Building | Sink                   | Room A201                  | 1 of 1                   | Water Fountain | right            | 1                      |

|    | Sample ID | Building Name | Fixture Housing Type   | Fixture Location             | Fixture Location Details                  | Fixture Type   | Fixture Position | Lead Test Result (ppb) |
|----|-----------|---------------|------------------------|------------------------------|-------------------------------------------|----------------|------------------|------------------------|
| 77 | 402244    | Main Building | Sink                   | Room B202                    | 1 of 1                                    | Water Fountain | right            | 1                      |
| 78 | 402246    | Main Building | Sink                   | Room B201                    | 1 of 1                                    | Water Fountain | right            | 1                      |
| 79 | 402255    | Main Building | Sink                   | Room C203                    | 1 of 1                                    | Tap            | left             | 1                      |
| 80 | 402257    | Main Building | Sink                   | Room C202                    | 1 of 1                                    | Tap            | left             | 1                      |
| 81 | 402258    | Main Building | Sink                   | Room C202                    | 1 of 1                                    | Water Fountain | right            | 1                      |
| 82 | 401207    | Main Building | Sink                   | Room C201                    | 1 of 1                                    | Water Fountain | right            | <1                     |
| 83 | 401990    | Main Building | Sink                   | Kitchen                      | 4 of 7                                    | Sprayer        | center           | <1                     |
| 84 | 401997    | Main Building | Fountain - Multi-Level | Next To Drama/Stage Room 101 | 1 of 1. Higher fountain                   | Water Fountain | right            | <1                     |
| 85 | 401998    | Main Building | Fountain - Multi-Level | Next To Drama/Stage Room 101 | 1 of 1. Lower fountain                    | Water Fountain | right            | <1                     |
| 86 | 402002    | Main Building | Sink                   | Staff Lounge                 | 1 of 1                                    | Water Fountain | right            | <1                     |
| 87 | 402003    | Main Building | Sink                   | Room C126                    | 1 of 4. Sinks with fountain left to right | Water Fountain | right            | <1                     |
| 88 | 402004    | Main Building | Sink                   | Room C126                    | 2 of 4                                    | Water Fountain | right            | <1                     |

| .  | Sample ID | Building Name | Fixture Housing Type   | Fixture Location           | Fixture Location Details | Fixture Type   | Fixture Position | Lead Test Result (ppb) |
|----|-----------|---------------|------------------------|----------------------------|--------------------------|----------------|------------------|------------------------|
| 89 | 402018    | Main Building | Fountain - Multi-Level | Next To Bathroom C114      | 1 of 1. Higher fountain  | Water Fountain | left             | <1                     |
| 90 | 402019    | Main Building | Fountain - Multi-Level | Next To Bathroom C114      | 1 of 1. Lower fountain   | Water Fountain | left             | <1                     |
| 91 | 402023    | Main Building | Fountain - Multi-Level | Next To Bathroom B114      | 1 of 1. Higher fountain  | Water Fountain | left             | <1                     |
| 92 | 402024    | Main Building | Fountain - Multi-Level | Next To Bathroom B114      | 1 of 1. Lower fountain.  | Water Fountain | left             | <1                     |
| 93 | 402038    | Main Building | Sink                   | Room A115                  | 2 of 9                   | Water Fountain | right            | <1                     |
| 94 | 402046    | Main Building | Sink                   | Room A115                  | 9 of 9                   | Water Fountain | right            | <1                     |
| 95 | 402048    | Main Building | Fountain - Multi-Level | Next To Bathroom A114      | 1 of 1. Higher fountain  | Water Fountain | left             | <1                     |
| 96 | 402049    | Main Building | Fountain - Multi-Level | Next To Bathroom A114      | 1 of 1. Lower fountain   | Water Fountain | left             | <1                     |
| 97 | 402056    | Main Building | Sink                   | Pod Sink Next To Room A104 | 1 of 1                   | Water Fountain | right            | <1                     |
| 98 | 402225    | Main Building | Sink                   | Room 129                   | 1 of 1                   | Water Fountain | right            | <1                     |

| .   | Sample ID | Building Name | Fixture Housing Type                      | Fixture Location            | Fixture Location Details | Fixture Type        | Fixture Position | Lead Test Result (ppb) |
|-----|-----------|---------------|-------------------------------------------|-----------------------------|--------------------------|---------------------|------------------|------------------------|
| 99  | 402226    | Main Building | Fountain - Multi-Level with Bottle Filler | Outside Of Fitness Room 101 | 1 of 1. Higher fountain  | Water Fountain      | left             | <1                     |
| 100 | 402227    | Main Building | Fountain - Multi-Level with Bottle Filler | Outside Of Fitness Room 101 | 1 of 1                   | Water Bottle Filler | right            | <1                     |
| 101 | 402228    | Main Building | Fountain - Multi-Level with Bottle Filler | Outside Of Fitness Room 101 | 1 of 1. Lower fountain   | Water Fountain      | right            | <1                     |
| 102 | 402229    | Main Building | Fountain - Multi-Level                    | Main Gym                    | 1 of 1. Higher fountain  | Water Fountain      | left             | <1                     |
| 103 | 402230    | Main Building | Fountain - Multi-Level                    | Main Gym                    | 1 of 1. Lower fountain   | Water Fountain      | right            | <1                     |
| 104 | 402232    | Main Building | Sink                                      | Room A209                   | 1 of 1                   | Water Fountain      | right            | <1                     |
| 105 | 402234    | Main Building | Sink                                      | Room A203                   | 1 of 1                   | Water Fountain      | right            | <1                     |
| 106 | 402239    | Main Building | Fountain - Multi-Level                    | Next To Restroom A214       | 1 of 1. Higher fountain  | Water Fountain      | left             | <1                     |
| 107 | 402247    | Main Building | Fountain - Multi-Level with Bottle Filler | Across From Room B210       | 1 of 1. Higher fountain  | Water Fountain      | left             | <1                     |

| .   | Sample ID | Building Name | Fixture Housing Type                      | Fixture Location      | Fixture Location Details | Fixture Type        | Fixture Position | Lead Test Result (ppb) |
|-----|-----------|---------------|-------------------------------------------|-----------------------|--------------------------|---------------------|------------------|------------------------|
| 108 | 402248    | Main Building | Fountain - Multi-Level with Bottle Filler | Across From Room B210 | 1 of 1                   | Water Bottle Filler | right            | <1                     |
| 109 | 402249    | Main Building | Fountain - Multi-Level with Bottle Filler | Across From Room B210 | 1 of 1. Lower fountain   | Water Fountain      | right            | <1                     |
| 110 | 402252    | Main Building | Sink                                      | Room C210             | 1 of 1                   | Water Fountain      | right            | <1                     |
| 111 | 402254    | Main Building | Sink                                      | Room C215             | 1 of 1                   | Water Fountain      | right            | <1                     |
| 112 | 402256    | Main Building | Sink                                      | Room C203             | 1 of 1                   | Water Fountain      | right            | <1                     |