Lead in Water Test Results Summary: Riverdale Grade School

Notes:

- **The lead in water Action Level is 15 parts per billion (ppb).**
  Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing.

- A "**ND**" or "non-detect" test result indicates the sample measured below the minimum detection limit of **[#] ppb**.

Legend:

- Test results **equal to or greater than the Action Level** of 15 ppb are **highlighted in red and precede a "High" value** in the "Initial Level" or "Final Level" column.

- Test results **near the Action Level** of 15 ppb (11.99 to 14.99 ppb) are **highlighted in yellow and precede a "Med" (Medium) value** in the "Initial Level" or "Final Level" column.

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
21880000-095SF24A	District Office Building; Kitchenette - Staff Fixture	12/21/2024	0.377	Low	*[enter date]*	*[enter result]*	*[autofill]*
21880000-096BF24A	District Office Building; Restroom - Bathroom Fixture	12/21/2024	1.32	Low			
21880100-001NS24A	Main Building; 1st Floor, Nurses Office - Nurses Station	12/21/2024	1.92	Low			
21880100-002BF24A	Main Building; 1st Floor, Nurses Office Restroom - Bathroom Fixture	12/21/2024	2.03	Low			
21880100-003CF24A	Main Building; 1st Floor, Classroom 110 - Classroom Fixture	12/21/2024	3.39	Low			
21880100-004DW24A	Main Building; 1st Floor, Classroom 110 - Drinking Fountain	12/21/2024	2.52	Low			
21880100-005CF24A	Main Building; 1st Floor, Classroom 106 - Classroom Fixture	12/21/2024	3.12	Low			
21880100-006DW24A	Main Building; 1st Floor, Classroom 106 - Drinking Fountain	12/21/2024	3.04	Low			
21880100-007CF24A	Main Building; 1st Floor, Classroom 102 - Classroom Fixture	12/21/2024	2.68	Low			
21880100-008DW24A	Main Building; 1st Floor, Classroom 102 - Drinking Fountain	12/21/2024	2.23	Low			
21880100-009CF24A	Main Building; 1st Floor, Classroom 101 - Classroom Fixture	12/21/2024	3.19	Low			
21880100-010DW24A	Main Building; 1st Floor, Classroom 101 - Drinking Fountain	12/21/2024	4.05	Low			
21880100-011CF24A	Main Building; 1st Floor, Classroom 105 - Classroom Fixture	12/21/2024	8.62	Low			
21880100-012DW24A	Main Building; 1st Floor, Classroom 105 - Drinking Fountain	12/21/2024	3.16	Low			
21880100-013CF24A	Main Building; 1st Floor, Classroom 109 - Classroom Fixture	12/21/2024	4.19	Low			
21880100-014DW24A	Main Building; 1st Floor, Classroom 109 - Drinking Fountain	12/21/2024	1.8	Low			
21880100-015BF24A	Main Building; 1st Floor, South Restrooms, South Faucet - Bathroom Fixture	12/21/2024	1.96	Low			
21880100-016BF24A	Main Building; 1st Floor, South Restrooms, South Middle Faucet - Bathroom Fixture	12/21/2024	2.88	Low			
21880100-017BF24A	Main Building; 1st Floor, South Restrooms,North Middle Faucet - Bathroom Fixture	12/21/2024	2.18	Low			
21880100-018BF24A	Main Building; 1st Floor, South Restrooms, North Faucet - Bathroom Fixture	12/21/2024	1.58	Low			
21880100-019DW24A	Main Building; 1st Floor, Corridor at SouthRestrooms, South Fountain - Drinking Fountain	12/21/2024	0.883	Low			
21880100-020DW24A	Main Building; 1st Floor, Corridor at South Restrooms, North Fountain - Drinking Fountain	12/21/2024	1.08	Low			
21880100-021DW24A	Main Building; 1st Floor, Corridor at North Restrooms, South Fountain - Drinking Fountain	12/21/2024	0.936	Low			
21880100-022DW24A	Main Building; 1st Floor, Corridor at NorthRestrooms, North Fountain - Drinking Fountain	12/21/2024	0.534	Low			
21880100-023BF24A	Main Building; 1st Floor, North Restrooms, South Faucet - Bathroom Fixture	12/21/2024	1.86	Low			
21880100-024BF24A	Main Building; 1st Floor, North Restrooms,South Middle Faucet - Bathroom Fixture	12/21/2024	2.06	Low			
21880100-025BF24A	Main Building; 1st Floor, North Restrooms, North Middle Faucet - Bathroom Fixture	12/21/2024	1.61	Low			
21880100-026BF24A	Main Building; 1st Floor, North Restrooms, North Faucet - Bathroom Fixture	12/21/2024	1.57	Low			
21880100-027CF24A	Main Building; 1st Floor, Classroom 127 - Classroom Fixture	12/21/2024	3.13	Low			
21880100-028DW24A	Main Building; 1st Floor, Classroom 127 - Drinking Fountain	12/21/2024	4.21	Low			
21880100-029CF24A	Main Building; 1st Floor, Classroom 131 - Classroom Fixture	12/21/2024	3.17	Low			
21880100-030DW24A	Main Building; 1st Floor, Classroom 131 - Drinking Fountain	12/21/2024	2.13	Low			
21880100-031CF24A	Main Building; 1st Floor, Classroom 135 - Classroom Fixture	12/21/2024	0.828	Low			
21880100-032DW24A	Main Building; 1st Floor, Classroom 135 - Drinking Fountain	12/21/2024	2.78	Low			
21880100-033CF24A	Main Building; 1st Floor, Classroom 136 - Classroom Fixture	12/21/2024	2.21	Low			
21880100-034DW24A	Main Building; 1st Floor, Classroom 136 - Drinking Fountain	12/21/2024	1.82	Low			
21880100-035CF24A	Main Building; 1st Floor, Classroom 132 - Classroom Fixture	12/21/2024	6.03	Low			
21880100-037CF24A	Main Building; 1st Floor, Classroom 128 - Classroom Fixture	12/21/2024	4.44	Low			
21880100-038BF24A	Main Building; 1st Floor, North Staff Restroom - Bathroom Fixture	12/21/2024	2.11	Low			
21880100-039BF24A	Main Building; 1st Floor, South Staff Restroom - Bathroom Fixture	12/21/2024	1.18	Low			
21880100-040SF24A	Main Building; 1st Floor, Teacher's Lounge - Staff Fixture	12/21/2024	1.84	Low			
21880100-041CF24A	Main Building; 2nd Floor, Classroom 210 - Classroom Fixture	12/21/2024	4.85	Low			
21880100-042DW24A	Main Building; 2nd Floor, Classroom 210 - Drinking Fountain	12/21/2024	10.3	Low			
21880100-043CF24A	Main Building; 2nd Floor, Classroom 206 - Classroom Fixture	12/21/2024	8.53	Low			
21880100-044DW24A	Main Building; 2nd Floor, Classroom 206 - Drinking Fountain	12/21/2024	2.16	Low			
21880100-045CF24A	Main Building; 2nd Floor, Classroom 202 - Classroom Fixture	12/21/2024	4.75	Low			
21880100-046DW24A	Main Building; 2nd Floor, Classroom 202 - Drinking Fountain	12/21/2024	2.52	Low			
21880100-047CF24A	Main Building; 2nd Floor, Classroom 201 - Classroom Fixture	12/21/2024	4.13	Low			
21880100-048DW24A	Main Building; 2nd Floor, Classroom 201 - Drinking Fountain	12/21/2024	2.82	Low			
21880100-049CF24A	Main Building; 2nd Floor, Classroom 205 - Classroom Fixture	12/21/2024	3.68	Low			
21880100-050DW24A	Main Building; 2nd Floor, Classroom 205 - Drinking Fountain	12/21/2024	4.18	Low			
21880100-051CF24A	Main Building; 2nd Floor, Classroom 209, East Wall, North Faucet - Classroom Fixture	12/21/2024	2.92	Low			
21880100-052CF24A	Main Building; 2nd Floor, Classroom 209, East Wall, North Middle Faucet - Classroom Fixture	12/21/2024	2.66	Low			
21880100-053CF24A	Main Building; 2nd Floor, Classroom 209, East Wall, South Middle Faucet - Classroom Fixture	12/21/2024	3.06	Low			
21880100-054CF24A	Main Building; 2nd Floor, Classroom 209, East Wall, South Faucet - Classroom Fixture	12/21/2024	2.33	Low			
21880100-055CF24A	Main Building; 2nd Floor, Classroom 209, South Wall - Classroom Fixture	12/21/2024	**15.3**	**High**			
21880100-057SF24A	Main Building; 2nd Floor, Classroom 209 Storage - Staff Fixture	12/21/2024	**29.4**	**High**			
21880100-058BF24A	Main Building; 2nd Floor, South Restrooms, South Faucet - Bathroom Fixture	12/21/2024	2.43	Low			
21880100-059BF24A	Main Building; 2nd Floor, South Restrooms, South Middle Faucet - Bathroom Fixture	12/21/2024	2.76	Low			
21880100-060BF24A	Main Building; 2nd Floor, South Restrooms, North Middle Faucet - Bathroom Fixture	12/21/2024	2.02	Low			
21880100-061BF24A	Main Building; 2nd Floor, South Restrooms, North Faucet - Bathroom Fixture	12/21/2024	2.61	Low			
21880100-062DW24A	Main Building; 2nd Floor, Corridor at South Restrooms, South Fountain - Drinking Fountain	12/21/2024	1.06	Low			
21880100-063DW24A	Main Building; 2nd Floor, Corridor at South Restrooms, North Fountain - Drinking Fountain	12/21/2024	1.14	Low			
21880100-065DW24A	Main Building; 2nd Floor, Corridor at North Restrooms, Fountain - Drinking Fountain	12/21/2024	0.371	Low			
21880100-066WB24A	Main Building; 2nd Floor, Corridor at North Restrooms, Bottle Filler - Bottle Filler	12/21/2024	ND	Low			
21880100-067BF24A	Main Building; 2nd Floor, North Restrooms, South Faucet - Bathroom Fixture	12/21/2024	2.6	Low			
21880100-068BF24A	Main Building; 2nd Floor, North Restrooms, South Middle Faucet - Bathroom Fixture	12/21/2024	2.35	Low			
21880100-069BF24A	Main Building; 2nd Floor, North Restrooms, North Middle Faucet - Bathroom Fixture	12/21/2024	2.41	Low			
21880100-070BF24A	Main Building; 2nd Floor, North Restrooms, North Faucet - Bathroom Fixture	12/21/2024	2.09	Low			
21880100-071CF24A	Main Building; 2nd Floor, Classroom 227, East Wall, North Faucet - Classroom Fixture	12/21/2024	2.94	Low			
21880100-072CF24A	Main Building; 2nd Floor, Classroom 227, East Wall, North Middle Faucet - Classroom Fixture	12/21/2024	6.17	Low			
21880100-073CF24A	Main Building; 2nd Floor, Classroom 227, East Wall, South Middle Faucet - Classroom Fixture	12/21/2024	1.15	Low			
21880100-074CF24A	Main Building; 2nd Floor, Classroom 227, East Wall, South Faucet - Classroom Fixture	12/21/2024	2.63	Low			
21880100-076CF24A	Main Building; 2nd Floor, Classroom 227, North Wall - Classroom Fixture	12/21/2024	**23.5**	**High**			
21880100-077SF24A	Main Building; 2nd Floor, Classroom 227 Storage - Staff Fixture	12/21/2024	2.75	Low			
21880100-078CF24A	Main Building; 2nd Floor, Classroom 231 - Classroom Fixture	12/21/2024	8.97	Low			
21880100-079DW24A	Main Building; 2nd Floor, Classroom 231 - Drinking Fountain	12/21/2024	7.81	Low			
21880100-080CF24A	Main Building; 2nd Floor, Classroom 235 - Classroom Fixture	12/21/2024	4.75	Low			
21880100-081DW24A	Main Building; 2nd Floor, Classroom 235 - Drinking Fountain	12/21/2024	3.13	Low			
21880100-082CF24A	Main Building; 2nd Floor, Classroom 236 - Classroom Fixture	12/21/2024	6.39	Low			

Fixture Location Description	Fixture ID #	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level
21880100-083DW24A	Main Building; 2nd Floor, Classroom 236 - Drinking Fountain	12/21/2024	2.83	Low			
21880100-084CF24A	Main Building; 2nd Floor, Classroom 232 - Classroom Fixture	12/21/2024	3.58	Low			
21880100-085DW24A	Main Building; 2nd Floor, Classroom 232 - Drinking Fountain	12/21/2024	2.9	Low			
21880100-086BF24A	Main Building; 2nd Floor, Staff Restroom at Classroom 232 - Bathroom Fixture	12/21/2024	1.69	Low			
21880100-087CF24A	Main Building; 2nd Floor, Classroom 228, West Wall - Classroom Fixture	12/21/2024	2.25	Low			
21880100-088DW24A	Main Building; 2nd Floor, Classroom 228, West Wall - Drinking Fountain	12/21/2024	2.37	Low			
21880100-089CF24A	Main Building; 2nd Floor, Classroom 228, Island, West Faucet - Classroom Fixture	12/21/2024	4.42	Low			
21880100-090DW24A	Main Building; 2nd Floor, Classroom 228, Island, West Fountain - Drinking Fountain	12/21/2024	6.37	Low			
21880100-091CF24A	Main Building; 2nd Floor, Classroom 228, Island, East Faucet - Classroom Fixture	12/21/2024	3.76	Low			
21880100-092DW24A	Main Building; 2nd Floor, Classroom 228, Island, East Fountain - Drinking Fountain	12/21/2024	4.64	Low			
21880100-093BF24A	Main Building; 2nd Floor, Restroom at Classroom 228 - Bathroom Fixture	12/21/2024	2.06	Low			
21880100-094SF24A	Main Building; 2nd Floor, Library Office - Staff Fixture	12/21/2024	3.06	Low			
21880101-097CF24A	Music Building; Band Room - Classroom Fixture	12/21/2024	1.39	Low			
21880101-099BF24A	Music Building; Restroom - Bathroom Fixture	12/21/2024	1.7	Low			
21880102-100WB24A	Commons; Gym, Bottle Filler - Bottle Filler	12/21/2024	1.04	Low			
21880102-101DW24A	Commons; Gym, West Fountain - Drinking Fountain	12/21/2024	1.12	Low			
21880102-102DW24A	Commons; Gym, East Fountain - Drinking Fountain	12/21/2024	1.16	Low			
21880102-103SF24A	Commons; Basement, Custodial Area - Staff Faucet	12/21/2024	**28.2**	**High**			
21880102-104BF24A	Commons; Girl's Restroom, East Faucet - Bathroom Fixture	12/21/2024	2	Low			
21880102-105BF24A	Commons; Girl's Restroom, Middle Faucet - Bathroom Fixture	12/21/2024	1.99	Low			
21880102-106BF24A	Commons; Girl's Restroom, West Faucet - Bathroom Fixture	12/21/2024	2.12	Low			
21880102-107BF24A	Commons; Boy's Restroom, East Faucet - Bathroom Fixture	12/21/2024	1.69	Low			
21880102-108BF24A	Commons; Boy's Restroom, Middle Faucet - Bathroom Fixture	12/21/2024	1.67	Low			
21880102-109BF24A	Commons; Boy's Restroom, West Faucet - Bathroom Fixture	12/21/2024	1.84	Low			
21880102-110DW24A	Commons; Cafeteria, West Fountain - Drinking Fountain	12/21/2024	0.642	Low			
21880102-112KF24A	Commons; Kitchen, West Wall, Sprayer - Kitchen Fixture	12/21/2024	2.89	Low			
21880102-113KF24A	Commons; Kitchen, North Wall, West Sink, West Faucet - Kitchen Fixture	12/21/2024	6.72	Low			
21880102-114KF24A	Commons; Kitchen, North Wall, West Sink, East Faucet - Kitchen Fixture	12/21/2024	7.05	Low			
21880102-115KF24A	Commons; Kitchen, North Wall, East Sink, West Faucet - Kitchen Fixture	12/21/2024	7.36	Low			
21880102-116KF24A	Commons; Kitchen, North Wall, East Sink, Sprayer - Kitchen Fixture	12/21/2024	**20.4**	**High**			
21880102-117KF24A	Commons; Kitchen, North Wall, East Sink, East Faucet - Kitchen Fixture	12/21/2024	3.98	Low			
21880102-118KF24A	Commons; West Wall, Handwashing Sink - Kitchen Fixture	12/21/2024	5.64	Low			
21880102-119IM24A	Commons; Kitchen, Ice Maker - Ice Maker	12/21/2024	ND	Low			
21880102-120DW24A	Exterior; Covered Play Area, East Fountain - Drinking Fountain	12/21/2024	ND	Low			