

School Name: **Oak Park Elementary (OP)**

Date:

Floor	Room Number	Location	Sample ID	Type		Lead Result
				DF = Drinking Fountain S = Sink = Water Cooler Bottle Filler	WC BF = K=Kettle	
Main	-	Kitchen	01-OP-Kitchen main	S		0.78
Main	-	Kitchen	02-OP-food warm	S		0
Main	-	Kitchen	03-OP-After DW sink	S		1.96
Main	-	Kitchen	04-OP-Bef DW sink1	S		<b>2.63</b>
Main	-	Kitchen	05-OP-Bef DW sink2	S		1.68
Main	-	Cafeteria	06-OP-WF	WF		0
Main	-	Cafeteria	07-OP-WF Lone	WF		0
Main	-	Cafeteria	08-OP-BF	BF		0
Main	-	Hall-near Gym	09-OP-WF	WF		1.01
Main	-	Hall-near Gym	10-OP-BF	BF		1.13
Main	-	Hall-near Gym	11-OP-WF Lone	WF		0
Main	-	Hall Near exit 9N	12-OP-BF	BF		0
Main	-	Hall Near exit 9N	13-OP-WF	WF		0
Main	132	Classroom	14-OP-132 sink	S		0
Main	133	Classroom	15-OP-133 sink	S		0
Main	129	Classroom	16-OP-129 sink	S		0
Main	125	Classroom	17-OP-125 sink South	S		0
Main	125	Classroom	18-OP-Dish Wash sink	S		1.38
Main	121	Classroom	19-OP-121 sink	S		1.85
Main	117	Classroom	20-OP-117 sink	S		0
Main	-	Staff Lounge	21-OP-LOUNGE W SINK	S		0.92
Main	-	Staff Lounge	22-OP-LOUNGE E SINK	S		0.55
Main	111	Classroom	23-OP-111 SINK	S		0.83
Main	109	Classroom	24-OP-109 SINK	S		1.16
Main	105 near exit 5N	Classroom	25-OP-SINK NEAR 5N	S		1.72
Main	101	Classroom	26-OP-101 SINK	S		0
Main	100	Classroom	27-OP-FAR LEFT SINK	S		0.54
Main	100	Classroom	28-OP-SINK2	S		0.66
Main	100	Classroom	29-OP-SINK3	S		1.58
Main	100	Classroom	30-OP-FAR RIGHT SINK	S		0.86
Main	-	Hall Acc from 107	31-OP-WF LONE	WF		0
Main	-	Hall Acc from 107	32-OP-BF	BF		0
Main	-	Hall Acc from 107	33-OP-WF	WF		0
Main	-	Library	34-OP-LIBRARY SINK	S		1.1
Second	-	Hall Acc from 207	35-OP-HALL ACC 207WF	WF		0
Second	-	Hall Acc from 207	36-OP-HALL ACC 207BF	BF		0
Second	205	Classroom	37-OP-205 SINK	S		<b>2.25</b>
Second	207	Classroom	38-OP-207 SINK	S		<b>2.23</b>
Second	209	Classroom	39-OP-209 SINK	S		0.76
Second	211	Classroom	40-OP-211 SINK	S		0.52
Second	213	Classroom	41-OP-213 SINK	S		<b>3.86</b>
Second	215	Classroom	42-OP-215 SINK	S		0.93
Second	217	Classroom	43-OP-217-SINK	S		1.06
Second	219	Classroom	44-OP-219-SINK	S		0
Main	-	Nurse Office	45-OP-NURSE SINK	S		0