



Tamalpais Union High School District Redwood High School Ghilotti Field Site Improvements Project – BID #101

Addendum No. 02

February 20, 2025

Owner:

Tamalpais Union High School District
395 Doherty Drive
Larkspur, CA 94939

This addendum shall supersede all previously issued specifications, addenda, and drawings wherein this addendum contradicts previously issued documents. All other conditions remain unchanged. The following changes, modifications, corrections, clarifications, and / or additions as set forth herein shall apply to the above documents and shall be made a part thereof and shall be subject to all the requirements thereof as though originally specified and / or shown. This addendum must be acknowledged on the bid form.

General:

1. Will the district and A&E look at other synthetic turf system options besides Fieldturf? Shaw Sports Turf would love to be in the mix, and I wanted to see what I can do on my end to make that happen. Please let me know.
 - The synthetic turf replacement of the athletic field is not part of the bid package.
2. Question on drawings. It subject is T2 synthetic turf connections. Looking at drawing L05.00 the T2 turf goes on south side and west side. I see the connection when it ties into net wall on west side but on south side it connects to detail L06.01 detail 03. What does turf connect to on side towards creek.
 - Attach turf to existing concrete border (Fence Edgeband).
 - Refer to T2 - SYNTHETIC TURF WITH SAND INFILL detail 03/L06.01.
 - Refer to Existing Fence Edgeband detail H/D2.0 (ATTACHED)

- Note that the intention of the turf is to have a cross slope of less than 2% at path of travel shown plan. The slope may be steeper where needed at drain inlets. The elevation of the nailer should reflect this proposed condition.

This Addendum consists of Three (3) pages including attachment.

Attachment: D2.0 - CONSTRUCTION DETAILS (Reference Document)

621 W Spain Street • Sonoma, CA 95476
707-933-0624 • Fax 707-996-8390

End of Addendum No. 2

