



June 21, 2024

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Prairie Crossing Elementary School
11605 S. Bradbury Ranch Drive, Parker, CO 80134
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Prairie Crossing Elementary School, located at 11605 S. Bradbury Ranch Drive in Parker, Colorado.

Fifty-five (55) AirChek radon test kits were placed on June 11, 2024, and were retrieved on June 13, 2024. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Jake Gamble".

Jake Gamble
Industrial Hygienist

A handwritten signature in black ink, appearing to read "Larry Head".

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:
PRARIE CROSSING ELEM

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11551105	102	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	1.4	2024-06-17
11551102	103	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	1.2	2024-06-17
11551106	107	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	1.6	2024-06-17
11550900	126	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.7	2024-06-17
11550899	128	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	1.0	2024-06-17
11550886	131	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	1.0	2024-06-17
11550887	132	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.7	2024-06-17
11550884	133	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.7	2024-06-17
11550885	133 (D)	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.7	2024-06-17
11550888	134	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.9	2024-06-17
11550889	135	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	1.1	2024-06-17
11550882	140	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.6	2024-06-17
11550868	143	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.0	2024-06-17
11550871	144	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	0.8	2024-06-17
11550872	145	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	0.9	2024-06-17
11550874	145 (B)	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	< 0.3	2024-06-17
11550873	145 (D)	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	0.7	2024-06-17
11550870	146	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	0.7	2024-06-17
11550869	150	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.0	2024-06-17
11550867	153	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	0.8	2024-06-17
11550866	155	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.2	2024-06-17
11550855	165	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.1	2024-06-17
11550854	166	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.2	2024-06-17
11550853	167	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.1	2024-06-17
11550857	170	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.1	2024-06-17
11550861	174	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	0.8	2024-06-17
11550862	174 (D)	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	0.8	2024-06-17
11550863	177	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	0.9	2024-06-17
11550864	178	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.1	2024-06-17
11550865	179	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	0.9	2024-06-17
11550860	180	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.0	2024-06-17
11550859	181	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	0.8	2024-06-17
11550858	182	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	0.7	2024-06-17
11550878	274	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.0	2024-06-17
11550879	277	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	0.8	2024-06-17
11550880	278	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	0.8	2024-06-17
11550881	279	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	< 0.3	2024-06-17

June 17, 2024

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
PRARIE CROSSING ELEM

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11550877	280	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	0.8	2024-06-17
11550876	281	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	< 0.3	2024-06-17
11550875	282	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	0.6	2024-06-17
11550893	374	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	1.0	2024-06-17
11550894	377	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.7	2024-06-17
11550895	378	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	1.1	2024-06-17
11550897	378 (B)	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	< 0.3	2024-06-17
11550896	378 (D)	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.7	2024-06-17
11550898	379	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.5	2024-06-17
11550892	380	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.6	2024-06-17
11550891	381	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.7	2024-06-17
11550890	382	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	1.0	2024-06-17
11551101	CAFETERIA	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	1.5	2024-06-17
11551103	GYM	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	1.6	2024-06-17
11551104	GYM OFFICE	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	1.9	2024-06-17
11550856	MAIL ROOM	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.0	2024-06-17
11550852	MAIN OFFICE	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.3	2024-06-17
11550883	PHONE ROOM	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.9	2024-06-17

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498