



June 21, 2024

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Redstone Elementary School
9970 Glenstone Circle, Highlands Ranch, CO 80130
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Redstone Elementary School, located at 9970 Glenstone Circle in Highlands Ranch, Colorado.

Forty-seven (47) AirChek radon test kits were placed on June 12, 2024, and forty-five (45) were retrieved on June 14, 2024. Two (2) AirChek test kits were missing at the time of our retrieval from Rooms M07 and M35. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Jake Gamble".

Jake Gamble
Industrial Hygienist

A handwritten signature in black ink, appearing to read "Larry Head".

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:
REDSTONE ELEM

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11551173	CAFETERIA	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	< 0.3	2024-06-17
11551187	ENGINEER OFFICE	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	2.6	2024-06-17
11551171	GYM N	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	< 0.3	2024-06-17
11551174	KITCHEN OFFICE	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	< 0.3	2024-06-17
11551183	L07	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.8	2024-06-17
11551184	L11	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	1.0	2024-06-17
11551185	L12	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.6	2024-06-17
11551186	L13	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.7	2024-06-17
11551182	L14	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	< 0.3	2024-06-17
11551181	L15	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	< 0.3	2024-06-17
11551180	L16	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	< 0.3	2024-06-17
11551199	M11	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.8	2024-06-17
11551001	M11 (B)	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	< 0.3	2024-06-17
11551200	M11 (D)	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.9	2024-06-17
11551198	M12	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	1.0	2024-06-17
11551197	M13	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	1.2	2024-06-17
11551195	M14	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.7	2024-06-17
11551194	M15	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.7	2024-06-17
11551193	M16	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.9	2024-06-17
11551192	M20	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.8	2024-06-17
11551190	M22	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.7	2024-06-17
11551191	M24	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.8	2024-06-17
11551002	M28	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	< 0.3	2024-06-17
11551159	M36	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.5	2024-06-17
11551158	M38	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.6	2024-06-17
11551160	M41	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.6	2024-06-17
11551179	M45	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.8	2024-06-17
11551188	M48	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.8	2024-06-17
11551189	M48 (D)	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.8	2024-06-17
11551176	M50	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.8	2024-06-17
11551178	M50 (B)	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	< 0.3	2024-06-17
11551177	M50 (D)	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.5	2024-06-17
11551175	M51	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.7	2024-06-17
11551172	M57	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.6	2024-06-17
11551162	M58	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.6	2024-06-17
11551169	M60	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	< 0.3	2024-06-17
11551161	M61	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.5	2024-06-17

June 17, 2024

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
REDSTONE ELEM

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11551163	M63	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	< 0.3	2024-06-17
11551168	M64	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	< 0.3	2024-06-17
11551167	M65	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.7	2024-06-17
11551165	M66	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.6	2024-06-17
11551166	M66 (D)	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.7	2024-06-17
11551164	M68	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.5	2024-06-17
11551170	M70	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	0.6	2024-06-17
11551156	MAIN OFFICE	2024-06-12 @ 9:00 am	2024-06-14 @ 10:00 am	< 0.3	2024-06-17