



June 5, 2024

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Sage Canyon Elementary School
2420 Autumn Sage Court, Castle Rock, CO 80108
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Sage Canyon Elementary School, located at 2420 Autumn Sage Court in Castle Rock, Colorado.

Forty-eight (48) AirChek radon test kits were placed on May 29, 2024, and forty-three (43) were retrieved on May 31, 2024. Five (5) AirChek radon kit was missing from Rooms A101A, A101B, A101F, A101G, and Main Office at the time of our retrieval. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Jake Gamble".

Jake Gamble
Industrial Hygienist

A handwritten signature in black ink, appearing to read "Larry Head".

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:
SAGE CANYON ES

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11536435	A102	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.7	2024-06-03
11536442	A106	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536434	A110	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.5	2024-06-03
11536436	A111	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536437	A112	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536438	A112 (D)	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.6	2024-06-03
11536439	A113	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.6	2024-06-03
11536476	B101	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536475	B102	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536471	B105	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536473	B105 (B)	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536472	B105 (D)	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536470	B106	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536469	B107	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536464	B108	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536465	B110	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536468	B111	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536466	B112	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536467	B112A	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.5	2024-06-03
11536446	B121	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536447	B122	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.8	2024-06-03
11536452	B123	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536453	B124	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.5	2024-06-03
11536454	B125	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536455	B126	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536456	B127	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536457	B128	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536458	B129	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536459	B130	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.5	2024-06-03
11536460	B131	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.7	2024-06-03
11536461	B131 (D)	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536462	B131A	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536463	B131B	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536474	B203	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536443	CAFETERIA	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536445	CAFETERIA OFFICE	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536444	ENGINEER OFFICE	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.6	2024-06-03

June 4, 2024

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
SAGE CANYON ES

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11536440	GYM	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536441	GYM OFFICE	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.6	2024-06-03
11536448	LIBRARY	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536450	LIBRARY (B)	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536449	LIBRARY (D)	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536451	MEDIA SPECIALIST	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498