



May 30, 2024

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Trailblazer Elementary School
9760 S. Hackberry Street, Highlands Ranch, CO 80129
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Trailblazer Elementary School, located at 9760 S. Hackberry Street in Highlands Ranch, Colorado.

Fifty (50) AirChek radon test kits were placed on May 22, 2024, and forty-eight (48) were retrieved on May 24, 2024. Two (2) AirChek radon kits were missing from Room 506 and 507 at the time of our retrieval. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Jake Gamble".

Jake Gamble
Industrial Hygienist

A handwritten signature in black ink, appearing to read "Larry Head".

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:
TRAILBLAZER ELEM.

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11536123	100S	2024-05-22 @ 8:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536120	101	2024-05-22 @ 8:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536121	102	2024-05-22 @ 8:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536122	103	2024-05-22 @ 8:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536129	104	2024-05-22 @ 8:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536130	105	2024-05-22 @ 8:00 am	2024-05-24 @ 9:00 am	0.6	2024-05-28
11536131	106	2024-05-22 @ 8:00 am	2024-05-24 @ 9:00 am	0.7	2024-05-28
11536134	201	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536135	202	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536136	203	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536139	204	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	0.7	2024-05-28
11536140	205	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536141	206	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	0.5	2024-05-28
11536137	207	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	0.7	2024-05-28
11536144	301	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536145	302	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536146	303	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536148	304	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536149	305	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	0.7	2024-05-28
11536150	306	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536147	307	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	0.6	2024-05-28
11536115	403	2024-05-22 @ 8:00 am	2024-05-24 @ 8:00 am	0.6	2024-05-28
11536108	404	2024-05-22 @ 8:00 am	2024-05-24 @ 8:00 am	1.2	2024-05-28
11536109	405	2024-05-22 @ 8:00 am	2024-05-24 @ 8:00 am	1.1	2024-05-28
11536110	407	2024-05-22 @ 8:00 am	2024-05-24 @ 8:00 am	< 0.3	2024-05-28
11536113	501	2024-05-22 @ 8:00 am	2024-05-24 @ 8:00 am	0.5	2024-05-28
11536119	503 CONFERENCE	2024-05-22 @ 8:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536124	504	2024-05-22 @ 8:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536127	505 SS	2024-05-22 @ 8:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536128	508	2024-05-22 @ 8:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536132	509	2024-05-22 @ 8:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536133	510	2024-05-22 @ 8:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536138	511	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536142	512	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536143	513	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11536104	514C	2024-05-22 @ 8:00 am	2024-05-24 @ 8:00 am	< 0.3	2024-05-28
11536103	514D	2024-05-22 @ 8:00 am	2024-05-24 @ 8:00 am	0.6	2024-05-28

May 28, 2024

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
TRAILBLAZER ELEM.

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11536102	514E	2024-05-22 @ 8:00 am	2024-05-24 @ 8:00 am	< 0.3	2024-05-28
11536105	BATES	2024-05-22 @ 8:00 am	2024-05-24 @ 8:00 am	< 0.3	2024-05-28
11536116	CAFETERIA	2024-05-22 @ 8:00 am	2024-05-24 @ 9:00 am	1.4	2024-05-28
11536117	CAFETERIA OFFICE	2024-05-22 @ 8:00 am	2024-05-24 @ 9:00 am	0.7	2024-05-28
11536111	GYM N	2024-05-22 @ 8:00 am	2024-05-24 @ 8:00 am	< 0.3	2024-05-28
11536112	GYM S	2024-05-22 @ 8:00 am	2024-05-24 @ 8:00 am	< 0.3	2024-05-28
11536101	MAIN OFFICE	2024-05-22 @ 8:00 am	2024-05-24 @ 8:00 am	0.7	2024-05-28
11536106	OFFICE	2024-05-22 @ 8:00 am	2024-05-24 @ 8:00 am	< 0.3	2024-05-28
11536107	ROOM BEHIND 514D	2024-05-22 @ 8:00 am	2024-05-24 @ 8:00 am	< 0.3	2024-05-28
11536114	TECH ROOM - MISSING	2024-05-22 @ 8:00 am	2024-05-24 @ 8:00 am	0.6	2024-05-28

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498