



May 30, 2024

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Copper Mesa Elementary School
3501 Poston Parkway, Highlands Ranch, CO 80129
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Copper Mesa Elementary School, located at 3501 Poston Parkway in Highlands Ranch, Colorado.

Forty-nine (49) AirChek radon test kits were placed on May 22, 2024, and retrieved on May 24, 2024. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Jake Gamble".

Jake Gamble
Industrial Hygienist

A handwritten signature in black ink, appearing to read "Larry Head".

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:
COPPER MESA ELEM.

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11451435	CAFÉ OFFICE	2024-05-22 @ 9:00 am	2024-05-24 @ 10:00 am	0.7	2024-05-28
11451433	CAFETERIA	2024-05-22 @ 9:00 am	2024-05-24 @ 10:00 am	0.9	2024-05-28
11451434	CAFETERIA (D)	2024-05-22 @ 9:00 am	2024-05-24 @ 10:00 am	1.6	2024-05-28
11451436	GYM N	2024-05-22 @ 10:00 am	2024-05-24 @ 10:00 am	0.9	2024-05-28
11451437	GYM S	2024-05-22 @ 10:00 am	2024-05-24 @ 10:00 am	< 0.3	2024-05-28
11451425	L07	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	0.6	2024-05-28
11451421	L11	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	0.5	2024-05-28
11451423	L11 (B)	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11451422	L11 (D)	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	0.6	2024-05-28
11451420	L12	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11451424	L13	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11451426	L14	2024-05-22 @ 9:00 am	2024-05-24 @ 10:00 am	0.7	2024-05-28
11451427	L15	2024-05-22 @ 9:00 am	2024-05-24 @ 10:00 am	< 0.3	2024-05-28
11451428	L16	2024-05-22 @ 9:00 am	2024-05-24 @ 10:00 am	< 0.3	2024-05-28
11451412	M07	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	0.6	2024-05-28
11451408	M11	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	0.5	2024-05-28
11451410	M113	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11451411	M113 (D)	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	0.8	2024-05-28
11451413	M114	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11451414	M115	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	0.9	2024-05-28
11451415	M116	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	0.7	2024-05-28
11451409	M12	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11451416	M22	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	0.7	2024-05-28
11451418	M24	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11451405	M27	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	0.6	2024-05-28
11451406	M28	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	0.9	2024-05-28
11451403	M34	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11451402	M35	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11451404	M38	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11451429	M41	2024-05-22 @ 9:00 am	2024-05-24 @ 10:00 am	< 0.3	2024-05-28
11451419	M45	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	0.7	2024-05-28
11451417	M48	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11451430	M50	2024-05-22 @ 9:00 am	2024-05-24 @ 10:00 am	0.8	2024-05-28
11451431	M51	2024-05-22 @ 9:00 am	2024-05-24 @ 10:00 am	0.7	2024-05-28
11451438	M57	2024-05-22 @ 10:00 am	2024-05-24 @ 10:00 am	0.6	2024-05-28
11451439	M58	2024-05-22 @ 10:00 am	2024-05-24 @ 10:00 am	0.5	2024-05-28
11451440	M61	2024-05-22 @ 10:00 am	2024-05-24 @ 10:00 am	1.2	2024-05-28

May 28, 2024

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
COPPER MESA ELEM.

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11451445	M62	2024-05-22 @ 10:00 am	2024-05-24 @ 10:00 am	1.0	2024-05-28
11451447	M62 (B)	2024-05-22 @ 10:00 am	2024-05-24 @ 10:00 am	< 0.3	2024-05-28
11451446	M62 (D)	2024-05-22 @ 10:00 am	2024-05-24 @ 10:00 am	0.6	2024-05-28
11451441	M63	2024-05-22 @ 10:00 am	2024-05-24 @ 10:00 am	1.0	2024-05-28
11451448	M64	2024-05-22 @ 10:00 am	2024-05-24 @ 10:00 am	0.8	2024-05-28
11451443	M66	2024-05-22 @ 10:00 am	2024-05-24 @ 10:00 am	0.7	2024-05-28
11451442	M68	2024-05-22 @ 10:00 am	2024-05-24 @ 10:00 am	0.8	2024-05-28
11451449	M69	2024-05-22 @ 10:00 am	2024-05-24 @ 10:00 am	0.8	2024-05-28
11451444	M70	2024-05-22 @ 10:00 am	2024-05-24 @ 10:00 am	0.9	2024-05-28
11451407	M87	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	< 0.3	2024-05-28
11451401	MAIN OFFICE	2024-05-22 @ 9:00 am	2024-05-24 @ 9:00 am	0.8	2024-05-28
11451432	PHONE ROOM	2024-05-22 @ 9:00 am	2024-05-24 @ 10:00 am	0.8	2024-05-28