



July 3, 2024

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Eldorado Elementary School
1305 W Timbervale Trail, Highlands Ranch, CO 80129
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Eldorado Elementary School, located at 1305 W Timbervale Trail in Highlands Ranch, Colorado.

Fifty-six (56) AirChek radon test kits were placed on June 18, 2024, and fifty-six (56) were retrieved on June 20, 2024. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Jake Gamble".

Jake Gamble
Industrial Hygienist

A handwritten signature in black ink, appearing to read "Larry Head".

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:**ELDORADO ELEMENTARY**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11546212	102	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.7	2024-06-24
11546215	103	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	2.3	2024-06-24
11546216	103 (D)	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.7	2024-06-24
11546211	107	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.5	2024-06-24
11546221	128	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.1	2024-06-24
11546232	133	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.3	2024-06-24
11546233	133 ROOM 1	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.2	2024-06-24
11546234	133 ROOM 2	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.3	2024-06-24
11546235	133 ROOM 3	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.4	2024-06-24
11546236	133 ROOM 4	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.0	2024-06-24
11546237	133 ROOM 5	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.0	2024-06-24
11546222	135	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.2	2024-06-24
11546238	140	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.1	2024-06-24
11546239	140 (D)	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	0.8	2024-06-24
11546240	143	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	0.9	2024-06-24
11546217	144	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.2	2024-06-24
11546241	150	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.2	2024-06-24
11546242	151	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.1	2024-06-24
11546252	153	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.0	2024-06-24
11546253	155	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.3	2024-06-24
11546261	160	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.0	2024-06-24
11546262	160 (D)	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	0.8	2024-06-24
11546209	166	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	0.9	2024-06-24
11546210	167	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.0	2024-06-24
11546207	170	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.1	2024-06-24
11546257	174	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	0.7	2024-06-24
11546254	177	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.0	2024-06-24
11546255	178	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	0.6	2024-06-24
11546256	179	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	< 0.3	2024-06-24
11546260	180	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	0.8	2024-06-24
11546259	181	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	0.9	2024-06-24
11546258	182	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	0.8	2024-06-24
11546246	274	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.0	2024-06-24
11546243	277	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	0.9	2024-06-24
11546244	278	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	0.7	2024-06-24
11546245	279	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.0	2024-06-24
11546249	280	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	0.7	2024-06-24

July 1, 2024

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

ELDORADO ELEMENTARY

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11546251	280 (B)	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	< 0.3	2024-06-24
11546250	280 (D)	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	0.7	2024-06-24
11546248	281	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	0.7	2024-06-24
11546247	282	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.0	2024-06-24
11546226	374	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	< 0.3	2024-06-24
11546228	374 (B)	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	< 0.3	2024-06-24
11546227	374 (D)	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	< 0.3	2024-06-24
11546223	377	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	< 0.3	2024-06-24
11546224	378	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	< 0.3	2024-06-24
11546225	379	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	< 0.3	2024-06-24
11546231	380	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	0.5	2024-06-24
11546230	381	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	0.6	2024-06-24
11546229	382	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	< 0.3	2024-06-24
11546220	ART ROOM	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.4	2024-06-24
11546218	CAFETERIA	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.8	2024-06-24
11546213	GYM	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.8	2024-06-24
11546214	GYM OFFICE	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	2.2	2024-06-24
11546208	MAIL ROOM	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.1	2024-06-24
11546206	MAIN OFFICE	2024-06-18 @ 12:00 pm	2024-06-20 @ 1:00 pm	1.0	2024-06-24