



June 5, 2024

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Flagstone Elementary School
104 Lovington Street, Castle Rock, CO 80104
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Flagstone Elementary School, located at 104 Lovington Street in Castle Rock, Colorado.

Fifty-nine (59) AirChek radon test kits were placed on May 29, 2024, and were retrieved on May 31, 2024. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Jake Gamble".

Jake Gamble
Industrial Hygienist

A handwritten signature in black ink, appearing to read "Larry Head".

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:**FLAGSTONE ELEMENTARY**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11536555	104	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	1.0	2024-06-03
11536559	107	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536558	110	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.6	2024-06-03
11536556	111	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.8	2024-06-03
11536557	111(D)	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.6	2024-06-03
11536554	112	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536553	113	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.7	2024-06-03
11536552	114	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.7	2024-06-03
11536508	15	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536512	2	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536542	204	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.8	2024-06-03
11536539	207	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.6	2024-06-03
11536540	210	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.5	2024-06-03
11536541	211	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.6	2024-06-03
11536543	212	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.8	2024-06-03
11536544	213	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.6	2024-06-03
11536546	213 (B)	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536545	213 (D)	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.7	2024-06-03
11536547	214	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.6	2024-06-03
11536549	218	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.8	2024-06-03
11536516	26	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536517	28	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.7	2024-06-03
11536518	30	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.8	2024-06-03
11536524	304	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	1.6	2024-06-03
11536519	307	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.9	2024-06-03
11536507	31	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536520	310	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.7	2024-06-03
11536521	311	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.8	2024-06-03
11536523	311 (B)	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536522	311 (D)	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.8	2024-06-03
11536525	312	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	1.0	2024-06-03
11536526	313	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.9	2024-06-03
11536527	314	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.7	2024-06-03
11536531	34	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536532	35	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.7	2024-06-03
11536529	36	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.8	2024-06-03
11536535	37	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.6	2024-06-03

Radon test result report for:**FLAGSTONE ELEMENTARY**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11536530	38	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.7	2024-06-03
11536538	43	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536550	46	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.6	2024-06-03
11536513	47	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.5	2024-06-03
11536548	50	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.6	2024-06-03
11536551	53	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.6	2024-06-03
11536528	6	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.7	2024-06-03
11536504	63	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.7	2024-06-03
11536505	66	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.7	2024-06-03
11536506	67	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536502	70	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.6	2024-06-03
11536514	CAFETERIA	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.5	2024-06-03
11536509	GYM N	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536510	GYM S	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536511	GYM S (D)	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536515	KITCHEN OFFICE	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	< 0.3	2024-06-03
11536503	MAIL ROOM	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.5	2024-06-03
11536501	MAIN OFFICE	2024-05-29 @ 9:00 am	2024-05-31 @ 10:00 am	0.6	2024-06-03
11536537	PHONE ROOM	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.5	2024-06-03
11536536	STAFF LOUNGE	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.5	2024-06-03
11536533	WORK ROOM	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.5	2024-06-03
11536534	WORK ROOM (D)	2024-05-29 @ 10:00 am	2024-05-31 @ 10:00 am	0.5	2024-06-03