



June 21, 2024

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Gold Rush Elementary School
12021 S. Swift Fox Way, Parker, CO 80134
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Gold Rush Elementary School, located at 12021 S. Swift Fox Way, in Parker, Colorado.

Fifty-one (51) AirChek radon test kits were placed on June 11, 2024, and were retrieved on June 13, 2024. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Jake Gamble".

Jake Gamble
Industrial Hygienist

A handwritten signature in black ink, appearing to read "Larry Head".

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:
GOLD RUSH ELEM

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11550802	A101A	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.2	2024-06-17
11550803	A101B	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.3	2024-06-17
11550805	A101F	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	0.5	2024-06-17
11550806	A101G	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.2	2024-06-17
11550807	A101H	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.2	2024-06-17
11550808	A102	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.6	2024-06-17
11550820	A106	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.5	2024-06-17
11550809	A110	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.9	2024-06-17
11550813	A110B	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.7	2024-06-17
11550810	A111	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.5	2024-06-17
11550811	A111 (D)	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.1	2024-06-17
11550812	A111B	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.8	2024-06-17
11550814	A112	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.5	2024-06-17
11550815	A113	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.6	2024-06-17
11550850	B101	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.9	2024-06-17
11550851	B102	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.8	2024-06-17
11550825	B104	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	1.0	2024-06-17
11550826	B104A	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	1.0	2024-06-17
11550849	B105	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.7	2024-06-17
11550848	B106	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	1.1	2024-06-17
11550847	B107	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.7	2024-06-17
11550840	B108	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	1.1	2024-06-17
11550839	B109	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.6	2024-06-17
11550841	B110	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.7	2024-06-17
11550842	B111	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.6	2024-06-17
11550843	B112	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.8	2024-06-17
11550844	B112A	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.7	2024-06-17
11550846	B112A (B)	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	< 0.3	2024-06-17
11550845	B112A (D)	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	1.0	2024-06-17
11550821	B121	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	0.6	2024-06-17
11550823	B121 (B)	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	< 0.3	2024-06-17
11550822	B121 (D)	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	0.6	2024-06-17
11550824	B122	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.8	2024-06-17
11550828	B123	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.5	2024-06-17
11550827	B124	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.9	2024-06-17
11550829	B125	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.7	2024-06-17
11550830	B126	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.8	2024-06-17

June 17, 2024

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

GOLD RUSH ELEM

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11550831	B127	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	1.0	2024-06-17
11550832	B128	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.6	2024-06-17
11550838	B129	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	1.1	2024-06-17
11550833	B130	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.7	2024-06-17
11550834	B130 (D)	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.7	2024-06-17
11550835	B131	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.9	2024-06-17
11550836	B131A	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.6	2024-06-17
11550837	B131B	2024-06-11 @ 1:00 pm	2024-06-13 @ 1:00 pm	0.8	2024-06-17
11550818	CAFETERIA	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.7	2024-06-17
11550804	COPY ROOM	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.2	2024-06-17
11550819	ENGINEER	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.7	2024-06-17
11550816	GYM	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	0.9	2024-06-17
11550817	GYM OFFICE	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.0	2024-06-17
11550801	MAIN OFFICE	2024-06-11 @ 12:00 pm	2024-06-13 @ 1:00 pm	1.2	2024-06-17

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498