



June 21, 2024

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Heritage Elementary School
6867 E. Heritage Place South, Centennial, CO 80111
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Heritage Elementary School, located at 6867 E. Heritage Place South in Centennial, Colorado.

Fifty-five (55) AirChek radon test kits were placed on June 10, 2024, and were retrieved on June 12, 2024. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Jake Gamble".

Jake Gamble
Industrial Hygienist

A handwritten signature in black ink, appearing to read "Larry Head".

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:
HERITAGE ELEM

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11546493	102	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	0.9	2024-06-17
11546489	103	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	0.9	2024-06-17
11546494	107	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	0.8	2024-06-17
11546492	113	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	1.0	2024-06-17
11546484	128	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546599	130	2024-06-10 @ 2:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546598	132	2024-06-10 @ 2:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546563	133	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546597	134	2024-06-10 @ 2:00 pm	2024-06-14 @ 2:00 pm	< 0.3	2024-06-17
11546596	135	2024-06-10 @ 2:00 pm	2024-06-13 @ 2:00 pm	< 0.3	2024-06-17
11546483	137	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546573	140	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546575	143	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546488	144	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	0.5	2024-06-17
11546487	145	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546584	146	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546585	150	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546586	153/155	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	0.5	2024-06-17
11546497	165	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546496	166	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546495	167	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546499	170	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546592	174	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546587	177	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546588	178	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546590	178 (B)	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546589	178 (D)	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546591	179\	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546593	180	2024-06-10 @ 2:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546594	181	2024-06-10 @ 2:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546595	182	2024-06-10 @ 2:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546580	274	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	0.6	2024-06-17
11546576	277	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546577	278	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546578	278 (D)	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546579	279	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546581	280	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17

June 17, 2024

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
HERITAGE ELEM

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11546582	281	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546583	282	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	0.6	2024-06-17
11546569	374	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546564	377	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546565	378	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546567	378 (B)	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546566	378 (D)	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546568	379	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546570	380	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546571	381	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546572	382	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546485	ART	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546486	CAFETERIA	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546491	GYM OFFICE	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546490	GYM OFFICE (D)	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	0.9	2024-06-17
11546498	MAIL ROOM	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546500	MAIN OFFICE	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17
11546574	PHONE ROOM	2024-06-10 @ 1:00 pm	2024-06-12 @ 2:00 pm	< 0.3	2024-06-17

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498