



July 3, 2024

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Legacy Point Elementary School
12736 Red Rosa Cir, Parker, CO 80134
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Legacy Point Elementary School, located at 12736 Red Rosa Circle in Parker, Colorado.

Forty-seven (47) AirChek radon test kits were placed on June 18, 2024, and forty-six (46) were retrieved on June 20, 2024. One (1) AirChek radon kit was missing from Room M24 at the time of our retrieval. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Jake Gamble".

Jake Gamble
Industrial Hygienist

A handwritten signature in black ink, appearing to read "Larry Head".

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:
LEGACY POINT ELEM

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11551030	CAFETERIA	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551015	COPY ROOM	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	0.6	2024-06-24
11551028	GYM	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551031	KITCHEN OFFICE	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551041	L07	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551042	L11	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551043	L12	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551044	L13	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551045	L13 (D)	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551040	L14	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551039	L15	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551038	L16	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	0.6	2024-06-24
11551046	L21	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551053	M07	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551058	M11	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551055	M12	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551057	M12 (B)	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551056	M12 (D)	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551054	M13	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551052	M14	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551051	M15	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551050	M16	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551047	M22	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551017	M27	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551016	M28	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551059	M30	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551013	M34	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	0.5	2024-06-24
11551014	M38	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551018	M41	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551037	M45	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	0.9	2024-06-24
11551032	M50	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551034	M50 (B)	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551033	M50 (D)	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551035	M51	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	0.5	2024-06-24
11551029	M57	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551019	M58	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	0.6	2024-06-24
11551020	M61	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24

July 1, 2024

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
LEGACY POINT ELEM

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11551024	M62	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551023	M63	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551025	M64	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551021	M68	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551022	M68 (D)	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551026	M69	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551027	M70	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551049	M87	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551012	MAIN OFFICE	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24
11551036	PHONE ROOM	2024-06-18 @ 10:00 am	2024-06-20 @ 11:00 am	< 0.3	2024-06-24

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498