



June 21, 2024

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Lone Tree Elementary School
9375 Heritage Hills Circle, Lone Tree, CO 80124
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Lone Tree Elementary School, located at 9375 Heritage Hills Circle in Lone Tree, Colorado.

Forty-nine (49) AirChek radon test kits were placed on June 12, 2024, and forty-eight (48) were retrieved on June 14, 2024. One (1) AirChek radon kit was missing from Room M68 at the time of our retrieval. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Jake Gamble".

Jake Gamble
Industrial Hygienist

A handwritten signature in black ink, appearing to read "Larry Head".

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:
LONE TREE ELEM

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11551120	ART ROOM	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551153	CAFETERIA	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551110	GYM N	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551111	GYM S	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551152	KITCHEN OFFICE	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551144	L07	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551141	L11	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551142	L12	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551143	L13	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551145	L14	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551146	L15	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	0.5	2024-06-17
11551147	L16	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551132	M07	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551127	M11	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551129	M11 (B)	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551128	M11 (D)	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551130	M12	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551131	M13	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551133	M14	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551134	M15	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551135	M16	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551136	M17	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551137	M18	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551124	M18	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551125	M19	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551139	M24	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551140	M24 (D)	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	0.6	2024-06-17
11551122	M35	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551123	M38	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551138	M45	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551148	M50	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551155	M57	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551107	M61	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551114	M62	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551109	M63	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551113	M66	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551115	M69	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17

June 17, 2024

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

LONE TREE ELEM

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11551116	M70	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551117	M70 (D)	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551118	M70A	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551119	M74	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551126	M87	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551121	MAIN OFFICE	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551108	MUSIC ROOM	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551150	PHONE ROOM	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551154	PHONE ROOM (B)	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17
11551151	PHONE ROOM (D)	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	0.6	2024-06-17
11551149	TEACHER BREAK ROOM	2024-06-12 @ 8:00 am	2024-06-14 @ 9:00 am	< 0.3	2024-06-17

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498