



July 3, 2024

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Mammoth Heights Elementary School
9500 Stonegate Pkwy, Parker, CO 80134
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Mammoth Heights Elementary School, located at 9500 Stonegate Parkway in Parker, Colorado.

Forty-five (45) AirChek radon test kits were placed on June 18, 2024, and forty-five (45) were retrieved on June 20, 2024. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Jake Gamble".

Jake Gamble
Industrial Hygienist

A handwritten signature in black ink, appearing to read "Larry Head".

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:**MAMMOTH HEIGHTS ELEM**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11546203	A1	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11546205	A1 (B)	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11546204	A1 (D)	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551099	A12	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551098	A14	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551095	A15	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551094	A17	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551096	A18	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	0.7	2024-06-24
11551097	A19	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551091	A21	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551092	A23	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551093	A23 (D)	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551090	A24	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551088	A26	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551086	A27	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	0.5	2024-06-24
11551089	A29	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551087	A31	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	0.8	2024-06-24
11551085	A33	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551084	A35	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551080	A36	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551082	A36 (B)	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551081	A36 (D)	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551078	A37	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11546202	A4	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551077	A43	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551083	A51	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551100	A8	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11546201	A9	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551076	ART	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551062	B12	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551063	B2	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551061	B3	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551067	B35	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	0.6	2024-06-24
11551068	B40	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551071	B45	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551069	B46	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	0.6	2024-06-24
11551070	B46 (D)	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	0.7	2024-06-24

July 1, 2024

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
MAMMOTH HEIGHTS ELEM

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11551066	B51	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551073	CAFETERIA	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	0.5	2024-06-24
11551074	CAFETERIA OFFICE	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551075	CUSTODIAL OFFICE	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551072	GYM	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551064	HEALTH	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551079	LIBRARY	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551060	MAIN OFFICE	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24
11551065	MUSIC	2024-06-18 @ 11:00 am	2024-06-20 @ 12:00 pm	< 0.3	2024-06-24

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498