



June 5, 2024

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Mesa Middle School
365 North Mitchell Street, Castle Rock, CO 80104
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Mesa Middle School, located at 365 North Mitchell Street in Castle Rock, Colorado.

Sixty-four (64) AirChek radon test kits were placed on May 29, 2024, and sixty-three (63) were retrieved on May 31, 2024. One (1) AirChek radon kit was missing from cafeteria north at the time of our retrieval. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Jake Gamble".

Jake Gamble
Industrial Hygienist

A handwritten signature in black ink, appearing to read "Larry Head".

Larry Head
CEO

Attachment: Laboratory Report

Radon test result report for:
MESA MIDDLE SCHOOL

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11536561	101	2024-05-29 @ 10:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536574	102	2024-05-29 @ 10:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536573	103	2024-05-29 @ 10:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536572	104	2024-05-29 @ 10:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536571	105	2024-05-29 @ 10:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536569	106	2024-05-29 @ 10:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536570	106 (D)	2024-05-29 @ 10:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536568	107	2024-05-29 @ 10:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536567	109	2024-05-29 @ 10:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536566	110	2024-05-29 @ 10:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536565	111	2024-05-29 @ 10:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536564	112	2024-05-29 @ 10:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536562	113	2024-05-29 @ 10:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536563	115	2024-05-29 @ 10:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536494	A101	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536496	A102	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536497	A103	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536493	A104	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536495	A105	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536576	A106	2024-05-29 @ 10:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536583	B101	2024-05-29 @ 11:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536586	B102	2024-05-29 @ 11:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536585	B103	2024-05-29 @ 11:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536580	B104	2024-05-29 @ 11:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536582	B104 (B)	2024-05-29 @ 11:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536581	B104 (D)	2024-05-29 @ 11:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536584	B105	2024-05-29 @ 11:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536579	B106	2024-05-29 @ 11:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536578	B107	2024-05-29 @ 11:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536589	C101	2024-05-29 @ 11:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536591	C102	2024-05-29 @ 11:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536592	C103	2024-05-29 @ 11:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536593	C103 (D)	2024-05-29 @ 11:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536588	C104	2024-05-29 @ 11:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536590	C105	2024-05-29 @ 11:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536587	C106	2024-05-29 @ 11:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536476	CAFETERIA S	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03

Radon test result report for:
MESA MIDDLE SCHOOL

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11536597	D101	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536599	D102	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536600	D103	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536477	D104	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536598	D105	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536483	E103	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536484	E104	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536485	E107	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536487	E107A	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536486	E108	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536488	E108A	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536479	GYM N	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536481	GYM N (B)	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536480	GYM N (D)	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536482	GYM S	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536478	KITCHEN OFFICE	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536575	M103	2024-05-29 @ 10:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536577	M104	2024-05-29 @ 10:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536594	M108	2024-05-29 @ 11:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03
11536595	M111	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536490	M117	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536489	M1176	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536491	M118	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536492	M118 (D)	2024-05-29 @ 11:00 am	2024-05-31 @ 12:00 pm	< 0.3	2024-06-03
11536560	MAIN OFFICE	2024-05-29 @ 10:00 am	2024-05-31 @ 11:00 am	< 0.3	2024-06-03