

ENVIRONMENTAL LABWORKS, INC.

June 7, 2024

Kingston Central School District
21 Wynkoop Place
Kingston, NY 12401

Dear James,

The following are results of the analyses performed on water samples from **Chambers Elementary School** received at the laboratory on 05/20/24.

Date/Time Collected: 05/18/24 7:54-9:17am First Draw
Collected By: Kingston CSD
Project ID: 05202419
Secondary ID: CH241847-96

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
01 Sink 05202419-1	EPA 200.8 Lead	0.0052 mg/L	X	0.005 mg/L	05/30/24
02 Kitchen Sink 05202419-2	EPA 200.8 Lead	0.0019 mg/L		0.005 mg/L	05/30/24
03 Sink 1 05202419-3	EPA 200.8 Lead	0.0025 mg/L		0.005 mg/L	05/30/24
03 Sink 2 05202419-4	EPA 200.8 Lead	0.0015 mg/L		0.005 mg/L	05/30/24
03 Sink 3 05202419-5	EPA 200.8 Lead	0.0014 mg/L		0.005 mg/L	05/30/24
04 Sink 1 05202419-6	EPA 200.8 Lead	0.0019 mg/L		0.005 mg/L	05/30/24
05 PT Sink 05202419-7	EPA 200.8 Lead	0.0013 mg/L		0.005 mg/L	05/30/24
06 Sink 1 05202419-8	EPA 200.8 Lead	0.0058 mg/L	X	0.005 mg/L	05/30/24
06 Sink 2 05202419-9	EPA 200.8 Lead	0.0021 mg/L		0.005 mg/L	05/30/24
07 Sink 1 05202419-10	EPA 200.8 Lead	0.0013 mg/L		0.005 mg/L	05/30/24

ENVIRONMENTAL LABWORKS, INC.

Chambers Middle School - 05202419

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
07 Sink 2 05202419-11	EPA 200.8 Lead	0.0013 mg/L		0.005 mg/L	05/30/24
08 Sink 1 05202419-12	EPA 200.8 Lead	0.0017 mg/L		0.005 mg/L	05/30/24
09 Sink 1 05202419-13	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/30/24
09 Sink 2 05202419-14	EPA 200.8 Lead	0.0063 mg/L	X	0.005 mg/L	05/30/24
10 Sink 1 05202419-15	EPA 200.8 Lead	0.0039 mg/L		0.005 mg/L	05/30/24
10 Bath Sink 2 05202419-16	EPA 200.8 Lead	0.0046 mg/L		0.005 mg/L	05/30/24
11 Bath Sink 1 05202419-17	EPA 200.8 Lead	0.0019 mg/L		0.005 mg/L	05/30/24
12 Sink 1 05202419-18	EPA 200.8 Lead	0.0021 mg/L		0.005 mg/L	05/30/24
12 Bath Sink 2 05202419-19	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/30/24
13 Bath Sink 1 05202419-20	EPA 200.8 Lead	0.0028 mg/L		0.005 mg/L	05/30/24
13 Sink 2 05202419-21	EPA 200.8 Lead	0.0024 mg/L		0.005 mg/L	05/30/24
14 Bath Sink 1 05202419-22	EPA 200.8 Lead	0.0011 mg/L		0.005 mg/L	05/30/24
14 Sink 2 05202419-23	EPA 200.8 Lead	0.0018 mg/L		0.005 mg/L	05/30/24
15 Bath Sink 1 05202419-24	EPA 200.8 Lead	0.0063 mg/L	X	0.005 mg/L	05/30/24
16 Bath Sink 1 05202419-25	EPA 200.8 Lead	0.0034 mg/L		0.005 mg/L	05/30/24

ENVIRONMENTAL LABWORKS, INC.

Chambers Elementary School - 05202419

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
17 Sink 1 05202419-26	EPA 200.8 Lead	0.0018 mg/L		0.005 mg/L	05/30/24
18 Sink 05202419-27	EPA 200.8 Lead	0.0030 mg/L		0.005 mg/L	05/30/24
19 Sink 1 05202419-28	EPA 200.8 Lead	0.0020 mg/L		0.005 mg/L	05/30/24
20 Sink 05202419-29	EPA 200.8 Lead	0.0214 mg/L	X	0.005 mg/L	05/30/24
21 Bath Sink 1 05202419-30	EPA 200.8 Lead	0.0027 mg/L		0.005 mg/L	05/30/24
21 Rm 11 Sink 2 05202419-31	EPA 200.8 Lead	0.0051 mg/L	X	0.005 mg/L	05/30/24
22 Sink 1 05202419-32	EPA 200.8 Lead	0.0035 mg/L		0.005 mg/L	05/30/24
22 Bath Sink 2 05202419-33	EPA 200.8 Lead	0.0059 mg/L	X	0.005 mg/L	05/30/24
23 Sink 1 05202419-34	EPA 200.8 Lead	0.0055 mg/L	X	0.005 mg/L	05/30/24
23 Bath Sink 2 05202419-35	EPA 200.8 Lead	0.0020 mg/L		0.005 mg/L	05/30/24
24 Bath Sink 1 05202419-36	EPA 200.8 Lead	0.0023 mg/L		0.005 mg/L	05/30/24
24 Sink 2 05202419-37	EPA 200.8 Lead	0.0062 mg/L	X	0.005 mg/L	05/30/24
25 Sink 1 05202419-38	EPA 200.8 Lead	0.0027 mg/L		0.005 mg/L	05/30/24
25 Bath Sink 2 05202419-39	EPA 200.8 Lead	0.0024 mg/L		0.005 mg/L	05/30/24
26 Bath Sink 1 05202419-40	EPA 200.8 Lead	0.0022 mg/L		0.005 mg/L	05/30/24

ENVIRONMENTAL LABWORKS, INC.

Chambers Elementary School - 05202419


LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
26 Room 15 Sink 2 05202419-41	EPA 200.8 Lead	0.0032 mg/L		0.005 mg/L	05/30/24
27 Bath Sink 1 05202419-42	EPA 200.8 Lead	0.0032 mg/L		0.005 mg/L	05/30/24
27 Sink 2 05202419-43	EPA 200.8 Lead	0.0036 mg/L		0.005 mg/L	05/30/24
28 Sink 1 05202419-44	EPA 200.8 Lead	0.0032 mg/L		0.005 mg/L	05/30/24
28 Bath Sink 2 05202419-45	EPA 200.8 Lead	0.0020 mg/L		0.005 mg/L	05/30/24
31 Bottle Fill 05202419-46	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/30/24
38 C-4 Sink 1 05202419-47	EPA 200.8 Lead	0.0097 mg/L	X	0.005 mg/L	05/30/24
48 Sink 1 05202419-48	EPA 200.8 Lead	0.0032 mg/L		0.005 mg/L	05/30/24
48 Bath Sink 2 05202419-49	EPA 200.8 Lead	0.0015 mg/L		0.005 mg/L	05/30/24
50 Bubbler Gym 05202419-50	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/30/24

Qualifier(Q):

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #10854. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director