

ENVIRONMENTAL LABWORKS, INC.

June 7, 2024

Kingston Central School District
21 Wynkoop Place
Kingston, NY 12401

Dear James,

The following are results of the analyses performed on water samples from **Crosby Elementary School** received at the laboratory on 05/20/24.

Date/Time Collected: 05/18/24 11:28-12:23pm First Draw
Collected By: Kingston CSD
Project ID: 05202416
Secondary ID: CY241718-45

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
74 girls sink 05202416-1	EPA 200.8 Lead	0.0051 mg/L	X	0.005 mg/L	05/30/24
75 bottle filler 05202416-2	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/30/24
75 room 16 sink 05202416-3	EPA 200.8 Lead	0.0086 mg/L	X	0.005 mg/L	05/30/24
76 room 15 sink 05202416-4	EPA 200.8 Lead	0.0078 mg/L	X	0.005 mg/L	05/30/24
77 room 17 sink 05202416-5	EPA 200.8 Lead	0.0140 mg/L	X	0.005 mg/L	05/30/24
78 art sink 05202416-6	EPA 200.8 Lead	0.0070 mg/L	X	0.005 mg/L	05/30/24
79 bath sink portable 05202416-7	EPA 200.8 Lead	0.0087 mg/L	X	0.005 mg/L	05/30/24
80 bath sink 1 portable 05202416-8	EPA 200.8 Lead	0.0200 mg/L	X	0.005 mg/L	05/30/24
79 sink 2 portable 05202416-9	EPA 200.8 Lead	0.0921 mg/L	X	0.005 mg/L	05/30/24
80 bath sink 2 portable 05202416-10	EPA 200.8 Lead	0.0380 mg/L	X	0.005 mg/L	05/30/24

ENVIRONMENTAL LABWORKS, INC.

Crosby Elementary School - 05202416

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
81 bath L sink 1 05202416-11	EPA 200.8 Lead	0.0105 mg/L	X	0.005 mg/L	05/30/24
81 bath R sink 2 05202416-12	EPA 200.8 Lead	0.0261 mg/L	X	0.005 mg/L	05/30/24
82 nurse sink 05202416-13	EPA 200.8 Lead	0.0069 mg/L	X	0.005 mg/L	05/30/24
83 faculty bk sink 05202416-14	EPA 200.8 Lead	0.0114 mg/L	X	0.005 mg/L	05/30/24
84 room 4 sink 05202416-15	EPA 200.8 Lead	0.0040 mg/L		0.005 mg/L	05/30/24
85 room 6 sink 05202416-16	EPA 200.8 Lead	0.0020 mg/L		0.005 mg/L	05/30/24
86 room 3 sink 05202416-17	EPA 200.8 Lead	0.0035 mg/L		0.005 mg/L	05/30/24
87 room 8 sink 05202416-18	EPA 200.8 Lead	0.0078 mg/L	X	0.005 mg/L	05/30/24
88 room 7 sink 05202416-19	EPA 200.8 Lead	0.0113 mg/L	X	0.005 mg/L	05/30/24
89 room 10 sink 05202416-20	EPA 200.8 Lead	0.0040 mg/L		0.005 mg/L	05/30/24
90 room 9 sink 05202416-21	EPA 200.8 Lead	0.0080 mg/L	X	0.005 mg/L	05/29/24
91 main bubbler 05202416-22	EPA 200.8 Lead	0.0016 mg/L		0.005 mg/L	05/29/24
92 room 2 sink 05202416-23	EPA 200.8 Lead	0.0032 mg/L		0.005 mg/L	05/29/24
93 room 1 sink 05202416-24	EPA 200.8 Lead	0.0055 mg/L	X	0.005 mg/L	05/29/24
94 bottle filler 05202416-25	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/29/24
95 Hnd sink 05202416-26	EPA 200.8 Lead	0.0055 mg/L	X	0.005 mg/L	05/29/24

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
NYSDOH #10824

ENVIRONMENTAL LABWORKS, INC.

Crosby Elementary School - 05202416


LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
96 left sink 05202416-27	EPA 200.8 Lead	0.0072 mg/L	X	0.005 mg/L	05/29/24
97 right sink 05202416-28	EPA 200.8 Lead	0.0124 mg/L	X	0.005 mg/L	05/29/24

Qualifier(Q):

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director