

ENVIRONMENTAL LABWORKS, INC.

June 7, 2024

Kingston Central School District
21 Wynkoop Place
Kingston, NY 12401

Dear James,

The following are results of the analyses performed on water samples from **Edson Elementary School** received at the laboratory on 05/20/24.

Date/Time Collected: 05/18/24 9:02-10:01am First Draw
Collected By: Kingston CSD
Project ID: 05202420
Secondary ID: ED241897-923

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
211 Kitchen Sink 05202420-1	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/29/24
212 Custodian Bath Sink 05202420-2	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/29/24
213 B-28 Sink 05202420-3	EPA 200.8 Lead	0.0083 mg/L	X	0.005 mg/L	05/29/24
214 B-27 Sink 05202420-4	EPA 200.8 Lead	0.0033 mg/L		0.005 mg/L	05/29/24
215 Café Bottle Fill 05202420-5	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/29/24
216 Café Bubbler 05202420-6	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/29/24
217 B-18 Sink 05202420-7	EPA 200.8 Lead	0.0044 mg/L		0.005 mg/L	05/29/24
218 B-17 Sink 05202420-8	EPA 200.8 Lead	0.0068 mg/L	X	0.005 mg/L	05/29/24
219 B-16 Sink 05202420-9	EPA 200.8 Lead	0.0021 mg/L		0.005 mg/L	05/29/24
220 B-15 Sink 05202420-10	EPA 200.8 Lead	0.0035 mg/L		0.005 mg/L	05/29/24

ENVIRONMENTAL LABWORKS, INC.

Edson Elementary School - 05202420

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
221 B-11 Sink 05202420-11	EPA 200.8 Lead	0.0763 mg/L	X	0.005 mg/L	05/29/24
222 A-4 Sink 05202420-12	EPA 200.8 Lead	0.0128 mg/L	X	0.005 mg/L	05/29/24
223 A-5 Sink Left 05202420-13	EPA 200.8 Lead	0.0014 mg/L		0.005 mg/L	05/29/24
224 A-5 Sink Right 05202420-14	EPA 200.8 Lead	0.0010 mg/L		0.005 mg/L	05/29/24
225 A2A Sink 05202420-15	EPA 200.8 Lead	0.0080 mg/L	X	0.005 mg/L	05/29/24
226 C-6 Sink 05202420-16	EPA 200.8 Lead	0.0080 mg/L	X	0.005 mg/L	05/29/24
227 C-15 Sink 05202420-17	EPA 200.8 Lead	0.0085 mg/L	X	0.005 mg/L	05/29/24
228 C-18 Sink 05202420-18	EPA 200.8 Lead	0.0439 mg/L	X	0.005 mg/L	05/29/24
229 C-14 Sink 05202420-19	EPA 200.8 Lead	0.0110 mg/L	X	0.005 mg/L	05/29/24
230 C-8 Sink 05202420-20	EPA 200.8 Lead	0.0044 mg/L		0.005 mg/L	05/29/24
231 C-9 Sink 05202420-21	EPA 200.8 Lead	0.0050 mg/L	X	0.005 mg/L	05/29/24
232 C-10 Sink 05202420-22	EPA 200.8 Lead	0.0045 mg/L		0.005 mg/L	05/29/24
233 C-5 Sink 05202420-23	EPA 200.8 Lead	0.0023 mg/L		0.005 mg/L	05/29/24
234 B-5 Sink 05202420-24	EPA 200.8 Lead	0.0016 mg/L		0.005 mg/L	05/29/24
235 B-4 Sink 05202420-25	EPA 200.8 Lead	0.0095 mg/L	X	0.005 mg/L	05/29/24
236 B-21 Sink 05202420-26	EPA 200.8 Lead	0.0140 mg/L	X	0.005 mg/L	05/29/24

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
NYSDOH #10824

ENVIRONMENTAL LABWORKS, INC.

Edson Elementary School - 05202420


LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
237 Nurse Sink 05202420-27	EPA 200.8 Lead	0.0037 mg/L		0.005 mg/L	05/29/24

Qualifier(Q):

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #10854. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director