

ENVIRONMENTAL LABWORKS, INC.

June 7, 2024

Kingston Central School District
21 Wynkoop Place
Kingston, NY 12401

Dear James,

The following are results of the analyses performed on water samples from **Meagher Pre-School** received at the laboratory on 05/20/24.

Date/Time Collected: 05/18/24 12:51-1:34pm First Draw
Collected By: Kingston CSD
Project ID: 05202415
Secondary ID: ME241694-717

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
98 kitchen sink 1 05202415-1	EPA 200.8 Lead	0.0619 mg/L	X	0.005 mg/L	05/30/24
98 kitchen sink 2 05202415-2	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/30/24
98 kitchen bath sink 05202415-3	EPA 200.8 Lead	0.0108 mg/L	X	0.005 mg/L	05/30/24
99 bath boys sink 05202415-4	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/30/24
100 bath girls sink 1 05202415-5	EPA 200.8 Lead	0.0024 mg/L		0.005 mg/L	05/30/24
100 bath girls sink 2 05202415-6	EPA 200.8 Lead	0.0021 mg/L		0.005 mg/L	05/30/24
101 bottle filler 05202415-7	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/30/24
102 back sink 1 05202415-8	EPA 200.8 Lead	0.0014 mg/L		0.005 mg/L	05/30/24
102 front sink 2 05202415-9	EPA 200.8 Lead	0.0073 mg/L	X	0.005 mg/L	05/30/24
103 faculty sink 05202415-10	EPA 200.8 Lead	0.0087 mg/L	X	0.005 mg/L	05/30/24

ENVIRONMENTAL LABWORKS, INC.

Meagher Pre-School - 05202415

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
105 faculty bath 05202415-11	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/30/24
106 room 4 sink 1 05202415-12	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/30/24
106 room 4 sink 2 05202415-13	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/30/24
107 room 3 sink 05202415-14	EPA 200.8 Lead	0.0013 mg/L		0.005 mg/L	05/30/24
108 room 2 sink 05202415-15	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/30/24
109 room 1 sink 05202415-16	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/30/24
110 bath W sink 1 st fl by elevator 05202415-17	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/30/24
111 bath M sink 1 st fl by elevator 05202415-18	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/30/24
112 bath 1 sink 2 nd fl by elevator 05202415-19	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/30/24
112 bath 2 sink 2 nd fl by elevator 05202415-20	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/30/24
113 kitchen sink 05202415-21	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/29/24
114 205 A sink 05202415-22	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/29/24
115 bottle filler by 104 05202415-23	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/29/24
104 reading rm bubbler 05202415-24	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/29/24

Qualifier(Q):

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.


PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
NYSDOH #10824

ENVIRONMENTAL LABWORKS, INC.

Meagher Pre-School - 05202415

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director