

## **ENVIRONMENTAL LABWORKS, INC.**

June 7, 2024

Kingston Central School District  
21 Wynkoop Place  
Kingston, NY 12401

Dear James,

The following are results of the analyses performed on water samples from **Miller Middle School** received at the laboratory on 05/20/24.

Date/Time Collected: 05/18/24 9:55-11:11am First Draw  
Collected By: Kingston CSD  
Project ID: 05202417  
Secondary ID: MM241746-76

| LOCATION/<br>SAMPLE ID          | PARAMETER         | RESULTS      | Q | ACTION LEVEL | ANALYZED |
|---------------------------------|-------------------|--------------|---|--------------|----------|
| 51 rm 172 sink<br>05202417-1    | EPA 200.8<br>Lead | 0.0336 mg/L  | X | 0.005 mg/L   | 05/29/24 |
| 52 bath sink<br>05202417-2      | EPA 200.8<br>Lead | 0.0123 mg/L  | X | 0.005 mg/L   | 05/29/24 |
| 53 sink 1 kitchen<br>05202417-3 | EPA 200.8<br>Lead | 0.0107 mg/L  | X | 0.005 mg/L   | 05/29/24 |
| 54 sink 2 kitchen<br>05202417-4 | EPA 200.8<br>Lead | 0.0067 mg/L  | X | 0.005 mg/L   | 05/29/24 |
| 55 sink 3 kitchen<br>05202417-5 | EPA 200.8<br>Lead | 0.0062 mg/L  | X | 0.005 mg/L   | 05/29/24 |
| 56 bottle filler<br>05202417-6  | EPA 200.8<br>Lead | <0.0010 mg/L |   | 0.005 mg/L   | 05/29/24 |
| 57 mid sink<br>05202417-7       | EPA 200.8<br>Lead | 0.0119 mg/L  | X | 0.005 mg/L   | 05/29/24 |
| 58 sink 1<br>05202417-8         | EPA 200.8<br>Lead | 0.0046 mg/L  |   | 0.005 mg/L   | 05/29/24 |
| 58 sink 2<br>05202417-9         | EPA 200.8<br>Lead | 0.0057 mg/L  | X | 0.005 mg/L   | 05/29/24 |
| 59 sink 1<br>05202417-10        | EPA 200.8<br>Lead | 0.0111 mg/L  | X | 0.005 mg/L   | 05/29/24 |

# ENVIRONMENTAL LABWORKS, INC.

Miller Middle School - 05202417

| LOCATION/<br>SAMPLE ID                  | PARAMETER         | RESULTS     | Q | ACTION LEVEL | ANALYZED |
|-----------------------------------------|-------------------|-------------|---|--------------|----------|
| 59 sink 2<br>05202417-11                | EPA 200.8<br>Lead | 0.0074 mg/L | X | 0.005 mg/L   | 05/29/24 |
| 60 sink 1<br>05202417-12                | EPA 200.8<br>Lead | 0.0483 mg/L | X | 0.005 mg/L   | 05/29/24 |
| 61 sink kitchen<br>05202417-13          | EPA 200.8<br>Lead | 0.0049 mg/L |   | 0.005 mg/L   | 05/29/24 |
| 62 sink main<br>05202417-14             | EPA 200.8<br>Lead | 0.0368 mg/L | X | 0.005 mg/L   | 05/29/24 |
| 64 Principal bath<br>05202417-15        | EPA 200.8<br>Lead | 0.0333 mg/L | X | 0.005 mg/L   | 05/29/24 |
| 63 sink 1<br>05202417-16                | EPA 200.8<br>Lead | 0.0094 mg/L | X | 0.005 mg/L   | 05/29/24 |
| 63 sink 2<br>05202417-17                | EPA 200.8<br>Lead | 0.0037 mg/L |   | 0.005 mg/L   | 05/29/24 |
| 63 sink 3<br>05202417-18                | EPA 200.8<br>Lead | 0.0039 mg/L |   | 0.005 mg/L   | 05/29/24 |
| 63 sink 4<br>05202417-19                | EPA 200.8<br>Lead | 0.0049 mg/L |   | 0.005 mg/L   | 05/29/24 |
| 65 sink 1<br>05202417-20                | EPA 200.8<br>Lead | 0.0700 mg/L | X | 0.005 mg/L   | 05/30/24 |
| 65 sink 2<br>05202417-21                | EPA 200.8<br>Lead | 0.0046 mg/L |   | 0.005 mg/L   | 05/29/24 |
| 65 sink 3<br>05202417-22                | EPA 200.8<br>Lead | 0.0040 mg/L |   | 0.005 mg/L   | 05/29/24 |
| 65 sink 4<br>05202417-23                | EPA 200.8<br>Lead | 0.0089 mg/L | X | 0.005 mg/L   | 05/29/24 |
| 66 sink 1<br>05202417-24                | EPA 200.8<br>Lead | 0.0115 mg/L | X | 0.005 mg/L   | 05/29/24 |
| 67 library upstairs sink<br>05202417-25 | EPA 200.8<br>Lead | 0.0106 mg/L | X | 0.005 mg/L   | 05/29/24 |
| 68 sink<br>05202417-26                  | EPA 200.8<br>Lead | 0.0341 mg/L | X | 0.005 mg/L   | 05/29/24 |

PO Box 733  
Marlboro, NY 12542  
Phone 845-236-7823  
Fax 845-236-3911  
NYSDOH #10824

## **ENVIRONMENTAL LABWORKS, INC.**

**Miller Middle School - 05202417**


| LOCATION/<br>SAMPLE ID          | PARAMETER         | RESULTS      | Q | ACTION LEVEL | ANALYZED |
|---------------------------------|-------------------|--------------|---|--------------|----------|
| 69 sink 1<br>05202417-27        | EPA 200.8<br>Lead | 0.0162 mg/L  | X | 0.005 mg/L   | 05/29/24 |
| 70 faculty sink<br>05202417-28  | EPA 200.8<br>Lead | 0.0119 mg/L  | X | 0.005 mg/L   | 05/29/24 |
| 71 bottle filler<br>05202417-29 | EPA 200.8<br>Lead | <0.0010 mg/L |   | 0.005 mg/L   | 05/29/24 |
| 72 sink 1<br>05202417-30        | EPA 200.8<br>Lead | 0.0144 mg/L  | X | 0.005 mg/L   | 05/29/24 |
| 73 bottle filler<br>05202417-31 | EPA 200.8<br>Lead | <0.0010 mg/L |   | 0.005 mg/L   | 05/29/24 |

**Qualifier(Q):**

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi  
Technical Director