

## **ENVIRONMENTAL LABWORKS, INC.**

---

June 7, 2024

Kingston Central School District  
21 Wynkoop Place  
Kingston, NY 12401

Dear James,

The following are results of the analyses performed on water samples from **Myer Elementary School** received at the laboratory on 05/20/24.

Date/Time Collected: 05/18/24 7:56-8:30am First Draw  
Collected By: Kingston CSD  
Project ID: 05202414  
Secondary ID: ME241683-93

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
200 room 23 sink 05202414-1	EPA 200.8 Lead	0.0091 mg/L	X	0.005 mg/L	05/30/24
201 room 22 sink 05202414-2	EPA 200.8 Lead	0.0026 mg/L		0.005 mg/L	05/30/24
202 bottle filler by gym 05202414-3	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/30/24
203 back kitchen sink 05202414-4	EPA 200.8 Lead	0.0215 mg/L	X	0.005 mg/L	05/30/24
204 front kitchen sink 05202414-5	EPA 200.8 Lead	0.0055 mg/L	X	0.005 mg/L	05/30/24
205 bottle filler cafe 05202414-6	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	05/30/24
206 room 10 sink 05202414-7	EPA 200.8 Lead	0.0020 mg/L		0.005 mg/L	05/30/24
207 room 1 sink 05202414-8	EPA 200.8 Lead	0.0053 mg/L	X	0.005 mg/L	05/30/24
208 room 2 sink 05202414-9	EPA 200.8 Lead	0.0039 mg/L		0.005 mg/L	05/30/24
210 room 11 sink 05202414-10	EPA 200.8 Lead	0.0026 mg/L		0.005 mg/L	05/30/24

PO Box 733  
Marlboro, NY 12542  
Phone 845-236-7823  
Fax 845-236-3911  
NYSDOH #10824

## **ENVIRONMENTAL LABWORKS, INC.**

**Myer Elementary School - 05202414**


LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
209 room 5 sink 05202414-11	EPA 200.8 Lead	0.0017 mg/L		0.005 mg/L	05/30/24

Qualifier(Q):

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi  
Technical Director