

ENVIRONMENTAL LABWORKS, INC.

November 13, 2024

Kingston Central School District
21 Wynkoop Place
Kingston, NY 12401

Dear James,

The following are results of the analyses performed on water samples from **Graves Elementary School** received at the laboratory on 10/23/24.

Date/Time Collected: 10/19/24 8:51-9:28am First Draw
Collected By: Kingston CSD
Project ID: 10232414
Secondary ID: KS244604-31

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
453 Faucet Kitchen Right 10232414-1	EPA 200.8 Lead	0.0074 mg/L	X	0.005 mg/L	10/29/24
452 Faucet Kitchen Left 10232414-2	EPA 200.8 Lead	0.0023 mg/L		0.005 mg/L	10/29/24
451 Café Bubbler 10232414-3	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
452 Café Bottle Filler 10232414-4	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
454 Fac Kitchen Faucet 10232414-5	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/30/24
458 Rm 18 Faucet 10232414-6	EPA 200.8 Lead	0.0017 mg/L		0.005 mg/L	10/29/24
456 Rm 23 Faucet 10232414-7	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
457 Rm 20 Faucet 10232414-8	EPA 200.8 Lead	0.0022 mg/L		0.005 mg/L	10/29/24
456 Rm 21 Faucet 10232414-9	EPA 200.8 Lead	0.0098 mg/L	X	0.005 mg/L	10/29/24
454 Rm 22 Faucet 10232414-10	EPA 200.8 Lead	0.0036 mg/L		0.005 mg/L	10/29/24

ENVIRONMENTAL LABWORKS, INC.

Graves Elementary School - 10232414

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
463 Faculty Bath Faucet o/s Con 10232414-11	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
459 4 th Grade Bubbler 10232414-12	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
460 4 th Grade Bottle Filler 10232414-13	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
461 Main Hall Bottle Filler 10232414-14	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
462 Main Hall Bubbler 10232414-15	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
468 Rm 8 Faucet 10232414-16	EPA 200.8 Lead	0.0139 mg/L	X	0.005 mg/L	10/29/24
467 Rm 10 Faucet 10232414-17	EPA 200.8 Lead	0.0015 mg/L		0.005 mg/L	10/29/24
466 Rm 11 Faucet 10232414-18	EPA 200.8 Lead	0.0020 mg/L		0.005 mg/L	10/29/24
465 Rm 14 Faucet 10232414-19	EPA 200.8 Lead	0.0075 mg/L	X	0.005 mg/L	10/29/24
464 Nurse Faucet 10232414-20	EPA 200.8 Lead	0.0010 mg/L		0.005 mg/L	10/29/24
472 Rm 4 Faucet 10232414-21	EPA 200.8 Lead	0.0019 mg/L		0.005 mg/L	10/29/24
473 Principal's Bath Faucet 10232414-22	EPA 200.8 Lead	0.0486 mg/L	X	0.005 mg/L	10/29/24
471 Rm 3 Faucet 10232414-23	EPA 200.8 Lead	0.0017 mg/L		0.005 mg/L	10/29/24
420 Rm 2 Faucet 10232414-24	EPA 200.8 Lead	0.0035 mg/L		0.005 mg/L	10/29/24
469 Rm 5 Faucet 10232414-25	EPA 200.8 Lead	0.0022 mg/L		0.005 mg/L	10/29/24

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
NYSDOH #10824

ENVIRONMENTAL LABWORKS, INC.

Graves Elementary School - 10232414


LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
474 Portable Faucet Left 10232414-26	EPA 200.8 Lead	0.160 mg/L	X	0.005 mg/L	10/30/24
473 Portable Faucet Center 10232414-27	EPA 200.8 Lead	0.269 mg/L	X	0.005 mg/L	10/30/24
475 Portable Faucet Right 10232414-28	EPA 200.8 Lead	0.0089 mg/L	X	0.005 mg/L	10/29/24

Qualifier(Q):

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director