

ENVIRONMENTAL LABWORKS, INC.

November 13, 2024

Kingston Central School District
21 Wynkoop Place
Kingston, NY 12401

Dear James,

The following are results of the analyses performed on water samples from
GW Elementary School received at the laboratory on 10/23/24.

Date/Time Collected: 10/19/24 5:17-10:45am First Draw
Collected By: Kingston CSD
Project ID: 10232413
Secondary ID: KS244567-603

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
505 Rm 126 Faucet 10232413-1	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
504 Rm 133 Faucet 10232413-2	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
503 Rm 129 Faucet 10232413-3	EPA 200.8 Lead	0.0042 mg/L		0.005 mg/L	10/29/24
502 Café Bottle Fill 10232413-4	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
501 Kitchen Left Faucet 10232413-5	EPA 200.8 Lead	0.0011 mg/L		0.005 mg/L	10/29/24
517 Auditorium Women's Faucet 10232413-6	EPA 200.8 Lead	0.0056 mg/L	X	0.005 mg/L	10/29/24
511 Rm 113 Faucet 10232413-7	EPA 200.8 Lead	0.0013 mg/L		0.005 mg/L	10/29/24
510 Rm 110 Faucet 10232413-8	EPA 200.8 Lead	0.0010 mg/L		0.005 mg/L	10/29/24
509 Rm 112 Faucet 10232413-9	EPA 200.8 Lead	0.0039 mg/L		0.005 mg/L	10/29/24
508 Rm 117 Faucet 10232413-10	EPA 200.8 Lead	0.0047 mg/L		0.005 mg/L	10/29/24

ENVIRONMENTAL LABWORKS, INC.

GW Elementary School - 10232413

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
507 Rm 118 Faucet 10232413-11	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
500 Kitchen Faucet Right 10232413-12	EPA 200.8 Lead	0.0013 mg/L		0.005 mg/L	10/29/24
518 Faucet Men's Auditorium 10232413-13	EPA 200.8 Lead	0.0083 mg/L	X	0.005 mg/L	10/29/24
512 Faucet Rm 108 10232413-14	EPA 200.8 Lead	0.0057 mg/L	X	0.005 mg/L	10/29/24
515 Rm 107 Faucet 10232413-15	EPA 200.8 Lead	0.0012 mg/L		0.005 mg/L	10/29/24
574 Rm 106 Faucet 10232413-16	EPA 200.8 Lead	0.0038 mg/L		0.005 mg/L	10/29/24
513 Rm 111 Faucet 10232413-17	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
506 Main Office Bottle Fill 10232413-18	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
516 Rm 101 Faucet 10232413-19	EPA 200.8 Lead	0.0012 mg/L		0.005 mg/L	10/29/24
519 Rm 214 Faucet 10232413-20	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
520 Rm 219 Faucet 10232413-21	EPA 200.8 Lead	0.0116 mg/L	X	0.005 mg/L	10/29/24
521 Rm 217 Faucet 10232413-22	EPA 200.8 Lead	0.0048 mg/L		0.005 mg/L	10/29/24
522 Rm 212 Faucet 10232413-23	EPA 200.8 Lead	0.0078 mg/L	X	0.005 mg/L	10/29/24
523 Rm 210 Faucet 10232413-24	EPA 200.8 Lead	0.0013 mg/L		0.005 mg/L	10/29/24
536 Rm 002 Faucet 10232413-25	EPA 200.8 Lead	0.0066 mg/L	X	0.005 mg/L	10/29/24

ENVIRONMENTAL LABWORKS, INC.

GW Elementary School - 10232413

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
533 Rm 010 Faucet 10232413-26	EPA 200.8 Lead	0.0010 mg/L		0.005 mg/L	10/29/24
535 Rm 001 Faucet 10232413-27	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
534 Rm 003 Faucet 10232413-28	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
530 Rm 007 Faucet 10232413-29	EPA 200.8 Lead	0.0033 mg/L		0.005 mg/L	10/29/24
532 Girls Rm across 005 10232413-30	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
527 Upstairs Bottle Filler 10232413-31	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
525 Girls Upstairs Faucet 10232413-32	EPA 200.8 Lead	0.0016 mg/L		0.005 mg/L	10/29/24
531 Rm 005 Faucet 10232413-33	EPA 200.8 Lead	0.0010 mg/L		0.005 mg/L	10/29/24
526 Rm 207 Faucet 10232413-34	EPA 200.8 Lead	0.0036 mg/L		0.005 mg/L	10/29/24
529 Rm 16 Faucet 10232413-35	EPA 200.8 Lead	0.0020 mg/L		0.005 mg/L	10/29/24
524 Rm 213 Faucet 10232413-36	EPA 200.8 Lead	0.0058 mg/L	X	0.005 mg/L	10/29/24
528 Rm 203 Faucet 10232413-37	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24

Qualifier(Q):

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.


PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
NYSDOH #10824

ENVIRONMENTAL LABWORKS, INC.

GW Elementary School - 10232413

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director