

ENVIRONMENTAL LABWORKS, INC.

November 13, 2024

Kingston Central School District
21 Wynkoop Place
Kingston, NY 12401

Dear James,

The following are results of the analyses performed on water samples from **JFK Elementary School** received at the laboratory on 10/23/24.

Date/Time Collected: 10/19/24 7:48-8:28am First Draw
Collected By: Kingston CSD
Project ID: 10232415
Secondary ID: KS244632-61

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
420 Rm 204 Faucet 10232415-1	EPA 200.8 Lead	0.0094 mg/L	X	0.005 mg/L	10/29/24
421 Rm 203 Faucet 10232415-2	EPA 200.8 Lead	0.0073 mg/L	X	0.005 mg/L	10/29/24
422 Rm 206 Faucet 10232415-3	EPA 200.8 Lead	0.0040 mg/L		0.005 mg/L	10/29/24
423 Rm 205 Faucet 10232415-4	EPA 200.8 Lead	0.0065 mg/L	X	0.005 mg/L	10/29/24
424 Rm 207 Faucet 10232415-5	EPA 200.8 Lead	0.0104 mg/L	X	0.005 mg/L	10/29/24
415 Rm 106 Faucet 10232415-6	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
416 Rm 103 Faucet 10232415-7	EPA 200.8 Lead	0.0018 mg/L		0.005 mg/L	10/29/24
417 Rm 104 Faucet 10232415-8	EPA 200.8 Lead	0.0020 mg/L		0.005 mg/L	10/29/24
418 Rm 102 Faucet 10232415-9	EPA 200.8 Lead	0.0025 mg/L		0.005 mg/L	10/29/24
419 Rm 202 Faucet 10232415-10	EPA 200.8 Lead	0.0065 mg/L	X	0.005 mg/L	10/29/24

ENVIRONMENTAL LABWORKS, INC.

JFK Elementary School - 10232415

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
410 Rm 113 Faucet 10232415-11	EPA 200.8 Lead	0.0065 mg/L	X	0.005 mg/L	10/29/24
411 Rm 111 Faucet 10232415-12	EPA 200.8 Lead	0.0043 mg/L		0.005 mg/L	10/29/24
412 Rm 109 Faucet 10232415-13	EPA 200.8 Lead	0.0091 mg/L	X	0.005 mg/L	10/29/24
413 Rm 108 Faucet 10232415-14	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
414 Rm 105 Faucet 10232415-15	EPA 200.8 Lead	0.0013 mg/L		0.005 mg/L	10/29/24
401 Café Bottle Filler 10232415-16	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
404 Rm 122 Faucet 10232415-17	EPA 200.8 Lead	0.0037 mg/L		0.005 mg/L	10/29/24
407 Principal's Bath Faucet 10232415-18	EPA 200.8 Lead	0.0016 mg/L		0.005 mg/L	10/29/24
408 Fac Rm Faucet 10232415-19	EPA 200.8 Lead	0.0051 mg/L	X	0.005 mg/L	10/29/24
409 Nurse Faucet 10232415-20	EPA 200.8 Lead	0.0048 mg/L		0.005 mg/L	10/29/24
402 Rm 129 Faucet 10232415-21	EPA 200.8 Lead	0.0019 mg/L		0.005 mg/L	10/29/24
400 Kitchen Faucet 10232415-22	EPA 200.8 Lead	0.0168 mg/L	X	0.005 mg/L	10/29/24
405 Bubbler Main Hall 10232415-23	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24
404 Rm 120 10232415-24	EPA 200.8 Lead	0.0016 mg/L		0.005 mg/L	10/29/24
406 Main Hall Bottle Fill 10232415-25	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	10/29/24

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
NYSDOH #10824

ENVIRONMENTAL LABWORKS, INC.

JFK Elementary School - 10232415


LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
427 Rm 211 Faucet 10232415-26	EPA 200.8 Lead	0.0030 mg/L		0.005 mg/L	10/29/24
425 Rm 210 Faucet 10232415-27	EPA 200.8 Lead	0.0021 mg/L		0.005 mg/L	10/29/24
426 Rm 209 Faucet 10232415-28	EPA 200.8 Lead	0.0028 mg/L		0.005 mg/L	10/29/24
429 Upstairs Fac Bath Faucet 10232415-29	EPA 200.8 Lead	0.0014 mg/L		0.005 mg/L	10/29/24
428 Rm 213 Faucet 10232415-30	EPA 200.8 Lead	0.0107 mg/L	X	0.005 mg/L	10/29/24

Qualifier(Q):

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director