Lead Sample Test Results and Actions

LINCOLN ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 001		No				
FX 002	Rm A1 Sink	Yes	0.002			No Action Required
FX 003		No				
FX 004		No				
FX 005		No				
FX 006		No				
FX 007		No				
FX 008		No				
FX 009		No				
FX 010		No				
FX 011		No				
FX 012		No				
FX 013		No				
FX 014	Rm 4A Sink	Yes	0.004			No Action Required
FX 015		No				
FX 016		No				
FX 017		No				
FX 018		No				
FX 019		No				
FX 020		No				
FX 021		No				
FX 022		No				
FX 023		No				
FX 024		No				
FX 025		No				
FX 026		No				
FX 027		No				
FX 028	Rm 4 Sink	Yes	0.001			No Action Required
FX 029		No				

Lead Sample Test Results and Actions

LINCOLN ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 030		No				
FX 031	Rm 5 Sink	Yes	0.002			No Action Required
FX 032		No				
FX 033		No				
FX 034		No				
FX 035		No				
FX 036		No				
FX 037		No				
FX 038	Kitchen Sink	Yes	0.001			No Action Required
FX 039		No				
FX 040		No				
FX 041		No				
FX 042		No				
FX 043	Sink Main Office	Yes	0.0009			No Action Required
FX 044		No				
FX 045		No				
FX 046		No				
FX 047		No				
FX 048	Fountain by girls RR	Yes	0.002			No Action Required
FX 049		No				
FX 050	Bottle Boys RR	Yes	0.0009			No Action Required
FX 051		No				
FX 052		No				
FX 053		No				
FX 054		No				
FX 055		No				
FX 056		No				
FX 057		No				
FX 058		No				
FX 059		No				
FX 060	Rm 7 Sink	Yes	0.0009			No Action Required

Lead Sample Test Results and Actions

LINCOLN ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 061		No				
FX 062		No				
FX 063	Rm 10 Sink	Yes	0.002			No Action Required
FX 064		No				
FX 065		No				
FX 066		No				
FX 067		No				
FX 068		No				
FX 069		No				
FX 070		No				
FX 071		No				
FX 072	Rm 15 Sink	Yes	0.0009			No Action Required
FX 073		No				
FX 074	Rm 16 Sink	Yes	0.001			No Action Required
FX 075		No				
FX 076		No				
FX 077		No				
FX 078		No				
FX 079		No				
FX 080		No				
FX 081		No				
FX 082		No				
FX 083		No				
FX 084		No				
FX 085		No				
FX 086		No				
FX 087		No				
FX 088		No				
FX 089		No				
FX 090		No				
FX 091		No				
FX 092		No				
FX 093	A Hall Bottle Filler	Yes	0.0009			No Action Required
FX 094		No				

Lead Sample Test Results and Actions

LINCOLN ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 095		No				
FX 096	Main Hall bottle filler	Yes	0.0009			No Action Required