

Lead Sample Test Results and Actions

LONGFELLOW ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 µg/L less than 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 001	Bottle Filler TL Hall	Yes	0.0009			No Action Required
FX 002		No				
FX 003		No				
FX 004		No				
FX 005		No				
FX 006		No				
FX 007	Kitchen Sink/Bottle Filler	Yes	0.0009			No Action Required
FX 008	Bottle Filler TL Hall	Yes	0.0009			No Action Required
FX 009		No				
FX 010	Bottle Filler K-2 Hall	Yes	0.0009			No Action Required
FX 011		No				
FX 012	Bottle Filler 4-6 Hall	Yes	0.0009			No Action Required
FX 013		No				
FX 014		No				
FX 015	Bottle Filler By Library	Yes	0.0009			No Action Required
FX 016		No				
FX 017		No				
FX 018	Bottle Filler 2-3 Hall	Yes	0.0009			No Action Required
FX 019		No				
FX 020		No				
FX 021		No				
FX 022		No				
FX 023		No				
FX 024		No				
FX 025		No				
FX 026		No				
FX 027		No				
FX 028		No				
FX 029		No				
FX 030		No				
FX 031	Rm 106 Sink	Yes	0.0009			No Action Required
FX 032		No				
FX 033	Rm 107 Sink	Yes	0.0009			No Action Required
FX 034	Rm 108 Sink	Yes	0.0009			No Action Required
FX 035		No				
FX 036		No				

Lead Sample Test Results and Actions

LONGFELLOW ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 µg/L less than 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 037		No				
FX 038		No				
FX 039	Rm 118 Sink	Yes	0.0009			No Action Required
FX 040		No				
FX 041		No				
FX 042		No				
FX 043	Rm 120 Sink	Yes	0.0009			No Action Required
FX 044		No				
FX 045		No				
FX 046	Rm 121 Sink	Yes	0.0009			No Action Required
FX 047		No				
FX 048		No				
FX 049	Rm 123 Sink	Yes	0.0009			No Action Required
FX 050		No				
FX 051		No				
FX 052		No				
FX 053	Rm 201 Sink	Yes	0.0009			No Action Required
FX 054		No				
FX 055	Rm 203 Sink	Yes	0.0009			No Action Required
FX 056	Rm 204 Sink	Yes	0.001			No Action Required
FX 057		No				
FX 058	Rm 206 Sink	Yes	0.0009			No Action Required
FX 059		No				
FX 060	Rm 212 Sink	Yes	0.0009			No Action Required
FX 061		No				
FX 062		No				
FX 063		No				
FX 064	Rm 214 Sink	Yes	0.001			No Action Required
FX 065		No				
FX 066	Rm 215 Sink	Yes	0.0009			No Action Required
FX 067		No				
FX 068		No				
FX 069		No				
FX 070	Rm 217 Sink	Yes	0.0009			No Action Required
FX 071		No				
FX 072		No				

Lead Sample Test Results and Actions

LONGFELLOW ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations greater than 5.0 µg/L less than 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 073		No				
FX 074		No				
FX 075	Kitchen Sink	Yes	0.0009			No Action Required
FX 076		No				
FX 077		No				
FX 078		No				
FX 079		No				
FX 080		No				
FX 081		No				
FX 082		No				
FX 083		No				
FX 084		No				