Lead Sample Test Results and Actions

LEWIS AND CLARK ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 001		No				
FX 002		No				
FX 003		No				
FX 004		No				
FX 005	MH bottle filler	Yes	0.0009			No Action Requried
FX 006		No				
FX 007		No				
FX 008	Sink Rm 1	Yes	0.001			No Action Required
FX 009		No				
FX 010		No				
FX 011		No				
FX 012	Rm 5 sink	Yes	0.0009			No Action Required
FX 013		No				
FX 014		No				
FX 015		No				
FX 016		No				
FX 017		No				
FX 018		No				
FX 019	Boys low fountain	Yes	0.0009			No Action Required
FX 020		No				
FX 021		No				
FX 022		No				
FX 023		No				
FX 024		No				
FX 025		No				
FX 026	Girls low fountain	Yes	0.0009			No Action Required
FX 027	Sink Rm 7	Yes	0.0009			No Action Required
FX 028		No				
FX 029	Sink Rm 17	Yes	0.0009			No Action Required
FX 030						
FX 031		No				
FX 032		No				
FX 033	Sink Rm 9	Yes	0.0009			No Action Required
FX 034	Bottle Filler Gym hall	Yes	0.0009			No Action Required
FX 035		No				

Lead Sample Test Results and Actions

LEWIS AND CLARK ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 036		No				
FX 037		No				
FX 038		No				
FX 039		No				
FX 040		No				
FX 041		NO				
FX 042		No				
FX 043	Sink Rm 12	Yes	0.0009			No Action Required
FX 044		No				
FX 045	Sink Rm 13	Yes	0.0009			No Action Required
FX 046		No				
FX 047		No				
FX 048		No				
FX 049		No				
FX 050	Sink Rm 16	Yes	0.0009			No Action Required
FX 051		No				
FX 052		No				
FX 053	Bottle Filler East Hall	Yes	0.0009			No Action Required
FX 054	Sink Rm 19	Yes	0.0009			No Action Required
FX 055		No				
FX 056		No				
FX 057		No				
FX 058		No				
FX 059		No				
FX 060	Sink Rm 22	Yes	0.0009			No Action Required
FX 061		No				
FX 062	Sink Rm 23	Yes	0.0009			No Action Required
FX 063		No				
FX 064		No				
FX 065		No				
FX 066		No				
FX 067		No				
FX 068	Sink Rm 26	Yes	0.0009			
FX 069		No				
FX 070		No				

Lead Sample Test Results and Actions

LEWIS AND CLARK ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 071		No				
FX 072		No				
FX 073	Kitchen Sink	Yes	0.0009			No Action Required
FX 074		No				