

Lead Sample Test Results and Actions

SKYLINE EARLY LEARNING CENTER

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 001		No				
FX 002		No				
FX 003		No				
FX 004		No				
FX 005		No				
FX 006		No				
FX 007		No				
FX 008	Bottle filler bus entry	Yes	0.0009			No action required
FX 009		No				
FX 010		No				
FX 011		No				
FX 012		No				
FX 013		No				
FX 014		No				
FX 015		No				
FX 016	Sink Room 26	Yes	0.001			No action required
FX 017		No				
FX 018		No				
FX 019		No				
FX 020		No				
FX 021		No				
FX 022	Sink Room 22	Yes	0.0009			No action required
FX 023		No				
FX 024		No				
FX 025	Sink Room 21	Yes	0.0009			No action required
FX 026		No				
FX 027		No				
FX 028		No				
FX 029		No				
FX 030		No				
FX 031	Fountain N Pod Hall	Yes	0.001			No action required
FX 032	Sink in kitchen	Yes	0.0009			No action required
FX 033		No				
FX 034		No				

Lead Sample Test Results and Actions

SKYLINE EARLY LEARNING CENTER

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 035		No				
FX 036		No				
FX 037		No				
FX 038		No				
FX 039		No				
FX 040		No				
FX 041		No				
FX 042		No				
FX 043		No				
FX 044		No				
FX 045		No				
FX 046	Fountain Rm 9 Comms	Yes	0.0009			No action required
FX 047	Sink room west pod	Yes	0.0009			No action required
FX 048		No				
FX 049		No				
FX 050		No				
FX 051	Bottle filler by Rm 1	Yes	0.0009			No action required
FX 052		No				
FX 053		No				
FX 054	Sink Room 1	Yes	0.0009			No action required
FX 055		No				
FX 056		No				
FX 057		No				
FX 058		No				
FX 059		No				
FX 060		No				
FX 061		No				
FX 062		No				
FX 063		No				
FX 064		No				
FX 065	Fountain Room 7	Yes	0.0009			No action required
FX 066						