Lead Sample Test Results and Actions

RIVERVIEW ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 001		No				
FX 002		No				
FX 003		No				
FX 004		No				
FX 005		No				
FX 006		No				
FX 007		No				
FX 008		No				
FX 009		No				
FX 010	Kitchen sink west wall	Yes	0.0009			No action required
FX 011		No				
FX 012		No				
FX 013	Cafeteria fountain	Yes	0.004			No action required
FX 014	Fountain West Hall low	Yes	0.0009			No action required
FX 015		No				
FX 016		No				
FX 017		No				
FX 018		No				
FX 019	Room K1 fountain	Yes	0.010		Must be fixed, replaced or removed	
FX 020		No				
FX 021		No				
FX 022		No				
FX 023	Room K2 fountain	Yes	0.003			No action required
FX 024		No				
FX 025		No				
FX 026	Sink Aid Room	Yes	0.001			No Action Required
FX 027		No				
FX 028		No				
FX 029	Room A1 fountain	Yes	0.001			No action required
FX 030		No				
FX 031		No				
FX 032		No				
FX 033		No				
FX 034		No				
FX 035		No				

Lead Sample Test Results and Actions

RIVERVIEW ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 036		No				
FX 037		No				
FX 038		No				
FX 039	Room A6 fountain	Yes	0.002			No action required
FX 040		No				
FX 041		No				
FX 042		No				
FX 043	Room B2 fountain	Yes	0.001			No action required
FX 044		No				
FX 045		No				
FX 046		No				
FX 047		No				
FX 048		No				
FX 049	Room B5 fountain	Yes	0.001			No action required
FX 050		No				
FX 051		No				
FX 052		No				
FX 053	Room C1 fountain	Yes	0.003			No action required
FX 054		No				
FX 055		No				
FX 056		No				
FX 057		No				
FX 058		No				
FX 059		No				
FX 060		No				
FX 061		No				
FX 062		No				
FX 063	Room C6 fountain	Yes	0.002			No action required
FX 064		No				
FX 065		No				
FX 066		No				
FX 067	Boys Hall Bottle filler	Yes	0.0009			No action required
FX 068		No				
FX 069		No				
FX 070	Girls Hall Bottle filler	Yes	0.0009			No action required

Lead Sample Test Results and Actions

RIVERVIEW ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 070A		No				
FX 071		No				
FX 072		No				
FX 073	Bottle filler C hall	Yes	0.0009			No action required
FX 074		No				
FX 075		No				