Lead Sample Test Results and Actions

VALLEY VIEW ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 -Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 001		No				
FX 002		No				
FX 003	Rm A2 Fountain	Yes	0.0009			No Action Required
FX 004		No				
FX 005		No				
FX 006		No				
FX 007		No				
FX 008		No				
FX 009	Rm A5 Fountain	Yes	0.001			No Action Required
FX 010		No				
FX 011		No				
FX 012		No				
FX 013	Bottle Filler Main Hall	Yes	0.0009			No Action Required
FX 014		No				
FX 015		No				
FX 016		No				
FX 017		No				
FX 018		No				
FX 019		No				
FX 020		No				
FX 021		No				
FX 022	Rm K2 Fountain	Yes	0.0009			No Action Required
FX 023		No				
FX 024		No				
FX 025	Kitchen Sink	Yes	0.0009			No Action Required
FX 026		No				
FX 027		No				
FX 028		No				
FX 029		No				
FX 030		No				

Lead Sample Test Results and Actions

VALLEY VIEW ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 -Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 031		No				
FX 032		No				
FX 033		No				
FX 034		No				
FX 035	Rm B1 Fountain	Yes	0.003			No Action Required
FX 036		No				
FX 037		No				
FX 038		No				
FX 039		No				
FX 040		No				
FX 041	Rm B4 Fountain	Yes	0.001			No Action Required
FX 042		No				
FX 043	Rm C1 Fountain	Yes	0.001			No Action Required
FX 044		No				
FX 045		No				
FX 046		No				
FX 047	Rm C3 Fountain	Yes	0.002			No Action Required
FX 048		No				
FX 049	Rm C4 Fountain	Yes	0.002			No Action Required
FX 050		No				
FX 051		No				
FX 052		No				
FX 053	Rm C6 Fountain	Yes	0.001			No Action Required
FX 054		No				
FX 055		No				
FX 056		No				
FX 057		No				
FX 058		No				
FX 059		No				
FX 060		No				
FX 061		No				

Lead Sample Test Results and Actions

VALLEY VIEW ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 -Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 062		No				
FX 063		No				
FX 064	Rm B6 Fountain	Yes	0.001			No Action Required
FX 065		No				
FX 066		No				
FX 067	Cwing Bottle Filler	Yes	0.0009			No Action Required
FX 068		No				
FX 069	Bwing Hall Fountain	Yes	0.003			No Action Required