

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 001		No				
FX 002		No				
FX 003	Fountain Gym	Yes	0.0009			No Action Required
FX 004		No				
FX 005		No				
FX 006		No				
FX 007		No				
FX 008		No				
FX 009		No				
FX 010	K Fountain	Yes	0.001			No Action Required
FX 011		No				
FX 012	K Fountain	Yes	0.001			No Action Required
FX 013		No				
FX 014		No				
FX 015		No				
FX 016		No				
FX 017		No				
FX 018		No				
FX 019	Main Hall	Yes	0.0009			No Action Required
FX 020		No				
FX 021	Kitchen Sink	Yes	0.002			No Action Required
FX 022		No				
FX 023		No				
FX 024		No				
FX 025		No				
FX 026	Music/Art Rm	Yes	0.004			No Action Required
FX 027		No				

FX 028		No				
FX 029		No				
FX 030		No				
FX 031		No				
FX 032	Cmp Lab	Yes	0.006			No Action Required
FX 033		No				
FX 034		No				
FX 035		No				
FX 036		No				
FX 037	5th/6th Bottle	Yes	0.0009			No Action Required
FX 038		No				
FX 039	5th/6th High	Yes	0.0009			No Action Required
FX 040		No				
FX 041		No				
FX 042		No				
FX 043		No				
FX 044		No				
FX 045	3rd/4th High	Yes	0.0009			No Action Required
FX 045	3rd/4th Bottle	Yes	0.0009			No Action Required
FX 046		No				
FX 047		No				
FX 048		No				
FX 049		No				
FX 050		No				
FX 051		No				
FX 052		No				
FX 053	Rm 1st/2nd	Yes	0.0009			No Action Required
FX 054		No				
FX 055	Rm 1st/2nd H	Yes	0.0009			No Action Required
FX 056		No				

FX 057		No				
FX 058		No				
FX 059	Library Fountain	Yes	0.001			No Action Required