

Lead Sample Test Results and Actions

SACAJAWEA ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 001		No				
FX 002		No				
FX 003		No				
FX 004	Kitchen Sink	Yes	0.002			No Action Required
FX 005		No				
FX 006		No				
FX 007	West Hall Bottle Filler	Yes	0.0009			No Action Required
FX 008		No				
FX 009		No				
FX 010		No				
FX 011		No				
FX 012	Cafeteria Fountain	Yes	0.0009			No Action Required
FX 013		No				
FX 014		No				
FX 015		No				
FX 016		No				
FX 017	Rm A1 Fountain	Yes	0.002			No Action Required
FX 018		No				
FX 019		No				
FX 020		No				
FX 021		No				
FX 022		No				
FX 023		No				
FX 024		No				
FX 025		No				
FX 026		No				
FX 027	Rm A6 Fountain	Yes	0.001			No Action Required
FX 028		No				
FX 029		No				
FX 030	Rm K1 Fountain	Yes	0.003			No Action Required

Lead Sample Test Results and Actions

SACAJAWEA ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 031		No				
FX 032		No				
FX 033		No				
FX 034		No				
FX 035		No				
FX 036	Rm C2 Fountain	Yes	0.001			No Action Required
FX 037		No				
FX 038		No				
FX 039		No				
FX 040		No				
FX 041		No				
FX 042		No				
FX 043		No				
FX 044	Rm C6 Fountain	Yes	0.001			No Action Required
FX 045		No				
FX 046		No				
FX 047	SE Hall Bottle Filler	Yes	0.0009			No Action Required
FX 048		No				
FX 049		No				
FX 050		No				
FX 051		No				
FX 052		No				
FX 053	SW Hall Fountain	Yes	0.003			No Action Required
FX 054		No				
FX 055		No				
FX 056		No				
FX 057		No				
FX 058		No				
FX 059		No				
FX 060		No				

Lead Sample Test Results and Actions

SACAJAWEA ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 061	Rm B6 Fountain	Yes	0.002			No Action Required
FX 062		No				
FX 063		No				
FX 064		No				
FX 065		No				
FX 066		No				
FX 067		No				
FX 068		No				
FX 069		No				
FX 070		No				
FX 071	Rm B1 Fountain	Yes	0.0009			No Action Required
FX 072		No				
FX 073		No				
FX 074	B Hall Bottle Filler	Yes	0.0009			No Action Required
FX 075		No				
FX 076		No				
FX 077		No				
FX 078	Health Rm Sink	Yes	0.0009			No Action Required