

Lead Sample Test Results and Actions

WEST ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 001		No				
FX 002	Rm 1 Fountain	Yes	0.002			No Action Required
FX 003		No				
FX 004		No				
FX 005		No				
FX 006		No				
FX 007		No				
FX 008	Rm 4 Fountain	Yes	0.0009			
FX 009		No				
FX 010		No				
FX 011		No				
FX 012	Kitchen Sink	Yes	0.0009			No Action Required
FX 013		No				
FX 014		No				
FX 015		No				
FX 016		No				
FX 017		No				
FX 018		No				
FX 019		No				
FX 020		No				
FX 021		No				
FX 022		No				
FX 023		No				
FX 024		No				
FX 025		No				
FX 026		No				
FX 027		No				
FX 028		No				
FX 029		No				
FX 030		No				
FX 031		No				
FX 032		No				
FX 033	Rm 8 Fountain	Yes	0.003			No Action Required
FX 034		No				

Lead Sample Test Results and Actions

WEST ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 035		No				
FX 036		No				
FX 037		No				
FX 038		No				
FX 039		No				
FX 040		No				
FX 041		No				
FX 042		No				
FX 043		No				
FX 044		No				
FX 045	Bottle Filler Main Hall	Yes	0.0009			No Action Required
FX 046		No				
FX 047		No				
FX 048		No				
FX 049		No				
FX 050		No				
FX 051		No				
FX 052		No				
FX 053		No				
FX 054		No				
FX 055		No				
FX 056		No				
FX 057		No				
FX 058		No				
FX 059		No				
FX 060		No				
FX 061		No				
FX 062		No				
FX 063		No				
FX 064		No				
FX 065		No				
FX 066		No				
FX 067		No				
FX 068		No				

Lead Sample Test Results and Actions

WEST ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 069		No				
FX 070		No				
FX 071		No				
FX 072		No				
FX 073		No				
FX 074		No				
FX 075		No				
FX 076		No				
FX 077	Rm 12 Fountain	Yes	0.004			No Action Required
FX 078		No				
FX 079		No				
FX 080		No				
FX 081		No				
FX 082		No				
FX 083		No				
FX 084		No				
FX 085		No				
FX 086		No				
FX 087		No				
FX 088		No				
FX 089		No				
FX 090	Bottle Filler S Hall B	Yes	0.0009			No Action Required
FX 091		No				
FX 092	Bottle Filler S Hall G	Yes	0.002			No Action Required
FX 093	Rm 15 Sink	Yes	0.004			No Action Required
FX 094		No				
FX 095		No				
FX 096		No				
FX 097		No				
FX 098	Rm 18 Fountain	Yes	0.002			No Action Required
FX 099		No				
FX 100		No				
FX 101		No				
FX 102	Rm 20 Fountain	Yes	0.001			No Action Required

Lead Sample Test Results and Actions

WEST ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 103		No				
FX 104		No				
FX 105		No				
FX 106		No				
FX 107	Rm 23 Sink	Yes	0.0009			No Action Required
FX 108		No				
FX 109		No				
FX 110		No				
FX 111		No				
FX 112	Rm 25 Fountain	Yes	0.002			No Action Required
FX 113		No				
FX 114		No				
FX 115		No				
FX 116		No				
FX 117		No				
FX 118	Rm 26 Fountain	Yes	0.0009			No Action Required
FX 119		No				
FX 120		No				
FX 121	Rm 28 Sink	Yes	0.0009			No Action Required
FX 122		No				
FX 123		No				
FX 124		No				
FX 125		No				
FX 126	Rm 30 Fountain	Yes	0.0009			No Action Required
FX 127		No				
FX 128	Rm 31 Fountain	Yes	0.003			No Action Required
FX 129		No				
FX 130		No				
FX 131	Rm 35 Sink	Yes	0.002			No Action Required
FX 132		No				
FX 133		No				
FX 134		No				
FX 135		No				
FX 136		No				
FX 137		No				

Lead Sample Test Results and Actions

WEST ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 138		No				
FX 139		No				
FX 140		No				
FX 141	Bottle Filler N Hall G	Yes	0.0009			No Action Required
FX 142		No				
FX 143		No				
FX 144	Bottle Filler N Hall B	Yes	0.0009			No Action Required