

Lead Sample Test Results and Actions

WHITTIER ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 001		No				
FX 002		No				
FX 003	Bottle filler 1/F	Yes	0.0009			No action required
FX 004		No				
FX 005		No				
FX 006		No				
FX 007	Rm 8 fountain	Yes	0.001			No action required
FX 008		No				
FX 009		No				
FX 010	Rm 10 Fountain	Yes	0.0009			No action required
FX 011		No				
FX 012	Rm 11 Fountain	Yes	0.0009			No action required
FX 013		No				
FX 014		No				
FX 015	Kitchen sink	Yes	0.004			No action required
FX 016		No				
FX 017		No				
FX 018		No				
FX 019		No				
FX 020		No				
FX 021		No				
FX 022		No				
FX 023		No				
FX 024	Rm 1 Fountain	Yes	0.0009			No action required
FX 025		No				
FX 026		No				
FX 027		No				
FX 028		No				
FX 029		No				
FX 030		No				
FX 031		No				
FX 032		No				
FX 033	Rm 4 Fountain	Yes	0.0009			No action required
FX 034		No				

Lead Sample Test Results and Actions

WHITTIER ELEMENTARY SCHOOL

Fixture Number	Location	Part of Sampling Plan	Sampling Results (ppm)	Bin 1 - Lead concentrations greater than 15.0 micrograms per Liter (µg/L) – fixture must be immediately removed from service	Bin 2 - Lead concentrations equal or greater than 5.0 µg/L up to 15.0 µg/L – fixture must be fixed, replaced or removed from service	Bin 3 - Lead concentrations less than 5.0 µg/L – no action is required.
FX 035		No				
FX 036	Rm 5 fountain	Yes	0.0009			No action required
FX 037		No				
FX 038		No				
FX 039		No				
FX 040		No				
FX 041		No				
FX 042		No				
FX 043		No				
FX 044		No				
FX 045	Bottle filler 2/F	Yes	0.0009			No action required
FX 046		No				
FX 047	Rm 13 Fountain	Yes	0.0009			No action required
FX 048		No				
FX 049		No				
FX 050		No				
FX 051		No				
FX 052		No				
FX 053	Rm 17 Fountain	Yes	0.0009			No action required
FX 054		No				
FX 055	Rm 15 Fountain	Yes	0.0009			No action required
FX 056		No				
FX 057		No				